

June 09, 2021

David Crisafulli
Oswego City School District
1 Buccaneer Blvd
Oswego, NY 13126

RE: Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

Dear David Crisafulli:

Enclosed are the analytical results for sample(s) received by the laboratory on May 24, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Elizabeth Harrison
betty.harrison@pacelabs.com
(631)694-3040
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

Pace Analytical Services Long Island

Virginia Certification # 460302
Delaware Certification # NY10478
Delaware Certification # NY10478
575 Broad Hollow Rd, Melville, NY 11747
New York Certification #: 10478 Primary Accrediting Body
New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350
Connecticut Certification #: PH-0435
Maryland Certification #: 208
Rhode Island Certification #: LAO00340
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

Sample: CER KIT S. #1		Lab ID: 70174248001	Collected: 05/13/21 04:40	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.4	ug/L	1.0	1		06/08/21 21:10	7439-92-1	M1

Sample: CER KIT S. #2		Lab ID: 70174248002	Collected: 05/13/21 04:40	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/08/21 21:14	7439-92-1	

Sample: CER KIT SPRAYER #3		Lab ID: 70174248003	Collected: 05/13/21 04:40	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.6	ug/L	1.0	1		06/08/21 21:15	7439-92-1	

Sample: CER KIT HW S. #4		Lab ID: 70174248004	Collected: 05/13/21 04:40	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	9.9	ug/L	1.0	1		06/08/21 21:16	7439-92-1	

Sample: CER RM 155 CR		Lab ID: 70174248005	Collected: 05/13/21 04:45	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	40.5	ug/L	1.0	1		06/08/21 21:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

Sample: CER RM 155 BR	Lab ID: 70174248006	Collected: 05/13/21 04:45	Received: 05/24/21 11:35	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	30.3	ug/L	1.0	1		06/08/21 21:18	7439-92-1		
Sample: CER RM 157 CR	Lab ID: 70174248007	Collected: 05/13/21 04:46	Received: 05/24/21 11:35	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	71.6	ug/L	1.0	1		06/08/21 21:19	7439-92-1		
Sample: CER RM 165 CR	Lab ID: 70174248008	Collected: 05/13/21 04:50	Received: 05/24/21 11:35	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	2.1	ug/L	1.0	1		06/08/21 21:20	7439-92-1		
Sample: CER RM 167 CR	Lab ID: 70174248009	Collected: 05/13/21 04:52	Received: 05/24/21 11:35	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	2.2	ug/L	1.0	1		06/08/21 21:21	7439-92-1		
Sample: CER RM 169 CR	Lab ID: 70174248010	Collected: 05/13/21 04:52	Received: 05/24/21 11:35	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	10.2	ug/L	1.0	1		06/08/21 21:22	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

Sample: CER RM 168 CR		Lab ID: 70174248011	Collected: 05/13/21 04:54	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	252	ug/L	1.0	1		06/08/21 21:23	7439-92-1	

Sample: CER RM 166 CR		Lab ID: 70174248012	Collected: 05/13/21 05:00	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	60.4	ug/L	1.0	1		06/08/21 21:28	7439-92-1	

Sample: CER OLD LICK RM CR		Lab ID: 70174248013	Collected: 05/13/21 05:00	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	84.3	ug/L	1.0	1		06/08/21 21:29	7439-92-1	

Sample: CER RM 162 SLOP		Lab ID: 70174248014	Collected: 05/13/21 05:01	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	17.6	ug/L	1.0	1		06/08/21 21:30	7439-92-1	

Sample: CER RM 158 CR		Lab ID: 70174248015	Collected: 05/13/21 05:02	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	13.8	ug/L	1.0	1		06/08/21 21:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

Sample: CER RM 156 BR		Lab ID: 70174248016	Collected: 05/13/21 05:03	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	33.2	ug/L	1.0	1		06/08/21 21:32	7439-92-1	

Sample: CER ART RM 152 CR LEFT		Lab ID: 70174248017	Collected: 05/13/21 05:05	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/08/21 21:33	7439-92-1	

Sample: CER ART RM 152 CR RIGHT		Lab ID: 70174248018	Collected: 05/13/21 05:05	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.8	ug/L	1.0	1		06/08/21 21:34	7439-92-1	

Sample: CER ART RM 156 CR		Lab ID: 70174248019	Collected: 05/13/21 05:04	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	23.6	ug/L	1.0	1		06/08/21 21:35	7439-92-1	

Sample: CER KILN RM 152 CR		Lab ID: 70174248020	Collected: 05/13/21 05:06	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	92.7	ug/L	1.0	1		06/08/21 21:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

Sample: CER RM 174 SLOP		Lab ID: 70174248021	Collected: 05/13/21 05:12	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.2	ug/L	1.0	1		06/08/21 21:41	7439-92-1	

Sample: CER RM 176 CR		Lab ID: 70174248022	Collected: 05/13/21 05:13	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.8	ug/L	1.0	1		06/08/21 21:43	7439-92-1	

Sample: CER GYM HW BF		Lab ID: 70174248023	Collected: 05/13/21 05:14	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/08/21 21:44	7439-92-1	

Sample: CER CER RM 180 CR		Lab ID: 70174248024	Collected: 05/13/21 05:16	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	37.2	ug/L	1.0	1		06/08/21 21:45	7439-92-1	

Sample: CER RM 182 CR		Lab ID: 70174248025	Collected: 05/13/21 05:16	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	23.7	ug/L	1.0	1		06/08/21 21:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

Sample: CER RM 184 CR	Lab ID: 70174248026	Collected: 05/13/21 05:17	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	29.9	ug/L	1.0	1		06/08/21 21:49	7439-92-1	

Sample: CER RM 183 CR	Lab ID: 70174248027	Collected: 05/13/21 05:18	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	18.2	ug/L	1.0	1		06/08/21 21:50	7439-92-1	

Sample: CER RM 181 CR	Lab ID: 70174248028	Collected: 05/13/21 05:19	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	16.4	ug/L	1.0	1		06/09/21 10:59	7439-92-1	

Sample: CER RM 217 CR	Lab ID: 70174248029	Collected: 05/13/21 05:20	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	37.9	ug/L	1.0	1		06/08/21 21:52	7439-92-1	

Sample: CER RM 215 CR	Lab ID: 70174248030	Collected: 05/13/21 05:20	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	73.7	ug/L	1.0	1		06/08/21 21:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

Sample: CER HW BF NXT RM 215	Lab ID: 70174248031	Collected: 05/13/21 05:21	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/08/21 21:54	7439-92-1	
Sample: CER RM 204 SLOP	Lab ID: 70174248032	Collected: 05/13/21 05:23	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	16.1	ug/L	1.0	1		06/08/21 21:57	7439-92-1	
Sample: CER RM 212 CR	Lab ID: 70174248033	Collected: 05/13/21 05:28	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	15.0	ug/L	1.0	1		06/08/21 21:58	7439-92-1	
Sample: CER RM 214 CR	Lab ID: 70174248034	Collected: 05/13/21 05:28	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	17.8	ug/L	1.0	1		06/08/21 22:01	7439-92-1	
Sample: CER RM 216 CR	Lab ID: 70174248035	Collected: 05/13/21 05:28	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	36.1	ug/L	1.0	1		06/08/21 22:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING CER 5/13
 Pace Project No.: 70174248

Sample: CER STAFF BR		Lab ID: 70174248036	Collected: 05/13/21 05:19	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		06/08/21 22:03	7439-92-1	
Sample: CER BF NXT STAFF BR		Lab ID: 70174248037	Collected: 05/13/21 05:18	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/08/21 22:04	7439-92-1	
Sample: CER BOYS BR NXT APR		Lab ID: 70174248038	Collected: 05/13/21 05:17	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	11.1	ug/L	1.0	1		06/08/21 22:05	7439-92-1	
Sample: CER RM 123B SLOP		Lab ID: 70174248039	Collected: 05/13/21 05:20	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	8.2	ug/L	1.0	1		06/08/21 22:06	7439-92-1	
Sample: CER RM 134 CR		Lab ID: 70174248040	Collected: 05/13/21 04:36	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	31.6	ug/L	1.0	1		06/08/21 22:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

Sample: CER RM 121 KS		Lab ID: 70174248041	Collected: 05/13/21 04:40		Received: 05/24/21 11:35		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.5	ug/L	1.0	1		06/08/21 22:10	7439-92-1	

Sample: CER RM 101 BR		Lab ID: 70174248042	Collected: 05/13/21 04:42		Received: 05/24/21 11:35		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.4	ug/L	1.0	1		06/08/21 22:15	7439-92-1	

Sample: CER RM 109 BR		Lab ID: 70174248043	Collected: 05/13/21 04:50		Received: 05/24/21 11:35		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.7	ug/L	1.0	1		06/08/21 22:16	7439-92-1	

Sample: CER RM 109 CR		Lab ID: 70174248044	Collected: 05/13/21 04:50		Received: 05/24/21 11:35		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	55.1	ug/L	1.0	1		06/08/21 22:16	7439-92-1	

Sample: CER RM 11A SLOP		Lab ID: 70174248045	Collected: 05/13/21 04:57		Received: 05/24/21 11:35		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	15.6	ug/L	1.0	1		06/08/21 22:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

S, LLC
Road
1747
040

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

Sample: CER RM 113 BR	Lab ID: 70174248046	Collected: 05/13/21 05:00	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	13.5	ug/L	1.0	1		06/08/21 22:18	7439-92-1	

Sample: CER RM 113 CR	Lab ID: 70174248047	Collected: 05/13/21 05:01	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	37.5	ug/L	1.0	1		06/08/21 22:19	7439-92-1	

Sample: CER RM 115 BR	Lab ID: 70174248048	Collected: 05/13/21 05:04	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		06/08/21 22:20	7439-92-1	

Sample: CER RM 115 CR	Lab ID: 70174248049	Collected: 05/13/21 05:04	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		06/08/21 22:22	7439-92-1	

Sample: CER RM 117 BR	Lab ID: 70174248050	Collected: 05/13/21 05:09	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.0	ug/L	1.0	1		06/08/21 22:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

Sample: CER RM 117 CR		Lab ID: 70174248051	Collected: 05/13/21 05:11	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/08/21 22:25	7439-92-1	
Sample: CER RM 112 CR #1		Lab ID: 70174248052	Collected: 05/13/21 05:10	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.6	ug/L	1.0	1		06/08/21 22:28	7439-92-1	
Sample: CER RM 112 CR #2		Lab ID: 70174248053	Collected: 05/13/21 05:06	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.9	ug/L	1.0	1		06/08/21 22:29	7439-92-1	
Sample: CER RM 112 BR		Lab ID: 70174248054	Collected: 05/13/21 05:05	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		06/08/21 22:30	7439-92-1	
Sample: CER RM 110 CR		Lab ID: 70174248055	Collected: 05/13/21 04:59	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	31.6	ug/L	1.0	1		06/08/21 22:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

Sample: CER RM 110 BR	Lab ID: 70174248056	Collected: 05/13/21 05:00	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	11.8	ug/L	1.0	1		06/08/21 22:32	7439-92-1	
Sample: CER RM 108 BR	Lab ID: 70174248057	Collected: 05/13/21 05:00	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.0	ug/L	1.0	1		06/08/21 22:33	7439-92-1	
Sample: CER RM 108 CR	Lab ID: 70174248058	Collected: 05/13/21 04:54	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	16.2	ug/L	1.0	1		06/08/21 22:36	7439-92-1	
Sample: CER RM 106 BR	Lab ID: 70174248059	Collected: 05/13/21 04:48	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	8.3	ug/L	1.0	1		06/08/21 22:37	7439-92-1	
Sample: CER RM 106 CR	Lab ID: 70174248060	Collected: 05/13/21 04:48	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.5	ug/L	1.0	1		06/08/21 22:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

Sample: CER RM 104 CR		Lab ID: 70174248061	Collected: 05/13/21 04:48	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.9	ug/L	1.0	1		06/08/21 22:41	7439-92-1	

Sample: CER RM 104A CR		Lab ID: 70174248062	Collected: 05/13/21 04:48	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		06/08/21 22:44	7439-92-1	

Sample: CER RM 104 BR		Lab ID: 70174248063	Collected: 05/13/21 04:49	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.9	ug/L	1.0	1		06/08/21 22:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

QC Batch: 212479 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
Laboratory: Pace Analytical Services - Melville
Associated Lab Samples: 70174248001, 70174248002, 70174248003, 70174248004, 70174248005, 70174248006, 70174248007, 70174248008, 70174248009, 70174248010, 70174248011, 70174248012, 70174248013, 70174248014, 70174248015, 70174248016, 70174248017, 70174248018, 70174248019, 70174248020

METHOD BLANK: 1065371 Matrix: Water
Associated Lab Samples: 70174248001, 70174248002, 70174248003, 70174248004, 70174248005, 70174248006, 70174248007, 70174248008, 70174248009, 70174248010, 70174248011, 70174248012, 70174248013, 70174248014, 70174248015, 70174248016, 70174248017, 70174248018, 70174248019, 70174248020

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/08/21 21:08	

LABORATORY CONTROL SAMPLE: 1065372

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.1	102	85-115	

MATRIX SPIKE SAMPLE: 1065374

Parameter	Units	70174248001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.4	50	69.3	132	70-130	M1

MATRIX SPIKE SAMPLE: 1065376

Parameter	Units	70174248011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	252	50	310	116	70-130	

SAMPLE DUPLICATE: 1065373

Parameter	Units	70174248001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.4	3.4	1	

SAMPLE DUPLICATE: 1065375

Parameter	Units	70174248011 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	252	263	4	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

QC Batch:	212480	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70174248021, 70174248022, 70174248023, 70174248024, 70174248025, 70174248026, 70174248027, 70174248028, 70174248029, 70174248030, 70174248031, 70174248032, 70174248033, 70174248034, 70174248035, 70174248036, 70174248037, 70174248038, 70174248039, 70174248040		

METHOD BLANK: 1065378 Matrix: Water

Associated Lab Samples: 70174248021, 70174248022, 70174248023, 70174248024, 70174248025, 70174248026, 70174248027, 70174248028, 70174248029, 70174248030, 70174248031, 70174248032, 70174248033, 70174248034, 70174248035, 70174248036, 70174248037, 70174248038, 70174248039, 70174248040

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/08/21 21:39	

LABORATORY CONTROL SAMPLE: 1065379

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.7	101	85-115	

MATRIX SPIKE SAMPLE: 1065381

Parameter	Units	70174248021 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	5.2	50	65.1	120	70-130	

MATRIX SPIKE SAMPLE: 1065383

Parameter	Units	70174248031 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	62.3	124	70-130	

SAMPLE DUPLICATE: 1065380

Parameter	Units	70174248021 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	5.2	5.2	0	

SAMPLE DUPLICATE: 1065382

Parameter	Units	70174248031 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

QC Batch:	212481	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
Associated Lab Samples:	70174248041, 70174248042, 70174248043, 70174248044, 70174248045, 70174248046, 70174248047, 70174248048, 70174248049, 70174248050, 70174248051, 70174248052, 70174248053, 70174248054, 70174248055, 70174248056, 70174248057, 70174248058, 70174248059, 70174248060		
		Laboratory:	Pace Analytical Services - Melville

METHOD BLANK:	1065385	Matrix:	Water
Associated Lab Samples:	70174248041, 70174248042, 70174248043, 70174248044, 70174248045, 70174248046, 70174248047, 70174248048, 70174248049, 70174248050, 70174248051, 70174248052, 70174248053, 70174248054, 70174248055, 70174248056, 70174248057, 70174248058, 70174248059, 70174248060		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/08/21 22:08	

LABORATORY CONTROL SAMPLE:	1065386					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.0	102	85-115	

MATRIX SPIKE SAMPLE:	1065388						
Parameter	Units	70174248041 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L		5.5	50	63.4	116	70-130

MATRIX SPIKE SAMPLE:	1065390						
Parameter	Units	70174248051 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L		<1.0	50	57.0	112	70-130

SAMPLE DUPLICATE:	1065387					
Parameter	Units	70174248041 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	5.5	5.3	3		

SAMPLE DUPLICATE:	1065389					
Parameter	Units	70174248051 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

QC Batch: 212482 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
Laboratory: Pace Analytical Services - Melville
Associated Lab Samples: 70174248061, 70174248062, 70174248063

METHOD BLANK: 1065391 Matrix: Water
Associated Lab Samples: 70174248061, 70174248062, 70174248063

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/08/21 22:39	

LABORATORY CONTROL SAMPLE: 1065392

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.0	100	85-115	

MATRIX SPIKE SAMPLE: 1065394

Parameter	Units	70174248061 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.9	50	52.7	102	70-130	

SAMPLE DUPLICATE: 1065393

Parameter	Units	70174248061 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.9	1.8	3	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

DEFINITIONS

- DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.
- ND - Not Detected at or above adjusted reporting limit.
- TNTC - Too Numerous To Count
- J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.
- MDL - Adjusted Method Detection Limit.
- PQL - Practical Quantitation Limit.
- RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.
- S - Surrogate
1,2-Diphenylhydrazine decomposes and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.
Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.
- LCS(D) - Laboratory Control Sample (Duplicate)
- MS(D) - Matrix Spike (Duplicate)
- DUP - Sample Duplicate
- RPD - Relative Percent Difference
- NC - Not Calculable.
- SG - Silica Gel - Clean-Up
- U - Indicates the compound was analyzed for, but not detected.
N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.
Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.
- TNI - The NELAC Institute.

ANALYTE QUALIFIERS

M1 Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70174248001	CER KIT S. #1	EPA 200.8	212479		
70174248002	CER KIT S. #2	EPA 200.8	212479		
70174248003	CER KIT SPRAYER #3	EPA 200.8	212479		
70174248004	CER KIT HW S. #4	EPA 200.8	212479		
70174248005	CER RM 155 CR	EPA 200.8	212479		
70174248006	CER RM 155 BR	EPA 200.8	212479		
70174248007	CER RM 157 CR	EPA 200.8	212479		
70174248008	CER RM 165 CR	EPA 200.8	212479		
70174248009	CER RM 167 CR	EPA 200.8	212479		
70174248010	CER RM 169 CR	EPA 200.8	212479		
70174248011	CER RM 168 CR	EPA 200.8	212479		
70174248012	CER RM 166 CR	EPA 200.8	212479		
70174248013	CER OLD LICK RM CR	EPA 200.8	212479		
70174248014	CER RM 162 SLOP	EPA 200.8	212479		
70174248015	CER RM 158 CR	EPA 200.8	212479		
70174248016	CER RM 156 BR	EPA 200.8	212479		
70174248017	CER ART RM 152 CR LEFT	EPA 200.8	212479		
70174248018	CER ART RM 152 CR RIGHT	EPA 200.8	212479		
70174248019	CER ART RM 156 CR	EPA 200.8	212479		
70174248020	CER KILN RM 152 CR	EPA 200.8	212479		
70174248021	CER RM 174 SLOP	EPA 200.8	212480		
70174248022	CER RM 176 CR	EPA 200.8	212480		
70174248023	CER GYM HW BF	EPA 200.8	212480		
70174248024	CER CER RM 180 CR	EPA 200.8	212480		
70174248025	CER RM 182 CR	EPA 200.8	212480		
70174248026	CER RM 184 CR	EPA 200.8	212480		
70174248027	CER RM 183 CR	EPA 200.8	212480		
70174248028	CER RM 181 CR	EPA 200.8	212480		
70174248029	CER RM 217 CR	EPA 200.8	212480		
70174248030	CER RM 215 CR	EPA 200.8	212480		
70174248031	CER HW BF NXT RM 215	EPA 200.8	212480		
70174248032	CER RM 204 SLOP	EPA 200.8	212480		
70174248033	CER RM 212 CR	EPA 200.8	212480		
70174248034	CER RM 214 CR	EPA 200.8	212480		
70174248035	CER RM 216 CR	EPA 200.8	212480		
70174248036	CER STAFF BR	EPA 200.8	212480		
70174248037	CER BF NXT STAFF BR	EPA 200.8	212480		
70174248038	CER BOYS BR NXT APR	EPA 200.8	212480		
70174248039	CER RM 123B SLOP	EPA 200.8	212480		
70174248040	CER RM 134 CR	EPA 200.8	212480		
70174248041	CER RM 121 KS	EPA 200.8	212481		
70174248042	CER RM 101 BR	EPA 200.8	212481		
70174248043	CER RM 109 BR	EPA 200.8	212481		
70174248044	CER RM 109 CR	EPA 200.8	212481		
70174248045	CER RM 11A SLOP	EPA 200.8	212481		
70174248046	CER RM 113 BR	EPA 200.8	212481		
70174248047	CER RM 113 CR	EPA 200.8	212481		
70174248048	CER RM 115 BR	EPA 200.8	212481		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: SCHOOL LEAD TESTING CER 5/13
Pace Project No.: 70174248

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70174248049	CER RM 115 CR	EPA 200.8	212481		
70174248050	CER RM 117 BR	EPA 200.8	212481		
70174248051	CER RM 117 CR	EPA 200.8	212481		
70174248052	CER RM 112 CR #1	EPA 200.8	212481		
70174248053	CER RM 112 CR #2	EPA 200.8	212481		
70174248054	CER RM 112 BR	EPA 200.8	212481		
70174248055	CER RM 110 CR	EPA 200.8	212481		
70174248056	CER RM 110 BR	EPA 200.8	212481		
70174248057	CER RM 108 BR	EPA 200.8	212481		
70174248058	CER RM 108 CR	EPA 200.8	212481		
70174248059	CER RM 106 BR	EPA 200.8	212481		
70174248060	CER RM 106 CR	EPA 200.8	212481		
70174248061	CER RM 104 CR	EPA 200.8	212482		
70174248062	CER RM 104A CR	EPA 200.8	212482		
70174248063	CER RM 104 BR	EPA 200.8	212482		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



70174248

CHAIN-OF-CUSTODY / Analytical Request Do

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must

Section A

Required Client Information:
 Company: Oswego City School District
 Address: 1 Buccaneer Blvd
 Oswego, NY 13126

Required Project Information:
 Report To: David Crisafulli
 Copy To:

Purchase Order #:
 Project Name: School Lead Testing

Requested Due Date:
 Project #:

Section B
 Invoice Information:
 Attention:
 Company Name:
 Address:
 Face Project Manager: betty.harrison@oswego.edu
 Face Profile #:
 Regulatory/Agency:
 State/Location: ny

ITEM #	MATRIX CODE DW: Drinking Water WT: Water WV: Waste Water P: Product SL: Solid OL: Oil WP: Wipe AR: Air OT: Other TS: Tissue	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		# OF CONTAINERS	Preservatives Unpreserved H2SO4 HNO3 HCl NaOH Na2S2O3 Methanol Other	Analyses Test Y/N	Requested/Analytically Filtered (Y/N)	ACCEPTED BY/AFFILIATION				SAMPLE CONDITIONS					
				START DATE	END DATE					DATE	TIME	DATE	TIME	DATE	TIME				
				TIME	TIME					DATE	TIME	DATE	TIME	DATE	TIME				
1				5/13	440					X				5-17	0951				
2					440					X									
3					440					X									
4					440					X									
5					445					X									
6					445					X									
7					446					X									
8					450					X									
9					450					X									
10					450					X									
11					454					X									
12					500					X									

ADDITIONAL COMMENTS: *[Handwritten notes]*

REQUISITIONED BY/AFFILIATION: *[Signature]* DATE: 5-17 TIME: 0951

ACCEPTED BY/AFFILIATION: *[Signature]* DATE: 5-17 TIME: 0951

DATE SIGNED: 5/17/14

DATE SIGNED: 5/17/14

DATE SIGNED: 5/24/14



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page: 2 Of 6

Section A		Section B		Section C	
Required Client Information:		Required Project Information:		Invoice Information:	
Company:	Oswego City School District	Report To:	David Cristofulli	Attention:	
Address:	1 Buccanpeer Blvd	Copy To:		Company Name:	
Oswego, NY 13126		Purchase Order #:		Address:	
Email:	dcristofu@oswego.org	Project Name:	School Lead Testing	Pace Quote:	
Phone:	(315)341-2008	Project #:		Pace Project Manager:	betty.harrison@paceclabs.com
Requested Due Date:				Pace Profile #:	
Regulatory/Agency:		Regulatory/Agency:		State / Location:	

ITEM #	MATRIX	CODE	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	PRESERVATIVES								ANALYSES TEST	Y/N	Requested Analysis/Method	Y/N																	
					START DATE	END DATE			UNPRESERVED	H2SO4	HNO3	HCl	NaOH	Na2SO3	Methanol	Other					Residual Chlorine (Y/N)																
1	CEL Old 1cr Km CR	DW	513	500																																	
2	CER Km 100 Stop	W	501																																		
3	CER Km 158 Stop	W	503																																		
4	CER Km 156 BR	W	505																																		
5	CEL Act Km 152 CR Left	W	505																																		
6	CER Act Km 152 CR Right	W	504																																		
7	CER Km 156 CR	W	506																																		
8	CEL Km 152 CR	W	512																																		
9	CEL Km 174 Stop	W	513																																		
10	CEL Km 176 CR	W	514																																		
11	CEL Gym HW BF	W	156																																		
12	CER CER Km 180 CR	W																																			

RECEIVED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
<i>[Signature]</i>	5/17	0951	<i>[Signature]</i>	5/17	0951	
<i>[Signature]</i>	5/21	10:20	<i>[Signature]</i>	5/21/21	10:20	
<i>[Signature]</i>	5/24/21	1135	<i>[Signature]</i>	5/24/21	1135	

SAMPLER NAME AND SIGNATURE
 PRINT NAME of SAMPLER:
 SIGNATURE of SAMPLER:
 DATE Signed:



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A
Required Client Information:
 Company: Oswego City School District
 Address: 1 Buccaner Blvd
 Oswego, NY 13126
 Email: dorislu@oswego.org
 Phone: (315)341-2006
 Requested Due Date:

Section B
Required Project Information:
 Report To: David Crisafulli
 Copy To:
 Purchase Order #:
 Project Name: School Lead Testing
 Project #:

Section C
Invoice Information:
 Attention:
 Company Name:
 Address:
 Pace Quote:
 Pace Project Manager: bally.harrison@pacelabs.com
 Pace Profile #:
 Regulatory Agency:
 State/Location: ny

ITEM #	MATRIX	CODE	COLLECTED		SAMPLE TYPE (G-GRAB C-COMP)	MATRIX CODE (see valid codes to left)	# OF CONTAINERS		PRESERVATIVES		Y/N	Requested/Analysis Filtered (Y/N)	Residual Chlorine (Y/N)
			START DATE TIME	END DATE TIME			SAMPLE TEMP AT COLLECTION	Unpreserved	H2SO4	HNO3			
1	CEL	km 182 CR	5/13	5/16									
2	CEL	km 184 CR	5/17										
3	CEL	km 183 CR	5/18										
4	CEL	km 181 CR	5/19										
5	CEL	km 217 CR	5/20										
6	CEL	km 215 CR	5/20										
7	CEL	AW BF wtknais	5/21										
8	CEL	km 204 Slap	5/23										
9	CEL	km 212 CR	5/28										
10	CEL	km 214 CR	5/28										
11	CEL	km 216 CR	5/28										
12	CEL												

ADDITIONAL COMMENTS

REIMBURSED BY/AFFILIATION DATE TIME

ACCEPTED BY/AFFILIATION DATE TIME

SAMPLE CONDITIONS

Received on ice (Y/N)

Temp in C

Sealed (Y/N)

Cooler (Y/N)

Samples (Y/N)

Signature of SAMPLER: DATE Signed:

Signature of SAMPLER: DATE Signed:



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A
Required Client Information:
 Company: Oswego City School District
 Address: 1 Buccanear Blvd
 Oswego, NY 13126
 Email: dcrisafu@oswego.org
 Phone: (315)341-2008
 Fax: [Blank]
 Requested Due Date: [Blank]

Section B
Required Project Information:
 Report To: David Cristofulli
 Copy To: [Blank]
 Purchase Order #: CER
 Project Name: School Lead Testing
 Project #: [Blank]

Section C
Invoice Information:
 Attention: [Blank]
 Company Name: [Blank]
 Address: [Blank]
 Pace Quote: [Blank]
 Pace Project Manager: bobby.harrison@pacelabs.com
 Pace Profile #: [Blank]

Regulatory Agency: [Blank]
 State/Location: [Blank]

ITEM #	MATRIX	CODE	COLLECTED		SAMPLE TYPE (G=GRAB C=COMP)	MATRIX CODE (see valid codes to left)	SAMPLE TEMP AT COLLECTION		# OF CONTAINERS	PRESERVATIVES		ANALYSES TEST	Y/N	Request for Analysis Element (Y/N)	Residual Chlorine (Y/N)
			START DATE	END DATE			TIME	TIME		UNPRESERVED	H2SO4				
1	CER	Rm 115 BR	5/13	504a								X			
2	CER	Rm 115 CR	5/13	504a								X			
3		Rm 117 BR	5/13	509a								X			
4		Rm 117 CR	5/13	511a								X			
5		Rm 112 CR #1	5/10									X			
6		Rm 112 CR #2	5/10									X			
7		Rm 112 BR	5/05									X			
8		Rm 110 CR	4/59									X			
9		Rm 110 BR	5/00									X			
10		Rm 108 BR	5/00									X			
11	✓	Rm 108 CR	4/54									X			
12	CER	Rm 106 BR	5/17	448								X			

RECEIVED BY AFFILIATION [Signature] DATE: 5/17 09:57 TIME: 09:57

ACCEPTED BY AFFILIATION [Signature] DATE: 5/17/12 TIME: 10:20

DATE SIGNED: 5/17/12

DATE SIGNED: 5/17/12

TEMP In C

Received on Ice (Y/N)

Custody Sealed (Y/N)

Cooler (Y/N)

Samples Intact (Y/N)

ADDITIONAL COMMENTS:

SAMPLER NAME AND SIGNATURE: [Signature]

PRINT Name of SAMPLER:

SIGNATURE of SAMPLER:

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A
Required Client Information:
 Company: Oswego City School District
 Address: 1 Buccanear Blvd
 Oswego, NY 13126
 Email: dorbafu@oswego.org
 Phone: (315)341-2006
 Fax: _____
 Requested Due Date: _____

Section B
Required Project Information:
 Report To: David Cristofelli
 Copy To: _____
 Purchase Order #: CER
 Project Name: School Lead Testing
 Project #: _____

Section C
Invoice Information:
 Attention: _____
 Company Name: _____
 Address: _____
 Pace Quote: _____
 Pace Project Manager: betty.harrison@pacelabs.com
 Pace Profile #: _____
 Regulatory Agency: _____
 State / Location: NY

ITEM #	MATRIX	CODE	COLLECTED		DATE	TIME	DATE	TIME	SAMPLER NAME AND SIGNATURE	DATE SIGNED	TEMP IN C	Received on	Custody Scaled (Y/N)	Saled Cooler (Y/N)	Samples Inlet (Y/N)	
			START	END												
1	CER	Rm 106 CR	5/13	4:48 am	5/17	09:51	5/17	09:51	[Signature]	5/17	09:51					
2		Rm 104 CR	5/13	4:48	5/17	10:21	5/17	10:21	[Signature]	5/17	10:21					
3		Rm 104A CR	5/13	4:48	5/17	11:35	5/17	11:35	[Signature]	5/17	11:35					
4		Rm 104 BR	5/13	4:49	5/17	11:35	5/17	11:35	[Signature]	5/17	11:35					
5																
6																
7																
8																
9																
10																
11																
12																

ADDITIONAL COMMENTS:

REQUISITION BY AFFILIATION:

ACCEPTED BY AFFILIATION:

DATE: 5-17 09:51

TIME: 10:21

DATE: 5/17 10:21

TIME: 11:35

DATE: 5/17 11:35

TIME: 11:35

SAMPLER NAME AND SIGNATURE:

PRINT Name of SAMPLER:

SIGNATURE of SAMPLER:

DATE SIGNED:



Sample Condition Upon Receipt

WO#: 70174248

Client Name: OSWEGO CSD

Project Due Date: 06/02/21

PM: EMH CLIENT: OCCSD

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #:
Primary Seal on Cooler/Box Present: Yes No Seals intact: Yes No

Temperature Blank Present: Yes No
Type of Ice: Wet Blue None

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other
Thermometer Used: TH091 Correction Factor: +0.0
Cooler Temperature(°C): 20.9 Cooler Temperature Corrected(°C): 20.9

Samples on ice, cooling process has begun
Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C
USDA Regulated Soil (N/A, water sample) Date and Initials of person examining contents: VTS 5.25.21

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No
Did samples originate from a foreign source including Hawaii and Puerto Rico? Yes X No
If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

Table with 17 rows and 3 columns. Columns: Question, Yes/No/N/A, and Comments. Includes items like Chain of Custody Present, Sampler Name & Signature on COC, Sufficient Volume, etc.

Client Notification/ Resolution: Field Data Required? Y / N
Person Contacted: Date/Time:
Comments/ Resolution:

