

June 10, 2021

David Crisafulli
Oswego City School District
1 Buccaneer Blvd
Oswego, NY 13126

RE: Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

Dear David Crisafulli:


Enclosed are the analytical results for sample(s) received by the laboratory on May 24, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Elizabeth Harrison
betty.harrison@pacelabs.com
(631)694-3040
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

Pace Analytical Services Long Island

Virginia Certification # 460302
Delaware Certification # NY10478
Delaware Certification # NY10478
575 Broad Hollow Rd, Melville, NY 11747
New York Certification #: 10478 Primary Accrediting Body
New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350
Connecticut Certification #: PH-0435
Maryland Certification #: 208
Rhode Island Certification #: LAO00340
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

Sample: OMS RM 126 CR		Lab ID: 70174392001	Collected: 05/12/21 04:56	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		06/09/21 17:13	7439-92-1	

Sample: OMS RM 131 CR		Lab ID: 70174392002	Collected: 05/12/21 04:58	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	70.8	ug/L	1.0	1		06/09/21 17:14	7439-92-1	

Sample: OMS RM 130A CR		Lab ID: 70174392003	Collected: 05/12/21 04:59	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	11.6	ug/L	1.0	1		06/09/21 17:15	7439-92-1	

Sample: OMS RM 133 KS #1		Lab ID: 70174392004	Collected: 05/12/21 05:03	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.6	ug/L	1.0	1		06/09/21 17:16	7439-92-1	

Sample: OMS RM 133 KS #2		Lab ID: 70174392005	Collected: 05/12/21 05:04	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.1	ug/L	1.0	1		06/09/21 17:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING OMS 5/12

Pace Project No.: 70174392

Sample: OMS RM 133 KS #3	Lab ID: 70174392006	Collected: 05/12/21 05:04	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.4	ug/L	1.0	1		06/09/21 17:19	7439-92-1	

Sample: OMS RM 133 KS #4	Lab ID: 70174392007	Collected: 05/12/21 05:05	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.0	ug/L	1.0	1		06/09/21 17:20	7439-92-1	

Sample: OMS RM 140 CR	Lab ID: 70174392008	Collected: 05/12/21 05:07	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	11.9	ug/L	1.0	1		06/09/21 17:21	7439-92-1	

Sample: OMS RM 148 KS	Lab ID: 70174392009	Collected: 05/12/21 05:09	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.6	ug/L	1.0	1		06/09/21 17:24	7439-92-1	

Sample: OMS RM 154 TECH CR	Lab ID: 70174392010	Collected: 05/12/21 05:11	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	201	ug/L	1.0	1		06/09/21 17:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

Sample: OMS RM 154 POD CR	Lab ID: 70174392011	Collected: 05/12/21 05:11	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.1	ug/L	1.0	1		06/09/21 17:30	7439-92-1	

Sample: OMS RM 162 TECH CR	Lab ID: 70174392012	Collected: 05/12/21 05:13	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	49.2	ug/L	1.0	1		06/09/21 17:31	7439-92-1	

Sample: OMS RM 162 POD CR	Lab ID: 70174392013	Collected: 05/12/21 05:13	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	35.7	ug/L	1.0	1		06/09/21 17:32	7439-92-1	

Sample: OMS RM 163 SLOP	Lab ID: 70174392014	Collected: 05/12/21 05:16	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.2	ug/L	1.0	1		06/09/21 17:32	7439-92-1	

Sample: OMS RM 116A SLOP	Lab ID: 70174392015	Collected: 05/12/21 05:20	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		06/09/21 17:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: OMS CAFE KS	Lab ID: 70174392016	Collected: 05/12/21 05:21	Received: 05/24/21 11:35	Matrix: Drinking Water				
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.0	ug/L	1.0	1		06/09/21 17:34	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: OMS SERU LINE KS	Lab ID: 70174392017	Collected: 05/12/21 05:23	Received: 05/24/21 11:35	Matrix: Drinking Water				
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.1	ug/L	1.0	1		06/09/21 17:35	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: OMS KIT HW #1	Lab ID: 70174392018	Collected: 05/12/21 05:28	Received: 05/24/21 11:35	Matrix: Drinking Water				
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/09/21 17:36	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: OMS KS #2	Lab ID: 70174392019	Collected: 05/12/21 05:29	Received: 05/24/21 11:35	Matrix: Drinking Water				
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.2	ug/L	1.0	1		06/09/21 17:37	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: OMS KS #3 LEFT	Lab ID: 70174392020	Collected: 05/12/21 05:29	Received: 05/24/21 11:35	Matrix: Drinking Water				
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.4	ug/L	1.0	1		06/09/21 17:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

Sample: OMS KS SPRAYER #5		Lab ID: 70174392021	Collected: 05/12/21 05:30	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/09/21 17:43	7439-92-1	

Sample: OMS KS #4 RIGHT		Lab ID: 70174392022	Collected: 05/12/21 05:29	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/09/21 17:44	7439-92-1	

Sample: OMS KS #6		Lab ID: 70174392023	Collected: 05/12/21 05:36	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.4	ug/L	1.0	1		06/09/21 17:45	7439-92-1	

Sample: OMS KS #7		Lab ID: 70174392024	Collected: 05/12/21 05:28	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.9	ug/L	1.0	1		06/09/21 17:46	7439-92-1	

Sample: OMS KS #8		Lab ID: 70174392025	Collected: 05/12/21 05:38	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		06/09/21 17:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

Sample: OMS KS LEFT #9	Lab ID: 70174392026	Collected: 05/12/21 05:39	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		06/09/21 17:48	7439-92-1	

Sample: OMS KS RIGHT #10	Lab ID: 70174392027	Collected: 05/12/21 05:40	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	5.7	ug/L	1.0	1		06/09/21 17:49	7439-92-1	

Sample: OMS KETTLE LEFT #11	Lab ID: 70174392028	Collected: 05/12/21 05:42	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	6.7	ug/L	1.0	1		06/09/21 17:50	7439-92-1	

Sample: OMS KETTLE RIGHT #12	Lab ID: 70174392029	Collected: 05/12/21 05:42	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	5.9	ug/L	1.0	1		06/09/21 17:54	7439-92-1	

Sample: OMS BR LEFT	Lab ID: 70174392030	Collected: 05/12/21 05:45	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	8.6	ug/L	1.0	1		06/09/21 17:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

Sample: OMS ICE MACH. KIT	Lab ID: 70174392031	Collected: 05/12/21 05:48	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/09/21 17:58	7439-92-1	

Sample: OMS GYM ICE MACH	Lab ID: 70174392032	Collected: 05/12/21 05:55	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/09/21 17:59	7439-92-1	

Sample: OMS COACH BR	Lab ID: 70174392033	Collected: 05/12/21 05:58	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.1	ug/L	1.0	1		06/09/21 18:00	7439-92-1	

Sample: OMS BR TO POOL	Lab ID: 70174392034	Collected: 05/12/21 05:58	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	34.0	ug/L	1.0	1		06/09/21 18:01	7439-92-1	

Sample: OMS RM 115 SLOP	Lab ID: 70174392035	Collected: 05/12/21 06:00	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	13.2	ug/L	1.0	1		06/09/21 18:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

Sample: OMS BOTTLE FILL ELEV	Lab ID: 70174392036	Collected: 05/12/21 04:54	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/09/21 18:05	7439-92-1	

Sample: OMS RM 008 MENS T-SINK	Lab ID: 70174392037	Collected: 05/12/21 04:55	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.2	ug/L	1.0	1		06/09/21 18:06	7439-92-1	

Sample: OMS CUST SINK	Lab ID: 70174392038	Collected: 05/12/21 04:56	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	5.4	ug/L	1.0	1		06/09/21 18:07	7439-92-1	

Sample: OMS POOL RM 011	Lab ID: 70174392039	Collected: 05/12/21 04:59	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.6	ug/L	1.0	1		06/09/21 18:08	7439-92-1	M1

Sample: OMS RM 017 LH SINK	Lab ID: 70174392040	Collected: 05/12/21 04:59	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	19.0	ug/L	1.0	1		06/09/21 18:11	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

Sample: OMS RM 017 MIDDLE SINK Lab ID: 70174392041 Collected: 05/12/21 04:59 Received: 05/24/21 11:35 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	10.7	ug/L	1.0	1		06/09/21 18:12	7439-92-1	

Sample: OMS RM 017 RH SINK Lab ID: 70174392042 Collected: 05/12/21 04:59 Received: 05/24/21 11:35 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	25.8	ug/L	1.0	1		06/09/21 18:13	7439-92-1	

Sample: OMS RM 018 LH SINK Lab ID: 70174392043 Collected: 05/12/21 05:04 Received: 05/24/21 11:35 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	38.7	ug/L	1.0	1		06/09/21 18:15	7439-92-1	

Sample: OMS RM 018 MIDDLE SINK Lab ID: 70174392044 Collected: 05/12/21 05:04 Received: 05/24/21 11:35 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	9.1	ug/L	1.0	1		06/09/21 18:16	7439-92-1	

Sample: OMS RM 018 RH SINK Lab ID: 70174392045 Collected: 05/12/21 05:04 Received: 05/24/21 11:35 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.1	ug/L	1.0	1		06/09/21 18:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

Sample: OMS RM 019 LH SINK	Lab ID: 70174392046	Collected: 05/12/21 05:07	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	13.5	ug/L	1.0	1		06/09/21 18:18	7439-92-1	

Sample: OMS RM 019 MIDDLE	Lab ID: 70174392047	Collected: 05/12/21 05:07	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	20.9	ug/L	1.0	1		06/09/21 18:19	7439-92-1	

Sample: OMS RM 019 RH	Lab ID: 70174392048	Collected: 05/12/21 05:07	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	14.5	ug/L	1.0	1		06/09/21 18:20	7439-92-1	

Sample: OMS RM 021	Lab ID: 70174392049	Collected: 05/12/21 05:11	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	34.6	ug/L	1.0	1		06/09/21 18:23	7439-92-1	

Sample: OMS RM 035	Lab ID: 70174392050	Collected: 05/12/21 05:13	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	53.8	ug/L	1.0	1		06/09/21 18:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

Sample: OMS RM 043	Lab ID: 70174392051	Collected: 05/12/21 05:17	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	37.7	ug/L	1.0	1		06/09/21 18:29	7439-92-1	

Sample: OMS CUST MOP RM 046	Lab ID: 70174392052	Collected: 05/12/21 05:18	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.1	ug/L	1.0	1		06/09/21 18:30	7439-92-1	

Sample: OMS LIB MEDIA	Lab ID: 70174392053	Collected: 05/12/21 05:26	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	8.5	ug/L	1.0	1		06/09/21 18:31	7439-92-1	

Sample: OMS BOTTLE FILL MAIN	Lab ID: 70174392054	Collected: 05/12/21 05:28	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/09/21 18:32	7439-92-1	

Sample: OMS 102H NURSE SINK	Lab ID: 70174392055	Collected: 05/12/21 05:30	Received: 05/24/21 11:35	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.9	ug/L	1.0	1		06/09/21 18:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: OMS 102F NURSE SINK	Lab ID: 70174392056	Collected: 05/12/21 05:30	Received: 05/24/21 11:35	Matrix: Drinking Water				
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	8.9	ug/L	1.0	1		06/09/21 18:34	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: OMS 102 M SINK	Lab ID: 70174392057	Collected: 05/12/21 05:32	Received: 05/24/21 11:35	Matrix: Drinking Water				
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.2	ug/L	1.0	1		06/09/21 18:35	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: OMS 108 CUST MOP	Lab ID: 70174392058	Collected: 05/12/21 05:35	Received: 05/24/21 11:35	Matrix: Drinking Water				
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.2	ug/L	1.0	1		06/09/21 18:36	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: OMS RM 107	Lab ID: 70174392059	Collected: 05/12/21 05:37	Received: 05/24/21 11:35	Matrix: Drinking Water				
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.3	ug/L	1.0	1		06/09/21 18:38	7439-92-1	M1

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: OMS UPPER GYM BOXS SIDE MOP	Lab ID: 70174392060	Collected: 05/12/21 05:44	Received: 05/24/21 11:35	Matrix: Drinking Water				
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	17.0	ug/L	1.0	1		06/09/21 18:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SCHOOL LEAD TESTING OMS 5/12

Pace Project No.: 70174392

Sample: OMS MOS WOMENS RH		Lab ID: 70174392061	Collected: 05/12/21 05:50	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	47.5	ug/L	1.0	1		06/09/21 18:42	7439-92-1	

Sample: OMS MOS WOMEN LH		Lab ID: 70174392062	Collected: 05/12/21 05:58	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.6	ug/L	1.0	1		06/09/21 18:43	7439-92-1	

Sample: OMS MOS MENS		Lab ID: 70174392063	Collected: 05/12/21 05:48	Received: 05/24/21 11:35	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.2	ug/L	1.0	1		06/09/21 18:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

QC Batch: 212661
QC Batch Method: EPA 200.8
Analysis Method: EPA 200.8
Analysis Description: 200.8 MET No Prep Drinking Water
Laboratory: Pace Analytical Services - Melville
Associated Lab Samples: 70174392001, 70174392002, 70174392003, 70174392004, 70174392005, 70174392006, 70174392007, 70174392008

METHOD BLANK: 1066647
Matrix: Water
Associated Lab Samples: 70174392001, 70174392002, 70174392003, 70174392004, 70174392005, 70174392006, 70174392007, 70174392008

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/09/21 16:52	

LABORATORY CONTROL SAMPLE: 1066648

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.7	103	85-115	

MATRIX SPIKE SAMPLE: 1066650

Parameter	Units	70174371027 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.6	50	64.9	126	70-130	

MATRIX SPIKE SAMPLE: 1066652

Parameter	Units	70174371037 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	58.7	117	70-130	

SAMPLE DUPLICATE: 1066649

Parameter	Units	70174371027 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.6	1.6	3	

SAMPLE DUPLICATE: 1066651

Parameter	Units	70174371037 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

QC Batch:	212662	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70174392009, 70174392010, 70174392011, 70174392012, 70174392013, 70174392014, 70174392015, 70174392016, 70174392017, 70174392018, 70174392019, 70174392020, 70174392021, 70174392022, 70174392023, 70174392024, 70174392025, 70174392026, 70174392027, 70174392028		

METHOD BLANK:	1066653	Matrix:	Water
Associated Lab Samples:	70174392009, 70174392010, 70174392011, 70174392012, 70174392013, 70174392014, 70174392015, 70174392016, 70174392017, 70174392018, 70174392019, 70174392020, 70174392021, 70174392022, 70174392023, 70174392024, 70174392025, 70174392026, 70174392027, 70174392028		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/09/21 17:22	

LABORATORY CONTROL SAMPLE:	1066654					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.6	101	85-115	

MATRIX SPIKE SAMPLE:	1066656						
Parameter	Units	70174392009 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.6	50	61.4	120	70-130	

MATRIX SPIKE SAMPLE:	1066658						
Parameter	Units	70174392019 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	4.2	50	59.7	111	70-130	

SAMPLE DUPLICATE:	1066655					
Parameter	Units	70174392009 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	1.6	1.5	3		

SAMPLE DUPLICATE:	1066657					
Parameter	Units	70174392019 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	4.2	4.2	1		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

QC Batch:	212665	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70174392029, 70174392030, 70174392031, 70174392032, 70174392033, 70174392034, 70174392035, 70174392036, 70174392037, 70174392038, 70174392039, 70174392040, 70174392041, 70174392042, 70174392043, 70174392044, 70174392045, 70174392046, 70174392047, 70174392048		

METHOD BLANK:	1066660	Matrix:	Water
Associated Lab Samples:	70174392029, 70174392030, 70174392031, 70174392032, 70174392033, 70174392034, 70174392035, 70174392036, 70174392037, 70174392038, 70174392039, 70174392040, 70174392041, 70174392042, 70174392043, 70174392044, 70174392045, 70174392046, 70174392047, 70174392048		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/09/21 17:52	

LABORATORY CONTROL SAMPLE:	1066661					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.0	104	85-115	

MATRIX SPIKE SAMPLE:	1066663						
Parameter	Units	70174392029 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	5.9	50	69.5	127	70-130	

MATRIX SPIKE SAMPLE:	1066665						
Parameter	Units	70174392039 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.6	50	70.7	136	70-130	M1

SAMPLE DUPLICATE:	1066662					
Parameter	Units	70174392029 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	5.9	5.8	2		

SAMPLE DUPLICATE:	1066664					
Parameter	Units	70174392039 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	2.6	2.6	1		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

QC Batch: 212666 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
Laboratory: Pace Analytical Services - Melville
Associated Lab Samples: 70174392049, 70174392050, 70174392051, 70174392052, 70174392053, 70174392054, 70174392055, 70174392056, 70174392057, 70174392058, 70174392059, 70174392060, 70174392061, 70174392062, 70174392063

METHOD BLANK: 1066667 Matrix: Water
Associated Lab Samples: 70174392049, 70174392050, 70174392051, 70174392052, 70174392053, 70174392054, 70174392055, 70174392056, 70174392057, 70174392058, 70174392059, 70174392060, 70174392061, 70174392062, 70174392063

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/09/21 18:21	

LABORATORY CONTROL SAMPLE: 1066668

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.7	101	85-115	

MATRIX SPIKE SAMPLE: 1066670

Parameter	Units	70174392049 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	34.6	50	96.9	125	70-130	

MATRIX SPIKE SAMPLE: 1066672

Parameter	Units	70174392059 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.3	50	70.1	134	70-130	M1

SAMPLE DUPLICATE: 1066669

Parameter	Units	70174392049 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	34.6	34.4	1	

SAMPLE DUPLICATE: 1066671

Parameter	Units	70174392059 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.3	3.2	3	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

ANALYTE QUALIFIERS

M1 Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70174392001	OMS RM 126 CR	EPA 200.8	212661		
70174392002	OMS RM 131 CR	EPA 200.8	212661		
70174392003	OMS RM 130A CR	EPA 200.8	212661		
70174392004	OMS RM 133 KS #1	EPA 200.8	212661		
70174392005	OMS RM 133 KS #2	EPA 200.8	212661		
70174392006	OMS RM 133 KS #3	EPA 200.8	212661		
70174392007	OMS RM 133 KS #4	EPA 200.8	212661		
70174392008	OMS RM 140 CR	EPA 200.8	212661		
70174392009	OMS RM 148 KS	EPA 200.8	212662		
70174392010	OMS RM 154 TECH CR	EPA 200.8	212662		
70174392011	OMS RM 154 POD CR	EPA 200.8	212662		
70174392012	OMS RM 162 TECH CR	EPA 200.8	212662		
70174392013	OMS RM 162 POD CR	EPA 200.8	212662		
70174392014	OMS RM 163 SLOP	EPA 200.8	212662		
70174392015	OMS RM 116A SLOP	EPA 200.8	212662		
70174392016	OMS CAFE KS	EPA 200.8	212662		
70174392017	OMS SERU LINE KS	EPA 200.8	212662		
70174392018	OMS KIT HW #1	EPA 200.8	212662		
70174392019	OMS KS #2	EPA 200.8	212662		
70174392020	OMS KS #3 LEFT	EPA 200.8	212662		
70174392021	OMS KS SPRAYER #5	EPA 200.8	212662		
70174392022	OMS KS #4 RIGHT	EPA 200.8	212662		
70174392023	OMS KS #6	EPA 200.8	212662		
70174392024	OMS KS #7	EPA 200.8	212662		
70174392025	OMS KS #8	EPA 200.8	212662		
70174392026	OMS KS LEFT #9	EPA 200.8	212662		
70174392027	OMS KS RIGHT #10	EPA 200.8	212662		
70174392028	OMS KETTLE LEFT #11	EPA 200.8	212662		
70174392029	OMS KETTLE RIGHT #12	EPA 200.8	212665		
70174392030	OMS BR LEFT	EPA 200.8	212665		
70174392031	OMS ICE MACH. KIT	EPA 200.8	212665		
70174392032	OMS GYM ICE MACH	EPA 200.8	212665		
70174392033	OMS COACH BR	EPA 200.8	212665		
70174392034	OMS BR TO POOL	EPA 200.8	212665		
70174392035	OMS RM 115 SLOP	EPA 200.8	212665		
70174392036	OMS BOTTLE FILL ELEV	EPA 200.8	212665		
70174392037	OMS RM 008 MENS T-SINK	EPA 200.8	212665		
70174392038	OMS CUST SINK	EPA 200.8	212665		
70174392039	OMS POOL RM 011	EPA 200.8	212665		
70174392040	OMS RM 017 LH SINK	EPA 200.8	212665		
70174392041	OMS RM 017 MIDDLE SINK	EPA 200.8	212665		
70174392042	OMS RM 017 RH SINK	EPA 200.8	212665		
70174392043	OMS RM 018 LH SINK	EPA 200.8	212665		
70174392044	OMS RM 018 MIDDLE SINK	EPA 200.8	212665		
70174392045	OMS RM 018 RH SINK	EPA 200.8	212665		
70174392046	OMS RM 019 LH SINK	EPA 200.8	212665		
70174392047	OMS RM 019 MIDDLE	EPA 200.8	212665		
70174392048	OMS RM 019 RH	EPA 200.8	212665		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: SCHOOL LEAD TESTING OMS 5/12
Pace Project No.: 70174392

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70174392049	OMS RM 021	EPA 200.8	212666		
70174392050	OMS RM 035	EPA 200.8	212666		
70174392051	OMS RM 043	EPA 200.8	212666		
70174392052	OMS CUST MOP RM 046	EPA 200.8	212666		
70174392053	OMS LIB MEDIA	EPA 200.8	212666		
70174392054	OMS BOTTLE FILL MAIN	EPA 200.8	212666		
70174392055	OMS 102H NURSE SINK	EPA 200.8	212666		
70174392056	OMS 102F NURSE SINK	EPA 200.8	212666		
70174392057	OMS 102 M SINK	EPA 200.8	212666		
70174392058	OMS 108 CUST MOP	EPA 200.8	212666		
70174392059	OMS RM 107	EPA 200.8	212666		
70174392060	OMS UPPER GYM BOXS SIDE MOP	EPA 200.8	212666		
70174392061	OMS MOS WOMENS RH	EPA 200.8	212666		
70174392062	OMS MOS WOMEN LH	EPA 200.8	212666		
70174392063	OMS MOS MENS	EPA 200.8	212666		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A		Section B		Section C	
Required Client Information:		Required Project Information:		Invoice Information:	
Company:	Oswego City School District	Report To:	David Crise/Juli	Attention:	
Address:	1 Buccancer Blvd	Copy To:		Company Name:	
	Oswego, NY 13128	Purchase Order #:		Address:	
Email:	dcriseti@oswego.org	Project Name:	School Lead Testing	Pace Quote:	
Phone:	(315)341-2008	Project #:	AMS	Pace Project Manager:	bolly.harrison@pacelabs.com,
Requested Due Date:				Pace Profile #:	
Regulatory Agency		Regulatory Agency		State / Location	
				ny	

Page: 2 of 6

ITEM #	MATRIX	CODE	COLLECTED		SAMPLE TYPE (G-RAB O-COMP)	MATRIX CODE (see valid codes to left)	SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	PRESERVATIVES							ANALYSES TEST Y/N	Z00.8	Residual Chlorine (Y/N)
			START DATE	END DATE					H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol	Other			
1	AMS Km 62 Pod OK	DW	5/12	5/13											X			
2	AMS Km 63 Slop	W	5/12	5/16											X			
3	AMS Km 116A Slop	W	5/20												X			
4	AMS Cape KS	W	5/21												X			
5	AMS Sealine KS	W	5/28												X			
6	AMS Kit HW-H	W	5/29												X			
7	AMS KS #2	W	5/29												X			
8	AMS KS #3 Left	W	5/29												X			
9	AMS KS Sampler #5	W	5/29												X			
10	AMS KS #4 Right	W	5/29												X			
11	AMS KS #6	W	5/26												X			
12	AMS KS #7	W	5/28												X			

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
	<i>[Signature]</i>	5.17	0951	<i>[Signature]</i>	5/17	0951	
	<i>[Signature]</i>	5.21	10:40	<i>[Signature]</i>	5/21/21	10:40	
	<i>[Signature]</i>	5/24/21	1135	<i>[Signature]</i>	5/24/21	1135	

TEMP IN C

Received on

Ice (Y/N)

Custody (Y/N)

Sealed Cooler (Y/N)

Samples (Y/N)

Inact (Y/N)

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER:

SIGNATURE of SAMPLER:

DATE Signed:



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A		Section B		Section C	
Required Client Information:		Required Project Information:		Invoice Information:	
Company:	Oswego City School District	Report To:	David Crisafulli	Attention:	
Address:	1 Buccanear Blvd	Copy To:		Company Name:	
Oswego, NY 13128		Purchase Order #:		Address:	
Email:	dcrisafu@oswego.org	Project Name:	School Lead Testing	Face Quole:	
Phone:	(315)241-2806	School Lead Testing		Face Project Manager:	betty.harrison@pacelabs.com
Requested Due Date:		Project #:		Face Profile #:	
Regulatory Agency:		State / Location:		ny	

ITEM #	MATRIX	CODE	COLLECTED		SAMPLE TYPE (G-RAB C-COMP)	MATRIX CODE (see valid codes to left)	# OF CONTAINERS	Preservatives						Analyses Test (Y/N)	Requestor/Analyst/Filtered (Y/N)
			START	END				H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol		
DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME
1	Oms KS #8	DW	5/10	538											
2	Oms KS left #9	WT		539											
3	Oms KS Right #10	WW		540											
4	Oms Kettle left #11	P		541											
5	Oms Kettle Right #12	Product		542											
6	Oms BR left	Solids		545											
7	Oms Ice Mach. Kit	Oil		548											
8	Oms germ la mach	Wipe		555											
9	Oms Catch BR	Air		558											
10	Oms BR to pool	Other		558											
11	Oms Run 15 Slap	TS		600											
12															

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
	<i>[Signature]</i>	5-17	10:51	<i>[Signature]</i>	5-17	09:51	
	<i>[Signature]</i>	5-21	10:30	<i>[Signature]</i>	5-21	10:30	
	<i>[Signature]</i>	5-24	11:35	<i>[Signature]</i>	5-24	11:35	

TEMP H/C

Received on _____

Sealed _____

Custody _____

Cooler _____

Samples _____

(Y/N)

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER:

SIGNATURE of SAMPLER:

DATE Signed:

