

October 20, 2016

David Crisafulli
Oswego CSD
225 West Utica St
Oswego, NY 12126

RE: Project: O CSD - Charles E. Riley Elem.
Pace Project No.: 10365790

Dear David Crisafulli:

Enclosed are the analytical results for sample(s) received by the laboratory on October 11, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

Samples, in the electronic data deliverable (EDD) that accompanied this report, were flagged yellow if they exceeded the NYSDOH 15 ppb action level.

The space designated for the sampler on the chain of custody (COC) indicates if these samples were collected by Pace Analytical or were collected by the school district and just relinquished to Pace Analytical.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Amanda Albrecht
amanda.albrecht@pacelabs.com
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: O CSD - Charles E. Riley Elem.

Pace Project No.: 10365790

Minnesota Certification IDs

1700 Elm Street SE Suite 200, Minneapolis, MN 55414

Alaska Certification UST-107

525 N 8th Street, Salina, KS 67401

A2LA Certification #: 2926.01

Alaska Certification #: UST-078

Alaska Certification #MN00064

Alabama Certification #40770

Arizona Certification #: AZ-0014

Arkansas Certification #: 88-0680

California Certification #: 01155CA

Colorado Certification #Pace

Connecticut Certification #: PH-0256

EPA Region 8 Certification #: 8TMS-L

Florida/NELAP Certification #: E87605

Guam Certification #:14-008r

Georgia Certification #: 959

Georgia EPD #: Pace

Idaho Certification #: MN00064

Hawaii Certification #MN00064

Illinois Certification #: 200011

Indiana Certification#C-MN-01

Iowa Certification #: 368

Kansas Certification #: E-10167

Kentucky Dept of Envi. Protection - DW #90062

Kentucky Dept of Envi. Protection - WW #:90062

Louisiana DEQ Certification #: 3086

Louisiana DHH #: LA140001

Maine Certification #: 2013011

Maryland Certification #: 322

Michigan DEPH Certification #: 9909

Minnesota Certification #: 027-053-137

Mississippi Certification #: Pace

Montana Certification #: MT0092

Nevada Certification #: MN_00064

Nebraska Certification #: Pace

New Jersey Certification #: MN-002

New York Certification #: 11647

North Carolina Certification #: 530

North Carolina State Public Health #: 27700

North Dakota Certification #: R-036

Ohio EPA #: 4150

Ohio VAP Certification #: CL101

Oklahoma Certification #: 9507

Oregon Certification #: MN200001

Oregon Certification #: MN300001

Pennsylvania Certification #: 68-00563

Puerto Rico Certification

Saipan (CNMI) #:MP0003

South Carolina #:74003001

Texas Certification #: T104704192

Tennessee Certification #: 02818

Utah Certification #: MN000642013-4

Virginia DGS Certification #: 251

Virginia/VELAP Certification #: Pace

Washington Certification #: C486

West Virginia Certification #: 382

West Virginia DHHR #:9952C

Wisconsin Certification #: 999407970

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: O CSD - Charles E. Riley Elem.

Pace Project No.: 10365790

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10365790001	ROOM 123D-KITCHEN HAND SINK	Water	09/30/16 00:24	10/11/16 10:00
10365790002	ROOM 134A-SINK	Water	09/30/16 00:26	10/11/16 10:00
10365790003	ROOM 124-SINK	Water	09/30/16 00:28	10/11/16 10:00
10365790004	ROOM 127-WEST SIDE SINK	Water	09/30/16 00:29	10/11/16 10:00
10365790005	ROOM 127-EAST SIDE SINK	Water	09/30/16 00:29	10/11/16 10:00
10365790006	ROOM 123B-SLOP SINK	Water	09/30/16 00:30	10/11/16 10:00
10365790007	STAFF BATH SINK ACROSS 123B	Water	09/30/16 00:31	10/11/16 10:00
10365790008	SINK IN OFFICE BATHROOM	Water	09/30/16 00:34	10/11/16 10:00
10365790009	ROOM 111A - SLOP SINK	Water	09/30/16 00:34	10/11/16 10:00
10365790010	ROOM 113 - SINK	Water	09/30/16 00:35	10/11/16 10:00
10365790011	ROOM 113 - BATHROOM SINK	Water	09/30/16 00:35	10/11/16 10:00
10365790012	ROOM 115 - SINK	Water	09/30/16 00:37	10/11/16 10:00
10365790013	ROOM 115 - BATHROOM SINK	Water	09/30/16 00:38	10/11/16 10:00
10365790014	ROOM 117 - SINK	Water	09/30/16 00:39	10/11/16 10:00
10365790015	ROOM 117 - BATHROOM SINK	Water	09/30/16 00:40	10/11/16 10:00
10365790016	ROOM 112 - SINK	Water	09/30/16 00:41	10/11/16 10:00
10365790017	ROOM 112 - BATHROOM SINK	Water	09/30/16 00:42	10/11/16 10:00
10365790018	ROOM 112 - FOUNTAIN	Water	09/30/16 00:41	10/11/16 10:00
10365790019	ROOM 110 - SINK	Water	09/30/16 00:44	10/11/16 10:00
10365790020	ROOM 110 - BATHROOM SINK	Water	09/30/16 00:45	10/11/16 10:00
10365790021	ROOM 106 - BATHROOM SINK	Water	09/30/16 00:46	10/11/16 10:00
10365790022	ROOM 104A - SINK	Water	09/30/16 00:47	10/11/16 10:00
10365790023	ROOM 104A - BATHROOM SINK	Water	09/30/16 00:48	10/11/16 10:00
10365790024	BOYS BATHRM BOTTOMofRAMP SINK	Water	09/30/16 00:51	10/11/16 10:00
10365790025	GIRLS BATHRM BOTTOMofRAMP SINK	Water	09/30/16 00:50	10/11/16 10:00
10365790026	ROOM 152 SOUTH SINK	Water	09/30/16 00:52	10/11/16 10:00
10365790027	ROOM 152 - NORTH SINK	Water	09/30/16 00:54	10/11/16 10:00
10365790028	ROOM 156 - SINK	Water	09/30/16 00:56	10/11/16 10:00
10365790029	ROOM 156 - BATHROOM SINK	Water	09/30/16 00:56	10/11/16 10:00
10365790030	ROOM 158 - SINK	Water	09/30/16 00:58	10/11/16 10:00
10365790031	ROOM 162 - SLOP SINK	Water	09/30/16 01:00	10/11/16 10:00
10365790032	ROOM 160 - BOYS WEST SINK	Water	09/30/16 01:01	10/11/16 10:00
10365790033	ROOM 160 - BOYS EAST SINK	Water	09/30/16 01:01	10/11/16 10:00
10365790034	ROOM 160 - GIRLS EAST SINK	Water	09/30/16 00:59	10/11/16 10:00
10365790035	ROOM 160 - GIRLS WEST SINK	Water	09/30/16 01:00	10/11/16 10:00
10365790036	ROOM 166 - SINK	Water	09/30/16 01:03	10/11/16 10:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: O CSD - Charles E. Riley Elem.

Pace Project No.: 10365790

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10365790037	ROOM 168 - SINK	Water	09/30/16 01:04	10/11/16 10:00
10365790038	ROOM 169 - SINK	Water	09/30/16 01:05	10/11/16 10:00
10365790039	ROOM 167 - SINK	Water	09/30/16 01:06	10/11/16 10:00
10365790040	ROOM 165 - SINK	Water	09/30/16 01:06	10/11/16 10:00
10365790041	ROOM 157 - SINK	Water	09/30/16 01:07	10/11/16 10:00
10365790042	ROOM 155 - SINK	Water	09/30/16 01:07	10/11/16 10:00
10365790043	RM 202-GIRLS BATHRM-WEST SINK	Water	09/30/16 01:17	10/11/16 10:00
10365790044	RM 202-GIRLS BATHRM-EAST SINK	Water	09/30/16 01:17	10/11/16 10:00
10365790045	ROOM 204-SLOP SINK	Water	09/30/16 01:16	10/11/16 10:00
10365790046	ROOM 212 - SINK	Water	09/30/16 00:14	10/11/16 10:00
10365790047	ROOM 214 - SINK	Water	09/30/16 01:13	10/11/16 10:00
10365790048	ROOM 216 - SINK	Water	09/30/16 01:09	10/11/16 10:00
10365790049	ROOM 217 - SINK	Water	09/30/16 01:10	10/11/16 10:00
10365790050	ROOM 215 - SINK	Water	09/30/16 01:12	10/11/16 10:00
10365790051	ROOM 183 - SINK	Water	09/30/16 01:29	10/11/16 10:00
10365790052	ROOM 184 - SINK	Water	09/30/16 01:27	10/11/16 10:00
10365790053	ROOM 182 - SINK	Water	09/30/16 01:25	10/11/16 10:00
10365790054	ROOM 180 - SINK	Water	09/30/16 01:23	10/11/16 10:00
10365790055	ROOM 176 - SINK	Water	09/30/16 01:23	10/11/16 10:00
10365790056	SLOP SINK OUTSIDE ROOM 174	Water	09/30/16 01:21	10/11/16 10:00
10365790057	ROOM 106 - SINK	Water	09/30/16 00:46	10/11/16 10:00
10365790058	ROOM 206-BOYS BATHRM WEST SINK	Water	09/30/16 01:19	10/11/16 10:00
10365790059	ROOM 206-BOYS BATHRM EAST SINK	Water	09/30/16 01:19	10/11/16 10:00
10365790060	ROOM 181 - SINK	Water	09/30/16 01:26	10/11/16 10:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: O CSD - Charles E. Riley Elem.

Pace Project No.: 10365790

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10365790001	ROOM 123D-KITCHEN HAND SINK	EPA 200.8	TT3	1	PASI-M
10365790002	ROOM 134A-SINK	EPA 200.8	TT3	1	PASI-M
10365790003	ROOM 124-SINK	EPA 200.8	TT3	1	PASI-M
10365790004	ROOM 127-WEST SIDE SINK	EPA 200.8	TT3	1	PASI-M
10365790005	ROOM 127-EAST SIDE SINK	EPA 200.8	TT3	1	PASI-M
10365790006	ROOM 123B-SLOP SINK	EPA 200.8	TT3	1	PASI-M
10365790007	STAFF BATH SINK ACROSS 123B	EPA 200.8	TT3	1	PASI-M
10365790008	SINK IN OFFICE BATHROOM	EPA 200.8	TT3	1	PASI-M
10365790009	ROOM 111A - SLOP SINK	EPA 200.8	TT3	1	PASI-M
10365790010	ROOM 113 - SINK	EPA 200.8	TT3	1	PASI-M
10365790011	ROOM 113 - BATHROOM SINK	EPA 200.8	TT3	1	PASI-M
10365790012	ROOM 115 - SINK	EPA 200.8	TT3	1	PASI-M
10365790013	ROOM 115 - BATHROOM SINK	EPA 200.8	TT3	1	PASI-M
10365790014	ROOM 117 - SINK	EPA 200.8	TT3	1	PASI-M
10365790015	ROOM 117 - BATHROOM SINK	EPA 200.8	TT3	1	PASI-M
10365790016	ROOM 112 - SINK	EPA 200.8	TT3	1	PASI-M
10365790017	ROOM 112 - BATHROOM SINK	EPA 200.8	TT3	1	PASI-M
10365790018	ROOM 112 - FOUNTAIN	EPA 200.8	TT3	1	PASI-M
10365790019	ROOM 110 - SINK	EPA 200.8	TT3	1	PASI-M
10365790020	ROOM 110 - BATHROOM SINK	EPA 200.8	TT3	1	PASI-M
10365790021	ROOM 106 - BATHROOM SINK	EPA 200.8	TT3	1	PASI-M
10365790022	ROOM 104A - SINK	EPA 200.8	TT3	1	PASI-M
10365790023	ROOM 104A - BATHROOM SINK	EPA 200.8	TT3	1	PASI-M
10365790024	BOYS BATHRM BOTTOMofRAMP SINK	EPA 200.8	TT3	1	PASI-M
10365790025	GIRLS BATHRM BOTTOMofRAMP SINK	EPA 200.8	TT3	1	PASI-M
10365790026	ROOM 152 SOUTH SINK	EPA 200.8	TT3	1	PASI-M
10365790027	ROOM 152 - NORTH SINK	EPA 200.8	TT3	1	PASI-M
10365790028	ROOM 156 - SINK	EPA 200.8	TT3	1	PASI-M
10365790029	ROOM 156 - BATHROOM SINK	EPA 200.8	TT3	1	PASI-M
10365790030	ROOM 158 - SINK	EPA 200.8	TT3	1	PASI-M
10365790031	ROOM 162 - SLOP SINK	EPA 200.8	TT3	1	PASI-M
10365790032	ROOM 160 - BOYS WEST SINK	EPA 200.8	TT3	1	PASI-M
10365790033	ROOM 160 - BOYS EAST SINK	EPA 200.8	TT3	1	PASI-M
10365790034	ROOM 160 - GIRLS EAST SINK	EPA 200.8	TT3	1	PASI-M
10365790035	ROOM 160 - GIRLS WEST SINK	EPA 200.8	TT3	1	PASI-M
10365790036	ROOM 166 - SINK	EPA 200.8	TT3	1	PASI-M
10365790037	ROOM 168 - SINK	EPA 200.8	TT3	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: O CSD - Charles E. Riley Elem.

Pace Project No.: 10365790

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10365790038	ROOM 169 - SINK	EPA 200.8	TT3	1	PASI-M
10365790039	ROOM 167 - SINK	EPA 200.8	TT3	1	PASI-M
10365790040	ROOM 165 - SINK	EPA 200.8	TT3	1	PASI-M
10365790041	ROOM 157 - SINK	EPA 200.8	TT3	1	PASI-M
10365790042	ROOM 155 - SINK	EPA 200.8	TT3	1	PASI-M
10365790043	RM 202-GIRLS BATHRM-WEST SINK	EPA 200.8	TT3	1	PASI-M
10365790044	RM 202-GIRLS BATHRM-EAST SINK	EPA 200.8	TT3	1	PASI-M
10365790045	ROOM 204-SLOP SINK	EPA 200.8	TT3	1	PASI-M
10365790046	ROOM 212 - SINK	EPA 200.8	TT3	1	PASI-M
10365790047	ROOM 214 - SINK	EPA 200.8	TT3	1	PASI-M
10365790048	ROOM 216 - SINK	EPA 200.8	TT3	1	PASI-M
10365790049	ROOM 217 - SINK	EPA 200.8	TT3	1	PASI-M
10365790050	ROOM 215 - SINK	EPA 200.8	TT3	1	PASI-M
10365790051	ROOM 183 - SINK	EPA 200.8	TT3	1	PASI-M
10365790052	ROOM 184 - SINK	EPA 200.8	TT3	1	PASI-M
10365790053	ROOM 182 - SINK	EPA 200.8	TT3	1	PASI-M
10365790054	ROOM 180 - SINK	EPA 200.8	TT3	1	PASI-M
10365790055	ROOM 176 - SINK	EPA 200.8	TT3	1	PASI-M
10365790056	SLOP SINK OUTIDE ROOM 174	EPA 200.8	TT3	1	PASI-M
10365790057	ROOM 106 - SINK	EPA 200.8	TT3	1	PASI-M
10365790058	ROOM 206-BOYS BATHRM WEST SINK	EPA 200.8	TT3	1	PASI-M
10365790059	ROOM 206-BOYS BATHRM EAST SINK	EPA 200.8	TT3	1	PASI-M
10365790060	ROOM 181 - SINK	EPA 200.8	TT3	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: O CSD - Charles E. Riley Elem.

Pace Project No.: 10365790

Sample:	Lab ID:	Collected:	Received:	Matrix:				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: ROOM 123D-KITCHEN HAND SINK	Lab ID: 10365790001	09/30/16 00:24	10/11/16 10:00	Water				
Analytical Method: EPA 200.8								
Lead	5.9	ug/L	0.10	1		10/15/16 15:48	7439-92-1	
Sample: ROOM 134A-SINK	Lab ID: 10365790002	09/30/16 00:26	10/11/16 10:00	Water				
Analytical Method: EPA 200.8								
Lead	10.5	ug/L	0.10	1		10/15/16 15:57	7439-92-1	
Sample: ROOM 124-SINK	Lab ID: 10365790003	09/30/16 00:28	10/11/16 10:00	Water				
Analytical Method: EPA 200.8								
Lead	3.1	ug/L	0.10	1		10/15/16 15:58	7439-92-1	
Sample: ROOM 127-WEST SIDE SINK	Lab ID: 10365790004	09/30/16 00:29	10/11/16 10:00	Water				
Analytical Method: EPA 200.8								
Lead	10.4	ug/L	0.10	1		10/15/16 16:00	7439-92-1	
Sample: ROOM 127-EAST SIDE SINK	Lab ID: 10365790005	09/30/16 00:29	10/11/16 10:00	Water				
Analytical Method: EPA 200.8								
Lead	6.8	ug/L	0.10	1		10/15/16 16:01	7439-92-1	
Sample: ROOM 123B-SLOP SINK	Lab ID: 10365790006	09/30/16 00:30	10/11/16 10:00	Water				
Analytical Method: EPA 200.8								
Lead	1.8	ug/L	0.10	1		10/15/16 16:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: O CSD - Charles E. Riley Elem.

Pace Project No.: 10365790

Sample: STAFF BATH SINK ACROSS 123B		Lab ID: 10365790007	Collected: 09/30/16 00:31	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.56	ug/L	0.10	1		10/15/16 16:04	7439-92-1	
Sample: SINK IN OFFICE BATHROOM		Lab ID: 10365790008	Collected: 09/30/16 00:34	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	3.5	ug/L	0.10	1		10/15/16 16:06	7439-92-1	
Sample: ROOM 111A - SLOP SINK		Lab ID: 10365790009	Collected: 09/30/16 00:34	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	5.2	ug/L	0.10	1		10/15/16 16:07	7439-92-1	
Sample: ROOM 113 - SINK		Lab ID: 10365790010	Collected: 09/30/16 00:35	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	23.4	ug/L	0.10	1		10/15/16 16:12	7439-92-1	
Sample: ROOM 113 - BATHROOM SINK		Lab ID: 10365790011	Collected: 09/30/16 00:35	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	6.3	ug/L	0.10	1		10/15/16 16:13	7439-92-1	
Sample: ROOM 115 - SINK		Lab ID: 10365790012	Collected: 09/30/16 00:37	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.54	ug/L	0.10	1		10/15/16 16:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: O CSD - Charles E. Riley Elem.

Pace Project No.: 10365790

Sample: ROOM 115 - BATHROOM SINK		Lab ID: 10365790013	Collected: 09/30/16 00:38	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.46	ug/L	0.10	1		10/15/16 16:18	7439-92-1	
Sample: ROOM 117 - SINK		Lab ID: 10365790014	Collected: 09/30/16 00:39	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.5	ug/L	0.10	1		10/15/16 16:19	7439-92-1	
Sample: ROOM 117 - BATHROOM SINK		Lab ID: 10365790015	Collected: 09/30/16 00:40	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.24	ug/L	0.10	1		10/15/16 16:21	7439-92-1	
Sample: ROOM 112 - SINK		Lab ID: 10365790016	Collected: 09/30/16 00:41	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.36	ug/L	0.10	1		10/15/16 16:22	7439-92-1	
Sample: ROOM 112 - BATHROOM SINK		Lab ID: 10365790017	Collected: 09/30/16 00:42	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.48	ug/L	0.10	1		10/15/16 16:24	7439-92-1	
Sample: ROOM 112 - FOUNTAIN		Lab ID: 10365790018	Collected: 09/30/16 00:41	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	4.4	ug/L	0.10	1		10/15/16 16:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: O CSD - Charles E. Riley Elem.
Pace Project No.: 10365790

Sample: ROOM 110 - SINK		Lab ID: 10365790019	Collected: 09/30/16 00:44	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	19.6	ug/L	0.10	1		10/15/16 16:31	7439-92-1	
------	------	------	------	---	--	----------------	-----------	--

Sample: ROOM 110 - BATHROOM SINK		Lab ID: 10365790020	Collected: 09/30/16 00:45	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	3.5	ug/L	0.10	1		10/15/16 16:33	7439-92-1	
------	-----	------	------	---	--	----------------	-----------	--

Sample: ROOM 106 - BATHROOM SINK		Lab ID: 10365790021	Collected: 09/30/16 00:46	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	3.0	ug/L	0.10	1		10/16/16 10:17	7439-92-1	
------	-----	------	------	---	--	----------------	-----------	--

Sample: ROOM 104A - SINK		Lab ID: 10365790022	Collected: 09/30/16 00:47	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	1.8	ug/L	0.10	1		10/16/16 10:26	7439-92-1	
------	-----	------	------	---	--	----------------	-----------	--

Sample: ROOM 104A - BATHROOM SINK		Lab ID: 10365790023	Collected: 09/30/16 00:48	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	0.33	ug/L	0.10	1		10/16/16 10:28	7439-92-1	
------	------	------	------	---	--	----------------	-----------	--

Sample: BOYS BATHRM BOTTOMofRAMP SINK		Lab ID: 10365790024	Collected: 09/30/16 00:51	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	2.5	ug/L	0.10	1		10/16/16 10:29	7439-92-1	
------	-----	------	------	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: O CSD - Charles E. Riley Elem.
Pace Project No.: 10365790

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: GIRLS BATHRM BOTTOMofRAMP SINK								
		Lab ID: 10365790025	Collected: 09/30/16 00:50	Received: 10/11/16 10:00	Matrix: Water			
Analytical Method: EPA 200.8								
Lead	0.95	ug/L	0.10	1		10/16/16 10:31	7439-92-1	
Sample: ROOM 152 SOUTH SINK								
		Lab ID: 10365790026	Collected: 09/30/16 00:52	Received: 10/11/16 10:00	Matrix: Water			
Analytical Method: EPA 200.8								
Lead	0.49	ug/L	0.10	1		10/16/16 10:32	7439-92-1	
Sample: ROOM 152 - NORTH SINK								
		Lab ID: 10365790027	Collected: 09/30/16 00:54	Received: 10/11/16 10:00	Matrix: Water			
Analytical Method: EPA 200.8								
Lead	1.0	ug/L	0.10	1		10/16/16 10:34	7439-92-1	
Sample: ROOM 156 - SINK								
		Lab ID: 10365790028	Collected: 09/30/16 00:56	Received: 10/11/16 10:00	Matrix: Water			
Analytical Method: EPA 200.8								
Lead	74.3	ug/L	0.10	1		10/16/16 10:35	7439-92-1	
Sample: ROOM 156 - BATHROOM SINK								
		Lab ID: 10365790029	Collected: 09/30/16 00:56	Received: 10/11/16 10:00	Matrix: Water			
Analytical Method: EPA 200.8								
Lead	28.2	ug/L	0.10	1		10/16/16 10:37	7439-92-1	
Sample: ROOM 158 - SINK								
		Lab ID: 10365790030	Collected: 09/30/16 00:58	Received: 10/11/16 10:00	Matrix: Water			
Analytical Method: EPA 200.8								
Lead	4.5	ug/L	0.10	1		10/16/16 10:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: O CSD - Charles E. Riley Elem.
Pace Project No.: 10365790

Sample: ROOM 162 - SLOP SINK		Lab ID: 10365790031	Collected: 09/30/16 01:00	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	8.3	ug/L	0.10	1		10/16/16 10:40	7439-92-1	

Sample: ROOM 160 - BOYS WEST SINK		Lab ID: 10365790032	Collected: 09/30/16 01:01	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	3.3	ug/L	0.10	1		10/16/16 10:46	7439-92-1	

Sample: ROOM 160 - BOYS EAST SINK		Lab ID: 10365790033	Collected: 09/30/16 01:01	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	3.3	ug/L	0.10	1		10/16/16 10:47	7439-92-1	

Sample: ROOM 160 - GIRLS EAST SINK		Lab ID: 10365790034	Collected: 09/30/16 00:59	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	5.7	ug/L	0.10	1		10/16/16 10:49	7439-92-1	

Sample: ROOM 160 - GIRLS WEST SINK		Lab ID: 10365790035	Collected: 09/30/16 01:00	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	9.9	ug/L	0.10	1		10/16/16 10:50	7439-92-1	

Sample: ROOM 166 - SINK		Lab ID: 10365790036	Collected: 09/30/16 01:03	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	17.6	ug/L	0.10	1		10/16/16 10:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: O CSD - Charles E. Riley Elem.

Pace Project No.: 10365790

Sample: ROOM 168 - SINK		Lab ID: 10365790037	Collected: 09/30/16 01:04	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	19.4	ug/L	0.10	1		10/16/16 10:54	7439-92-1	
Sample: ROOM 169 - SINK		Lab ID: 10365790038	Collected: 09/30/16 01:05	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	9.1	ug/L	0.10	1		10/16/16 10:55	7439-92-1	
Sample: ROOM 167 - SINK		Lab ID: 10365790039	Collected: 09/30/16 01:06	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	9.6	ug/L	0.10	1		10/16/16 10:57	7439-92-1	
Sample: ROOM 165 - SINK		Lab ID: 10365790040	Collected: 09/30/16 01:06	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	3.9	ug/L	0.10	1		10/16/16 10:58	7439-92-1	
Sample: ROOM 157 - SINK		Lab ID: 10365790041	Collected: 09/30/16 01:07	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	49.2	ug/L	0.10	1		10/15/16 17:23	7439-92-1	
Sample: ROOM 155 - SINK		Lab ID: 10365790042	Collected: 09/30/16 01:07	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	8.2	ug/L	0.10	1		10/15/16 17:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: O CSD - Charles E. Riley Elem.
Pace Project No.: 10365790

Sample: RM 202-GIRLS BATHRM- WEST SINK **Lab ID: 10365790043** Collected: 09/30/16 01:17 Received: 10/11/16 10:00 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	4.7	ug/L	0.10	1		10/15/16 17:31	7439-92-1	

Sample: RM 202-GIRLS BATHRM- EAST SINK **Lab ID: 10365790044** Collected: 09/30/16 01:17 Received: 10/11/16 10:00 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	7.8	ug/L	0.10	1		10/15/16 17:32	7439-92-1	

Sample: ROOM 204-SLOP SINK **Lab ID: 10365790045** Collected: 09/30/16 01:16 Received: 10/11/16 10:00 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	13.0	ug/L	0.10	1		10/15/16 17:34	7439-92-1	

Sample: ROOM 212 - SINK **Lab ID: 10365790046** Collected: 09/30/16 00:14 Received: 10/11/16 10:00 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	9.4	ug/L	0.10	1		10/15/16 17:35	7439-92-1	

Sample: ROOM 214 - SINK **Lab ID: 10365790047** Collected: 09/30/16 01:13 Received: 10/11/16 10:00 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	28.4	ug/L	0.10	1		10/15/16 17:37	7439-92-1	

Sample: ROOM 216 - SINK **Lab ID: 10365790048** Collected: 09/30/16 01:09 Received: 10/11/16 10:00 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	21.6	ug/L	0.10	1		10/15/16 17:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: O CSD - Charles E. Riley Elem.
Pace Project No.: 10365790

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: ROOM 217 - SINK **Lab ID: 10365790049** Collected: 09/30/16 01:10 Received: 10/11/16 10:00 Matrix: Water

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	8.4	ug/L	0.10	1		10/15/16 17:43	7439-92-1	
------	-----	------	------	---	--	----------------	-----------	--

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: ROOM 215 - SINK **Lab ID: 10365790050** Collected: 09/30/16 01:12 Received: 10/11/16 10:00 Matrix: Water

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	22.8	ug/L	0.10	1		10/15/16 17:44	7439-92-1	
------	------	------	------	---	--	----------------	-----------	--

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: ROOM 183 - SINK **Lab ID: 10365790051** Collected: 09/30/16 01:29 Received: 10/11/16 10:00 Matrix: Water

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	6.4	ug/L	0.10	1		10/15/16 17:46	7439-92-1	
------	-----	------	------	---	--	----------------	-----------	--

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: ROOM 184 - SINK **Lab ID: 10365790052** Collected: 09/30/16 01:27 Received: 10/11/16 10:00 Matrix: Water

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	17.7	ug/L	0.10	1		10/15/16 17:49	7439-92-1	
------	------	------	------	---	--	----------------	-----------	--

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: ROOM 182 - SINK **Lab ID: 10365790053** Collected: 09/30/16 01:25 Received: 10/11/16 10:00 Matrix: Water

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	8.0	ug/L	0.10	1		10/15/16 17:50	7439-92-1	
------	-----	------	------	---	--	----------------	-----------	--

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: ROOM 180 - SINK **Lab ID: 10365790054** Collected: 09/30/16 01:23 Received: 10/11/16 10:00 Matrix: Water

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	10.5	ug/L	0.10	1		10/15/16 17:52	7439-92-1	
------	------	------	------	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: O CSD - Charles E. Riley Elem.

Pace Project No.: 10365790

Sample: ROOM 176 - SINK		Lab ID: 10365790055	Collected: 09/30/16 01:23	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.7	ug/L	0.10	1		10/15/16 17:53	7439-92-1	
Sample: SLOP SINK OUTSIDE ROOM 174		Lab ID: 10365790056	Collected: 09/30/16 01:21	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	6.4	ug/L	0.10	1		10/15/16 17:55	7439-92-1	
Sample: ROOM 106 - SINK		Lab ID: 10365790057	Collected: 09/30/16 00:46	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8						
Lead	43.3	ug/L	0.10	1	10/18/16 12:27	10/18/16 22:48	7439-92-1	
Sample: ROOM 206-BOYS BATHRM WEST SINK		Lab ID: 10365790058	Collected: 09/30/16 01:19	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	13.4	ug/L	0.10	1		10/15/16 17:59	7439-92-1	
Sample: ROOM 206-BOYS BATHRM EAST SINK		Lab ID: 10365790059	Collected: 09/30/16 01:19	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	10.6	ug/L	0.10	1		10/15/16 18:01	7439-92-1	
Sample: ROOM 181 - SINK		Lab ID: 10365790060	Collected: 09/30/16 01:26	Received: 10/11/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	14.6	ug/L	0.10	1		10/15/16 18:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: O CSD - Charles E. Riley Elem.
Pace Project No.: 10365790

QC Batch: 440809 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
Associated Lab Samples: 10365790001, 10365790002, 10365790003, 10365790004, 10365790005, 10365790006, 10365790007, 10365790008, 10365790009, 10365790010, 10365790011, 10365790012, 10365790013, 10365790014, 10365790015, 10365790016, 10365790017, 10365790018, 10365790019, 10365790020

METHOD BLANK: 2398257 Matrix: Water
Associated Lab Samples: 10365790001, 10365790002, 10365790003, 10365790004, 10365790005, 10365790006, 10365790007, 10365790008, 10365790009, 10365790010, 10365790011, 10365790012, 10365790013, 10365790014, 10365790015, 10365790016, 10365790017, 10365790018, 10365790019, 10365790020

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/15/16 15:35	

LABORATORY CONTROL SAMPLE: 2398258

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	111	111	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2402014 2402015

Parameter	Units	10365790001 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	5.9	100	100	108	110	102	104	70-130	2	20	

MATRIX SPIKE SAMPLE: 2402016

Parameter	Units	10365790011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	6.3	100	108	102	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: O CSD - Charles E. Riley Elem.
Pace Project No.: 10365790

QC Batch: 440811 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
Associated Lab Samples: 10365790021, 10365790022, 10365790023, 10365790024, 10365790025, 10365790026, 10365790027, 10365790028, 10365790029, 10365790030, 10365790031, 10365790032, 10365790033, 10365790034, 10365790035, 10365790036, 10365790037, 10365790038, 10365790039, 10365790040

METHOD BLANK: 2398263 Matrix: Water
Associated Lab Samples: 10365790021, 10365790022, 10365790023, 10365790024, 10365790025, 10365790026, 10365790027, 10365790028, 10365790029, 10365790030, 10365790031, 10365790032, 10365790033, 10365790034, 10365790035, 10365790036, 10365790037, 10365790038, 10365790039, 10365790040

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/16/16 10:08	

LABORATORY CONTROL SAMPLE: 2398264

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	103	103	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2402480 2402481

Parameter	Units	10365790021 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	3.0	100	100	102	102	99	99	70-130	0	20	

MATRIX SPIKE SAMPLE: 2402482

Parameter	Units	10365790031 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	8.3	100	104	95	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: O CSD - Charles E. Riley Elem.

Pace Project No.: 10365790

QC Batch:	440812	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	ICPMS Metals, Drinking Water
Associated Lab Samples:	10365790041, 10365790042, 10365790043, 10365790044, 10365790045, 10365790046, 10365790047, 10365790048, 10365790049, 10365790050, 10365790051, 10365790052, 10365790053, 10365790054, 10365790055, 10365790056, 10365790058, 10365790059, 10365790060		

METHOD BLANK:	2398266	Matrix:	Water
Associated Lab Samples:	10365790041, 10365790042, 10365790043, 10365790044, 10365790045, 10365790046, 10365790047, 10365790048, 10365790049, 10365790050, 10365790051, 10365790052, 10365790053, 10365790054, 10365790055, 10365790056, 10365790058, 10365790059, 10365790060		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/15/16 17:05	

LABORATORY CONTROL SAMPLE: 2398267

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	101	101	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2402023 2402024

Parameter	Units	10365790041 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	49.2	100	100	151	152	102	103	70-130	1	20	

MATRIX SPIKE SAMPLE: 2402025

Parameter	Units	10365790051 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	6.4	100	106	100	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: O CSD - Charles E. Riley Elem.

Pace Project No.: 10365790

QC Batch: 441615	Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8	Analysis Description: 200.8 MET
Associated Lab Samples: 10365790057	

METHOD BLANK: 2403963 Matrix: Water
Associated Lab Samples: 10365790057

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/18/16 22:41	

LABORATORY CONTROL SAMPLE: 2403964

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	107	107	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2403965 2403966

Parameter	Units	10365790057 Result	MS	MSD	MS	MSD	MS	MSD	% Rec	Max		Qual
			Spike Conc.	Spike Conc.	Result	Result	% Rec	% Rec	Limits	RPD	RPD	
Lead	ug/L	43.3	100	100	140	140	97	97	70-130	0	20	

MATRIX SPIKE SAMPLE: 2403967

Parameter	Units	10366210062 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L		232	100	326	94	70-130

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: O CSD - Charles E. Riley Elem.

Pace Project No.: 10365790

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

LABORATORIES

PASI-M Pace Analytical Services - Minneapolis

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: O CSD - Charles E. Riley Elem.

Pace Project No.: 10365790

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10365790001	ROOM 123D-KITCHEN HAND SINK	EPA 200.8	440809		
10365790002	ROOM 134A-SINK	EPA 200.8	440809		
10365790003	ROOM 124-SINK	EPA 200.8	440809		
10365790004	ROOM 127-WEST SIDE SINK	EPA 200.8	440809		
10365790005	ROOM 127-EAST SIDE SINK	EPA 200.8	440809		
10365790006	ROOM 123B-SLOP SINK	EPA 200.8	440809		
10365790007	STAFF BATH SINK ACROSS 123B	EPA 200.8	440809		
10365790008	SINK IN OFFICE BATHROOM	EPA 200.8	440809		
10365790009	ROOM 111A - SLOP SINK	EPA 200.8	440809		
10365790010	ROOM 113 - SINK	EPA 200.8	440809		
10365790011	ROOM 113 - BATHROOM SINK	EPA 200.8	440809		
10365790012	ROOM 115 - SINK	EPA 200.8	440809		
10365790013	ROOM 115 - BATHROOM SINK	EPA 200.8	440809		
10365790014	ROOM 117 - SINK	EPA 200.8	440809		
10365790015	ROOM 117 - BATHROOM SINK	EPA 200.8	440809		
10365790016	ROOM 112 - SINK	EPA 200.8	440809		
10365790017	ROOM 112 - BATHROOM SINK	EPA 200.8	440809		
10365790018	ROOM 112 - FOUNTAIN	EPA 200.8	440809		
10365790019	ROOM 110 - SINK	EPA 200.8	440809		
10365790020	ROOM 110 - BATHROOM SINK	EPA 200.8	440809		
10365790021	ROOM 106 - BATHROOM SINK	EPA 200.8	440811		
10365790022	ROOM 104A - SINK	EPA 200.8	440811		
10365790023	ROOM 104A - BATHROOM SINK	EPA 200.8	440811		
10365790024	BOYS BATHRM BOTTOMofRAMP SINK	EPA 200.8	440811		
10365790025	GIRLS BATHRM BOTTOMofRAMP SINK	EPA 200.8	440811		
10365790026	ROOM 152 SOUTH SINK	EPA 200.8	440811		
10365790027	ROOM 152 - NORTH SINK	EPA 200.8	440811		
10365790028	ROOM 156 - SINK	EPA 200.8	440811		
10365790029	ROOM 156 - BATHROOM SINK	EPA 200.8	440811		
10365790030	ROOM 158 - SINK	EPA 200.8	440811		
10365790031	ROOM 162 - SLOP SINK	EPA 200.8	440811		
10365790032	ROOM 160 - BOYS WEST SINK	EPA 200.8	440811		
10365790033	ROOM 160 - BOYS EAST SINK	EPA 200.8	440811		
10365790034	ROOM 160 - GIRLS EAST SINK	EPA 200.8	440811		
10365790035	ROOM 160 - GIRLS WEST SINK	EPA 200.8	440811		
10365790036	ROOM 166 - SINK	EPA 200.8	440811		
10365790037	ROOM 168 - SINK	EPA 200.8	440811		
10365790038	ROOM 169 - SINK	EPA 200.8	440811		
10365790039	ROOM 167 - SINK	EPA 200.8	440811		
10365790040	ROOM 165 - SINK	EPA 200.8	440811		
10365790041	ROOM 157 - SINK	EPA 200.8	440812		
10365790042	ROOM 155 - SINK	EPA 200.8	440812		
10365790043	RM 202-GIRLS BATHRM-WEST SINK	EPA 200.8	440812		
10365790044	RM 202-GIRLS BATHRM-EAST SINK	EPA 200.8	440812		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: O CSD - Charles E. Riley Elem.

Pace Project No.: 10365790

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10365790045	ROOM 204-SLOP SINK	EPA 200.8	440812		
10365790046	ROOM 212 - SINK	EPA 200.8	440812		
10365790047	ROOM 214 - SINK	EPA 200.8	440812		
10365790048	ROOM 216 - SINK	EPA 200.8	440812		
10365790049	ROOM 217 - SINK	EPA 200.8	440812		
10365790050	ROOM 215 - SINK	EPA 200.8	440812		
10365790051	ROOM 183 - SINK	EPA 200.8	440812		
10365790052	ROOM 184 - SINK	EPA 200.8	440812		
10365790053	ROOM 182 - SINK	EPA 200.8	440812		
10365790054	ROOM 180 - SINK	EPA 200.8	440812		
10365790055	ROOM 176 - SINK	EPA 200.8	440812		
10365790056	SLOP SINK OUTSIDE ROOM 174	EPA 200.8	440812		
10365790058	ROOM 206-BOYS BATHRM WEST SINK	EPA 200.8	440812		
10365790059	ROOM 206-BOYS BATHRM EAST SINK	EPA 200.8	440812		
10365790060	ROOM 181 - SINK	EPA 200.8	440812		
10365790057	ROOM 106 - SINK	EPA 200.8	441615	EPA 200.8	441832

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

10365790

Section A Requested Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: Oswego CSD		Report To:		Attention:	
Address: 225 West Ulica St Oswego, NY 12126		Copy To:		Company Name:	
Email To: dcrisafu@oswego.org		Purchase Order No.:		Address:	
Phone:		Project Name: Charles E. Riley Elem.		Pace Quote Reference:	
Requested Due Date/TAT:		Project Number:		Pace Project Manager:	
				Pace Profile #:	

REGULATORY AGENCY

NPDES GROUND WATER DRINKING WATER

UST RCRA OTHER

SITE LOCATION

GA IL IN MI NC

OH SC WI OTHER_NY

ITEM #	Section D Required Client Information	Valid Matrix Codes	MATRIX CODE	SAMPLE TYPE	COLLECTED		# OF CONTAINERS	PRESERVATIVES	Requested Analyte	Filtered (Y/N)	Face Project No. Lab ID.
					COMPOSITE START	COMPOSITE END/GRAB					
1	GIRLS BATHROOM BOTTOM OF RAMP SINK	DW	DW	G	9/30	08:50	1	Unpreserved			025
2	ROOM 152 SOUTH SINK	DW	DW	G		00:52	1				026
3	ROOM 152 - NORTH SINK	DW	DW	G		00:54	1				027
4	ROOM 156 - SINK	DW	DW	G		00:56	1				028
5	ROOM 156 - BATHROOM SINK	DW	DW	G		00:58	1				029
6	ROOM 158 - SINK	DW	DW	G		1:00	1				030
7	ROOM 162 - SLOP SINK	DW	DW	G		1:01	1				031
8	ROOM 160-BOYS WEST SINK	DW	DW	G		1:01	1				032
9	ROOM 160-BOYS EAST SINK	DW	DW	G		00:59	1				033
10	ROOM 160 - GIRLS EAST SINK	DW	DW	G		1:00	1				034
11	ROOM 160 - GIRLS WEST SINK	DW	DW	G		1:03	1				035
12	ROOM 166 - SINK	DW	DW	G			1				036

RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
<i>James Murphy</i> PACE	9/30/16	18:30	<i>E. Y. Pace</i>	10/24/16	1000	Y/N Y/N Y/N Y/N Y/N Y/N Y/N
						Temp in C
						Received on
						Ice
						Custody Sealed
						Cooler
						Samples Intact

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: James Murphy - PACE Analytical

SIGNATURE of SAMPLER: *James Murphy*

DATE Signed (MM/DD/YY): 9/30/16



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

10365790

Section A
 Required Client Information:
 Company: Oswego CSD
 Address: 225 West Ulica St
 Oswego, NY 12126
 Email To: gcorisafu@oswego.org
 Phone: _____
 Fax: _____

Section B
 Required Project Information:
 Report To: _____
 Copy To: _____
 Purchase Order No.: _____
 Project Name: Charles E. Riley Elem.
 Project Number: _____

Section C
 Invoice Information:
 Attention: _____
 Company Name: _____
 Address: _____
 Pace Quote Reference: _____
 Pace Project Manager: _____
 Pace Profile #: _____

Page: 4 of 5

REGULATORY AGENCY

NPDES GROUND WATER DRINKING WATER
 UST RCRA OTHER _____

SITE GA IL IN MI NC
LOCATION OH SC WI OTHER_NY _____

ITEM #	Section D Required Client Information	Valid Matrix Codes	MATRIX CODE	SAMPLER TYPE	COLLECTED		# OF CONTAINERS	PRESERVATIVES						Requested Analyte	Pace Project No. Lab I.D.
					COMPOSITE START	COMPOSITE END/GRAB		Unpreserved	H ₂ SO ₄	HNO ₃	HCl	NaOH	Na ₂ S ₂ O ₈		
					DATE	TIME									
1	ROOM 168 - SINK	DW	DW	G	9/30	1:04	1								037
2	ROOM 169 - SINK	DW	DW	G	1:05		1								038
3	ROOM 167 - SINK	DW	DW	G	1:06		1								039
4	ROOM 165 - SINK	DW	DW	G	1:06		1								040
5	ROOM 157 - SINK	DW	DW	G	1:07		1								041
6	ROOM 155 - SINK	DW	DW	G	1:07		1								042
7	ROOM 202-GIRLS BATHROOM-WEST SINK	DW	DW	G	1:17		1								043
8	ROOM 202-GIRLS BATHROOM-EAST SINK	DW	DW	G	1:17		1								044
9	ROOM 204-SLOP SINK	DW	DW	G	1:16		1								045
10	ROOM 212 - SINK	DW	DW	G	00:14		1								046
11	ROOM 214 - SINK	DW	DW	G	1:13		1								047
12	ROOM 216 - SINK	DW	DW	G	1:09		1								048

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
	J. Murphy PACE	10/16/16	15:30	E.L. Pace	10/16/16	15:00	Temp in °C Received on Ice Custody Sealed Cooler Samples Intact
							Y/N Y/N Y/N Y/N Y/N
							Y/N Y/N Y/N Y/N Y/N

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: James Murphy - PACE Analytical
 SIGNATURE of SAMPLER: *J. Murphy*
 DATE Signed (MM / DD / YY): 9/30/16



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

10365790

Section A

Required Client Information:

Company: Oswego CSD

Address: 225 West Ulica St

Oswego, NY 12126

Email To:

dotrisatu@oswego.org

Phone:

Fac:

Section B

Required Project Information:

Report To:

Copy To:

Company Name:

Address:

Purchase Order No.:

Pace Quote Reference:

Project Name:

Charles E. Riley Elem.

Project Number:

Pace Profile #:

Section C

Invoice Information:

Attention:

Company Name:

Address:

Pace Quote Reference:

Pace Project Manager:

REGULATORY AGENCY

NPDES GROUND WATER DRINKING WATER

UST RCRA OTHER

SITE GA IL IN MI NC

LOCATION OH SC WI OTHER_NY

Section D

Requested Due Date/TAT:

Project Name:

Address:

Oswego, NY 12126

Email To:

dotrisatu@oswego.org

Phone:

Fac:

Requested Due Date/TAT:

Project Name:

Address:

Oswego, NY 12126

Email To:

dotrisatu@oswego.org

Phone:

Fac:

Valid Matrix Codes

DW DRINKING WATER
 WW WASTE WATER
 SL SOLID
 OIL OIL
 WIFE WIFE
 OTHER OTHER
 TISSUE TISSUE

Required Client Information

MATRIX CODE

DW DW
 WW WW
 SL SL
 OIL OIL
 WIFE WIFE
 OTHER OTHER
 TISSUE TISSUE

SAMPLE TYPE

G-GRAB G-COMP

DW G
 DW G
 DW G
 DW G
 DW G
 DW G
 DW G
 DW G
 DW G
 DW G
 DW G

COLLECTED

COMPOSITE START

DATE TIME

9/30 1:10
 1:12
 1:29
 1:27
 1:26
 1:25
 1:23
 1:23
 1:21
 1:19
 1:19

COMPOSITE ENDIGRAB

DATE TIME

1:10
 1:12
 1:29
 1:27
 1:26
 1:25
 1:23
 1:23
 1:21
 1:19
 1:19

OF CONTAINERS

1
 1
 1
 1
 1
 1
 1
 1
 1
 1
 1

SAMPLE TEMP AT COLLECTION

DATE TIME

10/10/10 18:30

ACCEPTED BY / AFFILIATION

DATE TIME

10/10/10 18:30

RELINQUISHED BY / AFFILIATION

DATE TIME

9/30/10 18:30

ADDITIONAL COMMENTS

J. Murphy Pace

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

10/10/10 18:30

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER:

James Murphy - PACE Analytical

SIGNATURE of SAMPLER:

J. Murphy

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER:

James Murphy - PACE Analytical

SIGNATURE of SAMPLER:

J. Murphy

DATE Signed

(MM / DD / YY):

9/30/10

Temp in C

Received on

Ice

Custody Sealed

Y/N

SAMPLE CONDITIONS

Temp in C

Received on

Ice

Custody Sealed

Y/N

Y/N

Y/N

Y/N

Y/N

DATE Signed

(MM / DD / YY):

9/30/10

Temp in C

Received on

Ice

Custody Sealed

Y/N

SAMPLE CONDITIONS

Temp in C

Received on

Ice

Custody Sealed

Y/N

DATE Signed

(MM / DD / YY):

9/30/10

Temp in C

Received on

Ice

Custody Sealed

Y/N

SAMPLE CONDITIONS

Temp in C

Received on

Ice

Custody Sealed

Y/N

DATE Signed

(MM / DD / YY):

9/30/10

Temp in C

Received on

Ice

Custody Sealed

Y/N

SAMPLE CONDITIONS

Temp in C

Received on

Ice

Custody Sealed

Y/N

DATE Signed

(MM / DD / YY):

9/30/10

Temp in C

Received on

Ice

Custody Sealed

Y/N

SAMPLE CONDITIONS

Temp in C

Received on

Ice

Custody Sealed

Y/N

DATE Signed

(MM / DD / YY):

9/30/10

Temp in C

Received on

Ice

Custody Sealed

Y/N

SAMPLE CONDITIONS

Temp in C

Received on

Ice

Custody Sealed

Y/N

DATE Signed

(MM / DD / YY):

9/30/10

Temp in C

Received on

Ice

Custody Sealed

Y/N

SAMPLE CONDITIONS

Temp in C

Received on

Ice

Custody Sealed

Y/N

DATE Signed

(MM / DD / YY):

9/30/10

Temp in C

Received on

Ice

Custody Sealed

Y/N

SAMPLE CONDITIONS

Temp in C

Received on

Ice

Custody Sealed

Y/N

DATE Signed

(MM / DD / YY):

9/30/10

Temp in C

Received on

Ice

Custody Sealed

Y/N

SAMPLE CONDITIONS

Temp in C

Received on

Ice

Custody Sealed

Y/N

DATE Signed

(MM / DD / YY):

9/30/10

Temp in C

Received on

Ice

Custody Sealed

Y/N

SAMPLE CONDITIONS

Temp in C

Received on

Ice

Custody Sealed

Y/N

DATE Signed

(MM / DD / YY):

9/30/10

Temp in C

Received on

Ice

Custody Sealed

Y/N

SAMPLE CONDITIONS

Temp in C

Received on

Ice

Custody Sealed

Y/N

DATE Signed

(MM / DD / YY):

9/30/10

Temp in C

Received on

Ice

Custody Sealed

Y/N

SAMPLE CONDITIONS

Temp in C


Received on

Ice

Custody Sealed

Y/N

DATE Signed

Sample Condition Upon Receipt	Client Name: <u>Oswego CSD</u>	Project #: WO# : 10365790
Courier: <input checked="" type="checkbox"/> Fed Ex <input type="checkbox"/> UPS <input type="checkbox"/> USPS <input type="checkbox"/> Client <input type="checkbox"/> Commercial <input type="checkbox"/> Pace <input type="checkbox"/> SpeedDee <input type="checkbox"/> Other: _____	Tracking Number: <u>7744463587</u>	 10365790

Custody Seal on Cooler/Box Present? Yes No **Seals Intact?** Yes No **Optional:** Proj. Due Date: _____ Proj. Name: _____

Packing Material: Bubble Wrap Bubble Bags None Other: _____ **Temp Blank?** Yes No

Thermometer Used: 151401163 151401164 B88A912167504 B88A0143310098 **Type of Ice:** Wet Blue None Samples on ice, cooling process has begun

Cooler Temp Read (°C): 17.6 **Cooler Temp Corrected (°C):** 17.8 **Biological Tissue Frozen?** Yes No N/A

Temp should be above freezing to 6°C **Correction Factor:** 10.2 **Date and Initials of Person Examining Contents:** ER 10/12/16

USDA Regulated Soil (N/A, water sample)
 Did samples originate in a quarantine zone within the United States: AL, AR, AZ, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX or VA (check maps)? Yes No N/A
 Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? Yes No N/A
If Yes to either question, fill out a Regulated Soil Checklist (F-MN-Q-338) and include with SCUR/COC paperwork.

	COMMENTS:
Chain of Custody Present? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	1.
Chain of Custody Filled Out? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	2.
Chain of Custody Relinquished? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	3.
Sampler Name and/or Signature on COC? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	5.
Short Hold Time Analysis (<72 hr)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	6.
Rush Turn Around Time Requested? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	7.
Sufficient Volume? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	8.
Correct Containers Used? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	9.
-Pace Containers Used? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Containers Intact? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	10.
Filtered Volume Received for Dissolved Tests? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container
Sample Labels Match COC? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	12.
-Includes Date/Time/ID/Analysis Matrix: <u>WT</u>	
All containers needing acid/base preservation have been checked? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input checked="" type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
All containers needing preservation are found to be in compliance with EPA recommendation? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Sample # <u>1-60</u>
(HNO ₃ , H ₂ SO ₄ , HCl<2; NaOH >9 Sulfide, NaOH >12 Cyanide) Exceptions: VOA, Coliform, TOC, Oil and Grease, DRO/8015 (water) DOC <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Initial when completed: _____ Lot # of added preservative: _____
Headspace in VOA Vials (>6mm)? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14.
Trip Blank Present? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Trip Blank Custody Seals Present? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if purchased): _____	

CLIENT NOTIFICATION/RESOLUTION **Field Data Required?** Yes No

Person Contacted: _____ Date/Time: _____

Comments/Resolution: _____

Project Manager Review: Awanda J. Albrecht **Date:** 10/14/16

Note: Whenever there is a discrepancy affecting North Carolina compliance samples, a copy of this form will be sent to the North Carolina DEHNR Certification Office (i.e. out of hold, incorrect preservative, out of temp, incorrect containers).