

October 19, 2016

David Crisafulli
Oswego CSD
225 West Utica St
Oswego, NY 12126

RE: Project: O CSD - Fitzhugh Park Elem.
Pace Project No.: 10365797

Dear David Crisafulli:

Enclosed are the analytical results for sample(s) received by the laboratory on October 12, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

Samples, in the electronic data deliverable (EDD) that accompanied this report, were flagged yellow if they exceeded the NYSDOH 15 ppb action level.

The space designated for the sampler on the chain of custody (COC) indicates if these samples were collected by Pace Analytical or were collected by the school district and just relinquished to Pace Analytical.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Amanda Albrecht
amanda.albrecht@pacelabs.com
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: O CSD - Fitzhugh Park Elem.

Pace Project No.: 10365797

Minnesota Certification IDs

1700 Elm Street SE Suite 200, Minneapolis, MN 55414

Alaska Certification UST-107

525 N 8th Street, Salina, KS 67401

A2LA Certification #: 2926.01

Alaska Certification #: UST-078

Alaska Certification #MN00064

Alabama Certification #40770

Arizona Certification #: AZ-0014

Arkansas Certification #: 88-0680

California Certification #: 01155CA

Colorado Certification #Pace

Connecticut Certification #: PH-0256

EPA Region 8 Certification #: 8TMS-L

Florida/NELAP Certification #: E87605

Guam Certification #:14-008r

Georgia Certification #: 959

Georgia EPD #: Pace

Idaho Certification #: MN00064

Hawaii Certification #MN00064

Illinois Certification #: 200011

Indiana Certification#C-MN-01

Iowa Certification #: 368

Kansas Certification #: E-10167

Kentucky Dept of Envi. Protection - DW #90062

Kentucky Dept of Envi. Protection - WW #:90062

Louisiana DEQ Certification #: 3086

Louisiana DHH #: LA140001

Maine Certification #: 2013011

Maryland Certification #: 322

Michigan DEPH Certification #: 9909

Minnesota Certification #: 027-053-137

Mississippi Certification #: Pace

Montana Certification #: MT0092

Nevada Certification #: MN_00064

Nebraska Certification #: Pace

New Jersey Certification #: MN-002

New York Certification #: 11647

North Carolina Certification #: 530

North Carolina State Public Health #: 27700

North Dakota Certification #: R-036

Ohio EPA #: 4150

Ohio VAP Certification #: CL101

Oklahoma Certification #: 9507

Oregon Certification #: MN200001

Oregon Certification #: MN300001

Pennsylvania Certification #: 68-00563

Puerto Rico Certification

Saipan (CNMI) #:MP0003

South Carolina #:74003001

Texas Certification #: T104704192

Tennessee Certification #: 02818

Utah Certification #: MN000642013-4

Virginia DGS Certification #: 251

Virginia/VELAP Certification #: Pace

Washington Certification #: C486

West Virginia Certification #: 382

West Virginia DHHR #:9952C

Wisconsin Certification #: 999407970

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: O CSD - Fitzhugh Park Elem.

Pace Project No.: 10365797

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10365797001	ROOM 226 - SINK	Water	09/30/16 01:40	10/12/16 10:00
10365797002	SLOP SINK OUTSIDE KILN ROOM	Water	09/30/16 01:41	10/12/16 10:00
10365797003	ROOM 225 - NORTH SINK	Water	09/30/16 01:42	10/12/16 10:00
10365797004	ROOM 225 - SOUTH SINK	Water	09/30/16 01:43	10/12/16 10:00
10365797005	ROOM 220B - NORTH SINK	Water	09/30/16 01:45	10/12/16 10:00
10365797006	ROOM 220A - SOUTH SINK	Water	09/30/16 01:45	10/12/16 10:00
10365797007	ROOM 215 - SINK	Water	09/30/16 01:48	10/12/16 10:00
10365797008	ROOM 210B - NORTH SINK	Water	09/30/16 01:50	10/12/16 10:00
10365797009	ROOM 210A - SOUTH SINK	Water	09/30/16 01:50	10/12/16 10:00
10365797010	GANG BATH NEXTtoRM 108 - SOUTH	Water	09/30/16 02:16	10/12/16 10:00
10365797011	GANG BATH NEXTtoRM 108 - NORTH	Water	09/30/16 02:15	10/12/16 10:00
10365797012	ROOM 110 - SINK	Water	09/30/16 02:14	10/12/16 10:00
10365797013	ROOM 109 - SINK	Water	09/30/16 02:13	10/12/16 10:00
10365797014	ROOM 112 - SINK	Water	09/30/16 02:13	10/12/16 10:00
10365797015	ROOM 111 - SINK	Water	09/30/16 02:12	10/12/16 10:00
10365797016	GANG BATH NEXTtoRM 114 - SOUTH	Water	09/30/16 02:17	10/12/16 10:00
10365797017	GANG BATH NEXTtoRM 114 - NORTH	Water	09/30/16 02:11	10/12/16 10:00
10365797018	ROOM 113 - SINK	Water	09/30/16 02:10	10/12/16 10:00
10365797019	ROOM 117 - COACHES OFFICE SINK	Water	09/30/16 02:04	10/12/16 10:00
10365797020	TUB RM SINK ACROSS GYM-RM 116C	Water	09/30/16 02:00	10/12/16 10:00
10365797021	BOYS STAFF BATHRM SINK-1ST FLR	Water	09/30/16 02:02	10/12/16 10:00
10365797022	GIRLS STAFF BATHRM -1ST FLR	Water	09/30/16 02:03	10/12/16 10:00
10365797023	ROOM 120A - SINK	Water	09/30/16 01:55	10/12/16 10:00
10365797024	ROOM 120 - SINK	Water	09/30/16 01:58	10/12/16 10:00
10365797025	ROOM 014A - SLOP SINK	Water	09/30/16 02:23	10/12/16 10:00
10365797026	ROOM 013A STAFF BATHROOMS	Water	09/30/16 02:24	10/12/16 10:00
10365797027	GANG BATH NEXTtoRM 010 - NORTH	Water	09/30/16 02:29	10/12/16 10:00
10365797028	GANG BATH NEXTtoRM 010 - MIDDLE	Water	09/30/16 02:28	10/12/16 10:00
10365797029	GANG BATH NEXTtoRM 010 - SOUTH	Water	09/30/16 02:28	10/12/16 10:00
10365797030	ROOM 007 - SINK	Water	09/30/16 02:38	10/12/16 10:00
10365797031	ROOM 005 - SINK	Water	09/30/16 02:30	10/12/16 10:00
10365797032	ROOM 003 - SINK	Water	09/30/16 02:31	10/12/16 10:00
10365797033	ROOM 001 - SINK	Water	09/30/16 02:33	10/12/16 10:00
10365797034	ROOM 004 - SINK	Water	09/30/16 02:34	10/12/16 10:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: O CSD - Fitzhugh Park Elem.

Pace Project No.: 10365797

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10365797035	ROOM 220C MIDDLE SINK	Water	09/30/16 01:55	10/12/16 10:00
10365797036	ROOM 210A - SLOP SINK	Water	09/30/16 01:52	10/12/16 10:00
10365797037	GANG BATH NEXTtoRM 114 - MIDDLE	Water	09/30/16 02:21	10/12/16 10:00
10365797038	RM013 - KITCHEN HAND WASH SINK	Water	09/30/16 02:25	10/12/16 10:00
10365797039	ROOM 002 - SINK	Water	09/30/16 02:36	10/12/16 10:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: O CSD - Fitzhugh Park Elem.
Pace Project No.: 10365797

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10365797001	ROOM 226 - SINK	EPA 200.8	TT3	1	PASI-M
10365797002	SLOP SINK OUTSIDE KILN ROOM	EPA 200.8	TT3	1	PASI-M
10365797003	ROOM 225 - NORTH SINK	EPA 200.8	TT3	1	PASI-M
10365797004	ROOM 225 - SOUTH SINK	EPA 200.8	TT3	1	PASI-M
10365797005	ROOM 220B - NORTH SINK	EPA 200.8	TT3	1	PASI-M
10365797006	ROOM 220A - SOUTH SINK	EPA 200.8	TT3	1	PASI-M
10365797007	ROOM 215 - SINK	EPA 200.8	TT3	1	PASI-M
10365797008	ROOM 210B - NORTH SINK	EPA 200.8	TT3	1	PASI-M
10365797009	ROOM 210A - SOUTH SINK	EPA 200.8	TT3	1	PASI-M
10365797010	GANG BATH NEXTtoRM 108 - SOUTH	EPA 200.8	TT3	1	PASI-M
10365797011	GANG BATH NEXTtoRM 108 - NORTH	EPA 200.8	TT3	1	PASI-M
10365797012	ROOM 110 - SINK	EPA 200.8	TT3	1	PASI-M
10365797013	ROOM 109 - SINK	EPA 200.8	TT3	1	PASI-M
10365797014	ROOM 112 - SINK	EPA 200.8	TT3	1	PASI-M
10365797015	ROOM 111 - SINK	EPA 200.8	TT3	1	PASI-M
10365797016	GANG BATH NEXTtoRM 114 - SOUTH	EPA 200.8	TT3	1	PASI-M
10365797017	GANG BATH NEXTtoRM 114 - NORTH	EPA 200.8	TT3	1	PASI-M
10365797018	ROOM 113 - SINK	EPA 200.8	TT3	1	PASI-M
10365797019	ROOM 117 - COACHES OFFICE SINK	EPA 200.8	TT3	1	PASI-M
10365797020	TUB RM SINK ACROSS GYM-RM 116C	EPA 200.8	TT3	1	PASI-M
10365797021	BOYS STAFF BATHRM SINK-1ST FLR	EPA 200.8	AJM	1	PASI-M
10365797022	GIRLS STAFF BATHRM -1ST FLR	EPA 200.8	WBS	1	PASI-M
10365797023	ROOM 120A - SINK	EPA 200.8	AJM	1	PASI-M
10365797024	ROOM 120 - SINK	EPA 200.8	AJM	1	PASI-M
10365797025	ROOM 014A - SLOP SINK	EPA 200.8	AJM	1	PASI-M
10365797026	ROOM 013A STAFF BATHROOMS	EPA 200.8	AJM	1	PASI-M
10365797027	GANG BATH NEXTtoRM 010 - NORTH	EPA 200.8	AJM	1	PASI-M
10365797028	GANG BATH NEXTtoRM 010 -MIDDLE	EPA 200.8	AJM	1	PASI-M
10365797029	GANG BATH NEXTtoRM 010 - SOUTH	EPA 200.8	AJM	1	PASI-M
10365797030	ROOM 007 - SINK	EPA 200.8	AJM	1	PASI-M
10365797031	ROOM 005 - SINK	EPA 200.8	AJM	1	PASI-M
10365797032	ROOM 003 - SINK	EPA 200.8	AJM	1	PASI-M
10365797033	ROOM 001 - SINK	EPA 200.8	AJM	1	PASI-M
10365797034	ROOM 004 - SINK	EPA 200.8	AJM	1	PASI-M
10365797035	ROOM 220C MIDDLE SINK	EPA 200.8	AJM	1	PASI-M
10365797036	ROOM 210A - SLOP SINK	EPA 200.8	AJM	1	PASI-M
10365797037	GANG BATH NEXTtoRM 114 -MIDDLE	EPA 200.8	WBS	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: O CSD - Fitzhugh Park Elem.

Pace Project No.: 10365797

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10365797038	RM013 - KITCHEN HAND WASH SINK	EPA 200.8	AJM	1	PASI-M
10365797039	ROOM 002 - SINK	EPA 200.8	AJM	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: O CSD - Fitzhugh Park Elem.

Pace Project No.: 10365797

Sample: ROOM 226 - SINK		Lab ID: 10365797001	Collected: 09/30/16 01:40	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	4.3	ug/L	0.10	1		10/16/16 12:42	7439-92-1	
------	-----	------	------	---	--	----------------	-----------	--

Sample: SLOP SINK OUTSIDE KILN ROOM		Lab ID: 10365797002	Collected: 09/30/16 01:41	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	6.8	ug/L	0.10	1		10/16/16 12:39	7439-92-1	
------	-----	------	------	---	--	----------------	-----------	--

Sample: ROOM 225 - NORTH SINK		Lab ID: 10365797003	Collected: 09/30/16 01:42	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	2.7	ug/L	0.10	1		10/16/16 12:40	7439-92-1	
------	-----	------	------	---	--	----------------	-----------	--

Sample: ROOM 225 - SOUTH SINK		Lab ID: 10365797004	Collected: 09/30/16 01:43	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	3.1	ug/L	0.10	1		10/16/16 12:51	7439-92-1	
------	-----	------	------	---	--	----------------	-----------	--

Sample: ROOM 220B - NORTH SINK		Lab ID: 10365797005	Collected: 09/30/16 01:45	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	2.6	ug/L	0.10	1		10/16/16 12:52	7439-92-1	
------	-----	------	------	---	--	----------------	-----------	--

Sample: ROOM 220A - SOUTH SINK		Lab ID: 10365797006	Collected: 09/30/16 01:45	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	5.0	ug/L	0.10	1		10/16/16 12:54	7439-92-1	
------	-----	------	------	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: O CSD - Fitzhugh Park Elem.

Pace Project No.: 10365797

Sample: ROOM 215 - SINK		Lab ID: 10365797007	Collected: 09/30/16 01:48	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	14.4	ug/L	0.10	1		10/16/16 12:55	7439-92-1	
Sample: ROOM 210B - NORTH SINK		Lab ID: 10365797008	Collected: 09/30/16 01:50	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.7	ug/L	0.10	1		10/16/16 12:57	7439-92-1	
Sample: ROOM 210A - SOUTH SINK		Lab ID: 10365797009	Collected: 09/30/16 01:50	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.2	ug/L	0.10	1		10/16/16 12:58	7439-92-1	
Sample: GANG BATH NEXTtoRM 108 - SOUTH		Lab ID: 10365797010	Collected: 09/30/16 02:16	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.6	ug/L	0.10	1		10/16/16 13:00	7439-92-1	
Sample: GANG BATH NEXTtoRM 108 - NORTH		Lab ID: 10365797011	Collected: 09/30/16 02:15	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.4	ug/L	0.10	1		10/16/16 13:02	7439-92-1	
Sample: ROOM 110 - SINK		Lab ID: 10365797012	Collected: 09/30/16 02:14	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	13.1	ug/L	0.10	1		10/16/16 13:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: O CSD - Fitzhugh Park Elem.

Pace Project No.: 10365797

Sample: ROOM 109 - SINK		Lab ID: 10365797013	Collected: 09/30/16 02:13	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	7.4	ug/L	0.10	1		10/16/16 13:10	7439-92-1	
Sample: ROOM 112 - SINK		Lab ID: 10365797014	Collected: 09/30/16 02:13	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.77	ug/L	0.10	1		10/16/16 13:12	7439-92-1	
Sample: ROOM 111 - SINK		Lab ID: 10365797015	Collected: 09/30/16 02:12	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.1	ug/L	0.10	1		10/16/16 13:14	7439-92-1	
Sample: GANG BATH NEXTtoRM 114 - SOUTH		Lab ID: 10365797016	Collected: 09/30/16 02:17	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.62	ug/L	0.10	1		10/16/16 13:15	7439-92-1	
Sample: GANG BATH NEXTtoRM 114 - NORTH		Lab ID: 10365797017	Collected: 09/30/16 02:11	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.9	ug/L	0.10	1		10/16/16 13:17	7439-92-1	
Sample: ROOM 113 - SINK		Lab ID: 10365797018	Collected: 09/30/16 02:10	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.96	ug/L	0.10	1		10/16/16 13:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: O CSD - Fitzhugh Park Elem.
Pace Project No.: 10365797

Sample: ROOM 117 - COACHES OFFICE SINK **Lab ID: 10365797019** Collected: 09/30/16 02:04 Received: 10/12/16 10:00 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	8.0	ug/L	0.10	1		10/16/16 13:20	7439-92-1	

Sample: TUB RM SINK ACROSS GYM-RM 116C **Lab ID: 10365797020** Collected: 09/30/16 02:00 Received: 10/12/16 10:00 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	3.4	ug/L	0.10	1		10/16/16 13:21	7439-92-1	

Sample: BOYS STAFF BATHRM SINK-1ST FLR **Lab ID: 10365797021** Collected: 09/30/16 02:02 Received: 10/12/16 10:00 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	1.4	ug/L	0.10	1		10/17/16 12:33	7439-92-1	

Sample: GIRLS STAFF BATHRM - 1ST FLR **Lab ID: 10365797022** Collected: 09/30/16 02:03 Received: 10/12/16 10:00 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	1.0	ug/L	0.10	1		10/18/16 11:40	7439-92-1	

Sample: ROOM 120A - SINK **Lab ID: 10365797023** Collected: 09/30/16 01:55 Received: 10/12/16 10:00 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	22.8	ug/L	0.10	1		10/17/16 12:38	7439-92-1	

Sample: ROOM 120 - SINK **Lab ID: 10365797024** Collected: 09/30/16 01:58 Received: 10/12/16 10:00 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	33.8	ug/L	0.10	1		10/17/16 12:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: O CSD - Fitzhugh Park Elem.
Pace Project No.: 10365797

Sample: ROOM 014A - SLOP SINK		Lab ID: 10365797025	Collected: 09/30/16 02:23	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.3	ug/L	0.10	1		10/17/16 12:40	7439-92-1	

Sample: ROOM 013A STAFF BATHROOMS		Lab ID: 10365797026	Collected: 09/30/16 02:24	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	5.7	ug/L	0.10	1		10/17/16 12:44	7439-92-1	

Sample: GANG BATH NEXTtoRM 010 - NORTH		Lab ID: 10365797027	Collected: 09/30/16 02:29	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	4.4	ug/L	0.10	1		10/17/16 12:45	7439-92-1	

Sample: GANG BATH NEXTtoRM 010 - MIDDLE		Lab ID: 10365797028	Collected: 09/30/16 02:28	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	3.0	ug/L	0.10	1		10/17/16 12:46	7439-92-1	

Sample: GANG BATH NEXTtoRM 010 - SOUTH		Lab ID: 10365797029	Collected: 09/30/16 02:28	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	5.6	ug/L	0.10	1		10/17/16 12:47	7439-92-1	

Sample: ROOM 007 - SINK		Lab ID: 10365797030	Collected: 09/30/16 02:38	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	6.1	ug/L	0.10	1		10/17/16 12:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: O CSD - Fitzhugh Park Elem.

Pace Project No.: 10365797

Sample: ROOM 005 - SINK		Lab ID: 10365797031	Collected: 09/30/16 02:30	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	13.3	ug/L	0.10	1		10/17/16 12:49	7439-92-1	
Sample: ROOM 003 - SINK		Lab ID: 10365797032	Collected: 09/30/16 02:31	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	22.7	ug/L	0.10	1		10/17/16 12:51	7439-92-1	
Sample: ROOM 001 - SINK		Lab ID: 10365797033	Collected: 09/30/16 02:33	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.0	ug/L	0.10	1		10/17/16 12:52	7439-92-1	
Sample: ROOM 004 - SINK		Lab ID: 10365797034	Collected: 09/30/16 02:34	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	5.3	ug/L	0.10	1		10/17/16 12:53	7439-92-1	
Sample: ROOM 220C MIDDLE SINK		Lab ID: 10365797035	Collected: 09/30/16 01:55	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	8.3	ug/L	0.10	1		10/17/16 12:57	7439-92-1	
Sample: ROOM 210A - SLOP SINK		Lab ID: 10365797036	Collected: 09/30/16 01:52	Received: 10/12/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	13.1	ug/L	0.10	1		10/17/16 12:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: O CSD - Fitzhugh Park Elem.

Pace Project No.: 10365797

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: GANG BATH NEXTtoRM 114 -MIDDLE

Lab ID: 10365797037 Collected: 09/30/16 02:21 Received: 10/12/16 10:00 Matrix: Water

200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	1.1	ug/L	0.10	1		10/18/16 11:41	7439-92-1	

Sample: RM013 - KITCHEN HAND WASH SINK

Lab ID: 10365797038 Collected: 09/30/16 02:25 Received: 10/12/16 10:00 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

200.8 MET ICPMS, DW

Analytical Method: EPA 200.8

Lead	3.3	ug/L	0.10	1		10/17/16 13:00	7439-92-1	
------	-----	------	------	---	--	----------------	-----------	--

Sample: ROOM 002 - SINK

Lab ID: 10365797039 Collected: 09/30/16 02:36 Received: 10/12/16 10:00 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

200.8 MET ICPMS, DW

Analytical Method: EPA 200.8

Lead	2.1	ug/L	0.10	1		10/17/16 13:01	7439-92-1	
------	-----	------	------	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: O CSD - Fitzhugh Park Elem.

Pace Project No.: 10365797

QC Batch: 440816 Analysis Method: EPA 200.8
 QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
 Associated Lab Samples: 10365797001, 10365797002, 10365797003, 10365797004, 10365797005, 10365797006, 10365797007, 10365797008, 10365797009, 10365797010, 10365797011, 10365797012, 10365797013, 10365797014, 10365797015, 10365797016, 10365797017, 10365797018, 10365797019, 10365797020

METHOD BLANK: 2398278 Matrix: Water
 Associated Lab Samples: 10365797001, 10365797002, 10365797003, 10365797004, 10365797005, 10365797006, 10365797007, 10365797008, 10365797009, 10365797010, 10365797011, 10365797012, 10365797013, 10365797014, 10365797015, 10365797016, 10365797017, 10365797018, 10365797019, 10365797020

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/16/16 12:33	

LABORATORY CONTROL SAMPLE: 2398279

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	101	101	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2402646 2402647

Parameter	Units	10365797001 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	4.3	100	100	99.7	102	95	97	70-130	2	20	

MATRIX SPIKE SAMPLE: 2402648

Parameter	Units	10365797011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.4	100	97.5	96	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: O CSD - Fitzhugh Park Elem.

Pace Project No.: 10365797

QC Batch: 440817 Analysis Method: EPA 200.8
 QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
 Associated Lab Samples: 10365797021, 10365797022, 10365797023, 10365797024, 10365797025, 10365797026, 10365797027, 10365797028, 10365797029, 10365797030, 10365797031, 10365797032, 10365797033, 10365797034, 10365797035, 10365797036, 10365797037, 10365797038, 10365797039

METHOD BLANK: 2398281 Matrix: Water
 Associated Lab Samples: 10365797021, 10365797022, 10365797023, 10365797024, 10365797025, 10365797026, 10365797027, 10365797028, 10365797029, 10365797030, 10365797031, 10365797032, 10365797033, 10365797034, 10365797035, 10365797036, 10365797037, 10365797038, 10365797039

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/18/16 11:39	

LABORATORY CONTROL SAMPLE: 2398282

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	96.8	97	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2402992 2402993

Parameter	Units	10365797021 Result	MS		MSD		MS		MSD		% Rec Limits	RPD	Max RPD	Qual
			Spike Conc.	Spike Conc.	Result	Result	% Rec	% Rec						
Lead	ug/L	1.4	100	100	99.9	101	99	99	70-130	1	20			

MATRIX SPIKE SAMPLE: 2402994

Parameter	Units	10365797031 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	13.3	100	107	94	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: O CSD - Fitzhugh Park Elem.

Pace Project No.: 10365797

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

LABORATORIES

PASI-M Pace Analytical Services - Minneapolis

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: O CSD - Fitzhugh Park Elem.
Pace Project No.: 10365797

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10365797001	ROOM 226 - SINK	EPA 200.8	440816		
10365797002	SLOP SINK OUTSIDE KILN ROOM	EPA 200.8	440816		
10365797003	ROOM 225 - NORTH SINK	EPA 200.8	440816		
10365797004	ROOM 225 - SOUTH SINK	EPA 200.8	440816		
10365797005	ROOM 220B - NORTH SINK	EPA 200.8	440816		
10365797006	ROOM 220A - SOUTH SINK	EPA 200.8	440816		
10365797007	ROOM 215 - SINK	EPA 200.8	440816		
10365797008	ROOM 210B - NORTH SINK	EPA 200.8	440816		
10365797009	ROOM 210A - SOUTH SINK	EPA 200.8	440816		
10365797010	GANG BATH NEXTtoRM 108 - SOUTH	EPA 200.8	440816		
10365797011	GANG BATH NEXTtoRM 108 - NORTH	EPA 200.8	440816		
10365797012	ROOM 110 - SINK	EPA 200.8	440816		
10365797013	ROOM 109 - SINK	EPA 200.8	440816		
10365797014	ROOM 112 - SINK	EPA 200.8	440816		
10365797015	ROOM 111 - SINK	EPA 200.8	440816		
10365797016	GANG BATH NEXTtoRM 114 - SOUTH	EPA 200.8	440816		
10365797017	GANG BATH NEXTtoRM 114 - NORTH	EPA 200.8	440816		
10365797018	ROOM 113 - SINK	EPA 200.8	440816		
10365797019	ROOM 117 - COACHES OFFICE SINK	EPA 200.8	440816		
10365797020	TUB RM SINK ACROSS GYM-RM 116C	EPA 200.8	440816		
10365797021	BOYS STAFF BATHRM SINK-1ST FLR	EPA 200.8	440817		
10365797022	GIRLS STAFF BATHRM -1ST FLR	EPA 200.8	440817		
10365797023	ROOM 120A - SINK	EPA 200.8	440817		
10365797024	ROOM 120 - SINK	EPA 200.8	440817		
10365797025	ROOM 014A - SLOP SINK	EPA 200.8	440817		
10365797026	ROOM 013A STAFF BATHROOMS	EPA 200.8	440817		
10365797027	GANG BATH NEXTtoRM 010 - NORTH	EPA 200.8	440817		
10365797028	GANG BATH NEXTtoRM 010 - MIDDLE	EPA 200.8	440817		
10365797029	GANG BATH NEXTtoRM 010 - SOUTH	EPA 200.8	440817		
10365797030	ROOM 007 - SINK	EPA 200.8	440817		
10365797031	ROOM 005 - SINK	EPA 200.8	440817		
10365797032	ROOM 003 - SINK	EPA 200.8	440817		
10365797033	ROOM 001 - SINK	EPA 200.8	440817		
10365797034	ROOM 004 - SINK	EPA 200.8	440817		
10365797035	ROOM 220C MIDDLE SINK	EPA 200.8	440817		
10365797036	ROOM 210A - SLOP SINK	EPA 200.8	440817		
10365797037	GANG BATH NEXTtoRM 114 - MIDDLE	EPA 200.8	440817		
10365797038	RM013 - KITCHEN HAND WASH SINK	EPA 200.8	440817		
10365797039	ROOM 002 - SINK	EPA 200.8	440817		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

10365797



Section A
Required Client Information:

Company: Oswego CSD
Address: 225 West Utica St
Oswego, NY 12126

E-mail To: dc@pacelabs.com
Phone: _____
Fax: _____

Requested Due Date/TAT: _____

Section B
Required Project Information:

Report To: _____
Copy To: _____

Purchase Order No.: _____
Project Name: Fitzhugh Park Elem.
Project Manager: _____
Project Number: _____

Section C
Invoice Information:

Attention: _____
Company Name: _____
Address: _____
Pace Quote Reference: _____
Pace Project Manager: _____
Pace Profile #: _____

REGULATORY AGENCY

NPDES GROUND WATER DRINKING WATER

UST RCRA OTHER _____

SITE LOCATION

GA IL IN MI NC
 OH SC WI OTHER NY

ITEM #	Section D Required Client Information	Valid Matrix Codes	MATRIX	CODE	SAMPLE TYPE	COLLECTED		# OF CONTAINERS	PRESERVATIVES						Filtered (Y/N)	Requested Analyte	Pace Project No. Lab ID.
						COMPOSITE START	COMPOSITE END/START		Unpreserved	H2SO4	HNO3	HCl	NaOH	Na2S2O8			
1	ROOM 226 - SINK	DW	DW	G	DW	DATE	TIME	1								X	001
2	SLOP SINK OUTSIDE KILN ROOM	DW	DW	G	DW	DATE	TIME	1								X	002
3	ROOM 225 - NORTH SINK	DW	DW	G	DW	DATE	TIME	1								X	003
4	ROOM 225 - SOUTH SINK	DW	DW	G	DW	DATE	TIME	1								X	004
5	ROOM 220B-NORTH SINK	DW	DW	G	DW	DATE	TIME	1								X	005
6	ROOM 220A- SOUTH SINK	DW	DW	G	DW	DATE	TIME	1								X	006
7	ROOM 215 - SINK	DW	DW	G	DW	DATE	TIME	1								X	007
8	ROOM 210B - NORTH SINK	DW	DW	G	DW	DATE	TIME	1								X	008
9	ROOM 210A - SOUTH SINK	DW	DW	G	DW	DATE	TIME	1								X	009
10	SLOP SINK OUTSIDE KILN ENTRANCE	DW	DW	G	DW	DATE	TIME	1								X	010
11	GANG BATH NEXT TO ROOM 108 - SOUTH SINK	DW	DW	G	DW	DATE	TIME	1								X	011
12	GANG BATH NEXT TO ROOM 108 - NORTH SINK	DW	DW	G	DW	DATE	TIME	1								X	011

ADDITIONAL COMMENTS

James Murphy PACE
10/16/16 18:30
10/16/16 10:00
EYL PACE

ACCEPTED BY / AFFILIATION _____

DATE 10/16/16

TIME 18:30

RELINQUISHED BY / AFFILIATION James Murphy PACE

DATE 10/16/16

TIME 18:30

RECEIVED ON _____

DATE _____

TIME _____

TEMP IN °C _____

RECEIVED ON _____

DATE _____

TIME _____

TEMP IN °C _____

RECEIVED ON _____

DATE _____

TIME _____

TEMP IN °C _____

SAMPLER NAME AND SIGNATURE

James Murphy - PACE Analytical
James Murphy

DATE SIGNED 9/30/16

CHAIN-OF-CUSTODY / Analytical Request Document
The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

10365797

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: Oswego CSD		Report To:		Attention:	
Address: 225 West Ulica St Oswego, NY 12126		Copy To:		Company Name:	
Email To: dcrisafu@oswego.org		Purchase Order No.:		Address:	
Phone: Fax:		Project Name: Fitzhugh Park Elem.		Pace Quote Reference:	
Requested Due Date/TAT:		Project Number:		Pace Project Manager:	
Requested Due Date/TAT:		Project Profile #:		Pace Project No. Lab I.D.	

ITEM #	Section D Required Client Information	Valid Matrix Codes	MATRIX CODE	SAMPLE TYPE	COLLECTED		# OF CONTAINERS	PRESERVATIVES	Requested Analyte	Filtered (Y/N)	SITE LOCATION	REGULATORY AGENCY	SAMPLE CONDITIONS			
					COMPOSITE START DATE TIME	COMPOSITE END/GRAB DATE TIME							Temp in °C	Received on Ice	Custody Sealed	Samples Intact
1	ROOM 110 - SINK	DW	DW	G	9/30	2:14	1	Unpreserved	X		GA	NPDES	128	Y/N	Y/N	Y/N
2	ROOM 109 - SINK	DW	DW	G	2:13		1	Unpreserved	X		GA	NPDES	10/2/16	Y/N	Y/N	Y/N
3	ROOM 112 - SINK	DW	DW	G	2:13		1	Unpreserved	X		GA	NPDES	10/2/16	Y/N	Y/N	Y/N
4	ROOM 111 - SINK	DW	DW	G	2:17		1	Unpreserved	X		GA	NPDES	10/2/16	Y/N	Y/N	Y/N
5	GANG BATH NEXT TO RM 114 - SOUTH SINK	DW	DW	G	2:11		1	Unpreserved	X		GA	NPDES	10/2/16	Y/N	Y/N	Y/N
6	GANG BATH NEXT TO RM 114 - NORTH SINK	DW	DW	G	2:10		1	Unpreserved	X		GA	NPDES	10/2/16	Y/N	Y/N	Y/N
7	ROOM 113 - SINK	DW	DW	G	2:04		1	Unpreserved	X		GA	NPDES	10/2/16	Y/N	Y/N	Y/N
8	ROOM 113 - NORTH SINK	DW	DW	G	2:04		1	Unpreserved	X		GA	NPDES	10/2/16	Y/N	Y/N	Y/N
9	ROOM 117 - COACHES OFFICE SINK	DW	DW	G	2:04		1	Unpreserved	X		GA	NPDES	10/2/16	Y/N	Y/N	Y/N
10	TUB RM SINK ACROSS FROM GYM-RM 116C	DW	DW	G	2:00		1	Unpreserved	X		GA	NPDES	10/2/16	Y/N	Y/N	Y/N
11	BOYS STAFF BATHROOM SINK-1ST FLOOR	DW	DW	G	2:02		1	Unpreserved	X		GA	NPDES	10/2/16	Y/N	Y/N	Y/N
12	GIRLS STAFF BATHROOM - 1ST FLOOR	DW	DW	G	2:03		1	Unpreserved	X		GA	NPDES	10/2/16	Y/N	Y/N	Y/N

RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME
JAM/Myly	10/16/16	18:30	EY/Grace	10/2/16	1000

ADDITIONAL COMMENTS		RELINQUISHED BY / AFFILIATION		DATE		TIME		ACCEPTED BY / AFFILIATION		DATE		TIME	
		JAM/Myly		10/16/16		18:30		EY/Grace		10/2/16		1000	

SAMPLER NAME AND SIGNATURE		DATE Signed (MM / DD / YY):	
James Murphy - PACE Analytical		9/30/16	
PRINT Name of SAMPLER:		DATE Signed (MM / DD / YY):	
James Murphy - PACE Analytical		9/30/16	
SIGNATURE of SAMPLER:		DATE Signed (MM / DD / YY):	
<i>JAM/Myly</i>		9/30/16	

10365797 u

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



Section A Required Client Information: Company: Oswego CSD Address: 225 West Ulica St Oswego, NY 12126 Email To: dorisafu@oswego.org Phone: _____ Fax: _____		Section B Required Project Information: Report To: _____ Copy To: _____ Purchase Order No.: _____ Project Name: Fitzhugh Park Elem. Project Number: _____		Section C Invoice Information: Attention: _____ Company Name: _____ Address: _____ Pace Quote Reference: _____ Pace Project Manager: _____ Pace Profile #: _____								
REGULATORY AGENCY <input type="checkbox"/> NPDES <input type="checkbox"/> GROUND WATER <input checked="" type="checkbox"/> DRINKING WATER <input type="checkbox"/> UST <input type="checkbox"/> RCRA <input type="checkbox"/> OTHER _____		SITE LOCATION <input type="checkbox"/> GA <input type="checkbox"/> IL <input type="checkbox"/> IN <input type="checkbox"/> MI <input type="checkbox"/> NC <input type="checkbox"/> OH <input type="checkbox"/> SC <input type="checkbox"/> WI <input type="checkbox"/> OTHER_NY _____		Filtered (Y/N) _____ Requested _____ Ant _____ Pace Project No. Lab ID.								
ITEM #	Valid Matrix Codes MATRIX DRINKING WATER WATER WATER PRODUCT SOIL/SLURRY DUST AIR OTHER TISSUE	CODE	MATRIX CODE	COLLECTED		# OF CONTAINERS	PRESERVATIVES		Requested	Ant	Pace Project No. Lab ID.	
				COMPOSITE START	COMPOSITE END/GRAB		Unpreserved	H ₂ SO ₄				HNO ₃
1	ROOM 120A - SINK	DW	G	9/30	1:55	1						023
2	ROOM 120 - SINK	DW	G		1:56	1						024
3	ROOM 014A - SLOP SINK	DW	G		2:23	1						025
4	ROOM 013A STAFF BATHROOMS	DW	G		2:24	1						026
5	GANG BATH NEXT TO RM 010 - NORTH SINK	DW	G		2:29	1						027
6	GANG BATH NEXT TO RM 010 - MIDDLE SINK	DW	G		2:28	1						028
7	GANG BATH NEXT TO RM 010 - SOUTH SINK	DW	G		2:28	1						029
8	ROOM 007 - SINK	DW	G		2:36	1						030
9	ROOM 005 - SINK	DW	G		2:30	1						031
10	ROOM 003 - SINK	DW	G		2:31	1						032
11	ROOM 001 SINK	DW	G		2:33	1						033
12	ROOM 004 - SINK	DW	G		2:34	1						034

ADDITIONAL COMMENTS
 Relinquished by Affiliation: James Murphy - PACE
 Date: 10/16/16
 Time: 18:30
 Accepted by Affiliation: PACE
 Date: 10/16/16
 Time: 18:00
 Sample Conditions: 17.8, 18.2

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: James Murphy - PACE Analytical
 SIGNATURE of SAMPLER: *James Murphy*
 DATE Signed (MM/DD/YY): 9/30/16

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



Page: 4 of 4	
Section A Required Client Information: Company: Oswego CSD Address: 225 West Ulica St Oswego, NY 12126 Email To: dorisafu@oswego.org Phone: _____ Requested Due Date/TAT: _____	Section B Required Project Information: Report To: _____ Copy To: _____ Purchase Order No.: _____ Project Name: Fitzhugh Park Elem. Project Number: _____
Section C	
Invoice Information: Attention: _____ Company Name: _____ Address: _____ Pace Quote Reference: _____ Pace Project Manager: _____ Pace Profile #: _____	
REGULATORY AGENCY	
<input type="checkbox"/> NPDES <input type="checkbox"/> GROUND WATER <input checked="" type="checkbox"/> DRINKING WATER <input type="checkbox"/> UST <input type="checkbox"/> RCRA <input type="checkbox"/> OTHER _____	
SITE	
<input type="checkbox"/> GA <input type="checkbox"/> IL <input type="checkbox"/> IN <input type="checkbox"/> MI <input type="checkbox"/> NC <input type="checkbox"/> OH <input type="checkbox"/> SC <input type="checkbox"/> WI <input type="checkbox"/> OTHER_NY _____	
LOCATION	
Filtered (Y/N) _____	
Requested Ante _____	
Preservatives: H ₂ SO ₄ , HNO ₃ , HCl, NaOH, Na ₂ S ₂ O ₃ , Methanol, Na ₂ SO ₄	
# OF CONTAINERS _____	
SAMPLE TEMP AT COLLECTION _____	
COLLECTED	
COMPOSITE START	COMPOSITE END/GRAB
DATE	TIME
MATRIX CODE SAMPLE TYPE G-RAB C-COMP PRESERVED BY / AFFILIATION DATE TIME ACCEPTED BY / AFFILIATION DATE TIME SAMPLE CONDITIONS	
Valid Matrix Codes: DW, WT, P, SL, OL, AR, OT, TS, URINO/WATER, WASTE WATER, SOLE/SOLID, OIL, AIR, OTHER TISSUE	
Section D Required Client Information SAMPLE ID (A-Z, 0-9 / .)	
Sample IDs MUST BE UNIQUE	
#	ITEM
1	ROOM 220C - MIDDLE SINK
2	ROOM 210A - SLOP SINK
3	GANG BATH NEXT TO RM 114 - MIDDLE SINK
4	ROOM 013- KITCHEN HAND WASH SINK
5	ROOM 002 - SINK
6	
7	
8	
9	
10	
11	
12	
ADDITIONAL COMMENTS: <i>James PACE 10/16/16 18:30</i>	
RELINQUISHED BY / AFFILIATION: <i>James PACE</i> DATE: <i>10/16/16</i> TIME: <i>18:30</i> ACCEPTED BY / AFFILIATION: <i>ETC</i> DATE: <i>10/26/16</i> TIME: <i>1000</i>	
Temp in °C: _____ Received on Ice: _____ Custody Sealed: _____ Samples Intact: _____	
PACE PROJECT NO. LAB I.D.: <i>035, 036, 037, 038, 039</i>	
SAMPLER NAME AND SIGNATURE: _____ PRINT Name of SAMPLER: James Murphy - PACE Analytical SIGNATURE of SAMPLER: <i>James Murphy</i> DATE Signed (MM / DD / YY): <i>9/23/16</i>	



Document Name:
Sample Condition Upon Receipt Form

Document No.:
F-MN-L-213-rev.17

Document Revised: 02Aug2016
Page 1 of 2

Issuing Authority:
Pace Minnesota Quality Office

Sample Condition Upon Receipt

Client Name:

Project #:

Oswego CSD

WO# : 10365797



10365797

Courier: Fed Ex UPS USPS Client

Commercial Pace Speedee Other:

Tracking Number: 7774 4446 3587, 2640

Custody Seal on Cooler/Box Present? Yes No Seals Intact? Yes No

Optional: Proj. Due Date: Proj. Name:

Packing Material: Bubble Wrap Bubble Bags None Other: Temp Blank? Yes No

Thermometer 151401163 B88A912167504 Type of Ice: Wet Blue None Samples on ice, cooling process has begun
Used: 151401164 B88A0143310098

Cooler Temp Read (°C): 17.6, 18.0 Cooler Temp Corrected (°C): 17.8, 18.2 Biological Tissue Frozen? Yes No N/A
Temp should be above freezing to 6°C Correction Factor: +0.2 Date and Initials of Person Examining Contents: EW 10/12/16

USDA Regulated Soil N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, AZ, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX or VA (check maps)? Yes No Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-MN-Q-338) and include with SCUR/COC paperwork.

	COMMENTS:
Chain of Custody Present? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	1.
Chain of Custody Filled Out? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	2.
Chain of Custody Relinquished? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	3.
Sampler Name and/or Signature on COC? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	5.
Short Hold Time Analysis (<72 hr)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	6.
Rush Turn Around Time Requested? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	7.
Sufficient Volume? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	8.
Correct Containers Used? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	9.
-Pace Containers Used? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Containers Intact? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	10.
Filtered Volume Received for Dissolved Tests? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container
Sample Labels Match COC? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	12.
-Includes Date/Time/ID/Analysis Matrix: <u>WT</u>	
All containers needing acid/base preservation have been checked? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input checked="" type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO ₃ , H ₂ SO ₄ , HCl<2; NaOH >9 Sulfide, NaOH>12 Cyanide) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Sample # <u>1-91</u>
Exceptions: VOA, Coliform, TOC, Oil and Grease, DRO/8015 (water) DOC <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Initial when completed: Lot # of added preservative:
Headspace in VOA Vials (>6mm)? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14.
Trip Blank Present? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Trip Blank Custody Seals Present? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if purchased):	

CLIENT NOTIFICATION/RESOLUTION

Field Data Required? Yes No

Person Contacted: _____

Date/Time: _____

Comments/Resolution: _____

Project Manager Review: Awanda J. Albrecht

Date: 10/14/16

Note: Whenever there is a discrepancy affecting North Carolina compliance samples, a copy of this form will be sent to the North Carolina DEHNR Certification Office (i.e. out of hold, incorrect preservative, out of temp, incorrect containers).