

October 20, 2016

David Crisafulli  
Oswego CSD  
225 West Utica St  
Oswego, NY 12126

RE: Project: O CSD - Minetto Elementary  
Pace Project No.: 10365814

Dear David Crisafulli:

Enclosed are the analytical results for sample(s) received by the laboratory on October 11, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

Samples, in the electronic data deliverable (EDD) that accompanied this report, were flagged yellow if they exceeded the NYSDOH 15 ppb action level.

The space designated for the sampler on the chain of custody (COC) indicates if these samples were collected by Pace Analytical or were collected by the school district and just relinquished to Pace Analytical.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Amanda Albrecht  
amanda.albrecht@pacelabs.com  
Project Manager

Enclosures



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## CERTIFICATIONS

Project: O CSD - Minetto Elementary

Pace Project No.: 10365814

---

### Minnesota Certification IDs

1700 Elm Street SE Suite 200, Minneapolis, MN 55414

Alaska Certification UST-107

525 N 8th Street, Salina, KS 67401

A2LA Certification #: 2926.01

Alaska Certification #: UST-078

Alaska Certification #MN00064

Alabama Certification #40770

Arizona Certification #: AZ-0014

Arkansas Certification #: 88-0680

California Certification #: 01155CA

Colorado Certification #Pace

Connecticut Certification #: PH-0256

EPA Region 8 Certification #: 8TMS-L

Florida/NELAP Certification #: E87605

Guam Certification #:14-008r

Georgia Certification #: 959

Georgia EPD #: Pace

Idaho Certification #: MN00064

Hawaii Certification #MN00064

Illinois Certification #: 200011

Indiana Certification#C-MN-01

Iowa Certification #: 368

Kansas Certification #: E-10167

Kentucky Dept of Envi. Protection - DW #90062

Kentucky Dept of Envi. Protection - WW #:90062

Louisiana DEQ Certification #: 3086

Louisiana DHH #: LA140001

Maine Certification #: 2013011

Maryland Certification #: 322

Michigan DEPH Certification #: 9909

Minnesota Certification #: 027-053-137

Mississippi Certification #: Pace

Montana Certification #: MT0092

Nevada Certification #: MN\_00064

Nebraska Certification #: Pace

New Jersey Certification #: MN-002

New York Certification #: 11647

North Carolina Certification #: 530

North Carolina State Public Health #: 27700

North Dakota Certification #: R-036

Ohio EPA #: 4150

Ohio VAP Certification #: CL101

Oklahoma Certification #: 9507

Oregon Certification #: MN200001

Oregon Certification #: MN300001

Pennsylvania Certification #: 68-00563

Puerto Rico Certification

Saipan (CNMI) #:MP0003

South Carolina #:74003001

Texas Certification #: T104704192

Tennessee Certification #: 02818

Utah Certification #: MN000642013-4

Virginia DGS Certification #: 251

Virginia/VELAP Certification #: Pace

Washington Certification #: C486

West Virginia Certification #: 382

West Virginia DHHR #:9952C

Wisconsin Certification #: 999407970

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### SAMPLE SUMMARY

Project: O CSD - Minetto Elementary

Pace Project No.: 10365814

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10365814001	ROOM 142-RECEIVING-SLOP SINK	Water	09/29/16 23:00	10/11/16 18:30
10365814002	RM 141-HAND WASH STATION SOUTH	Water	09/29/16 23:00	10/11/16 18:30
10365814003	RM 141-HAND WASH STATION NORTH	Water	09/29/16 23:01	10/11/16 18:30
10365814004	ROOM 141-BATHROOM SINK	Water	09/29/16 23:02	10/11/16 18:30
10365814005	ROOM 140-SINK-NORTH	Water	09/29/16 23:04	10/11/16 18:30
10365814006	BATHRM ACROSS BOILER RM SINK	Water	09/29/16 23:05	10/11/16 18:30
10365814007	ROOM 107A-FOUNTAIN	Water	09/29/16 23:09	10/11/16 18:30
10365814008	ROOM 107A-SINK	Water	09/29/16 23:08	10/11/16 18:30
10365814009	ROOM 109-SINK	Water	09/29/16 23:09	10/11/16 18:30
10365814010	ROOM 117-SINK	Water	09/29/16 23:09	10/11/16 18:30
10365814011	ROOM 111-FOUNTAIN ELKAY-NORTH	Water	09/29/16 23:11	10/11/16 18:30
10365814012	ROOM 116-SINK	Water	09/29/16 23:12	10/11/16 18:30
10365814013	ROOM 126-SINK	Water	09/29/16 23:14	10/11/16 18:30
10365814014	ROOM 128-SINK	Water	09/29/16 23:14	10/11/16 18:30
10365814015	ROOM 119-SINK	Water	09/29/16 23:17	10/11/16 18:30
10365814016	ROOM 123-SINK	Water	09/29/16 23:18	10/11/16 18:30
10365814017	ROOM 130-SINK	Water	09/29/16 23:20	10/11/16 18:30
10365814018	ROOM 222-SINK	Water	09/29/16 23:29	10/11/16 18:30
10365814019	ROOM 220-SINK	Water	09/29/16 23:30	10/11/16 18:30
10365814020	ROOM 218-SINK	Water	09/29/16 23:31	10/11/16 18:30
10365814021	ROOM 216-SINK	Water	09/29/16 23:31	10/11/16 18:30
10365814022	ROOM 214-SINK	Water	09/29/16 23:32	10/11/16 18:30
10365814023	ROOM 212-SINK	Water	09/29/16 23:33	10/11/16 18:30
10365814024	ROOM 211-SLOP SINK	Water	09/29/16 23:35	10/11/16 18:30
10365814025	BOYS GANG BATH.NEXT RM211 EAST	Water	09/29/16 23:36	10/11/16 18:30
10365814026	BOYS GANG BATH.NEXT RM211 WEST	Water	09/29/16 23:37	10/11/16 18:30
10365814027	GIRL GANG BATH.NEXT RM205 EAST	Water	09/29/16 23:37	10/11/16 18:30
10365814028	GIRL GANG BATH.NEXT RM205 WEST	Water	09/29/16 23:38	10/11/16 18:30
10365814029	ROOM 208-SINK	Water	09/29/16 23:39	10/11/16 18:30
10365814030	ROOM 206-SINK	Water	09/29/16 23:40	10/11/16 18:30
10365814031	ROOM 205-SINK	Water	09/29/16 23:40	10/11/16 18:30
10365814032	ROOM 204 -SINK	Water	09/29/16 23:41	10/11/16 18:30
10365814033	ROOM 203-SINK	Water	09/29/16 23:41	10/11/16 18:30
10365814034	ROOM 202-SINK	Water	09/29/16 23:43	10/11/16 18:30
10365814035	ROOM 201-SINK	Water	09/29/16 23:43	10/11/16 18:30

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## SAMPLE SUMMARY

Project: O CSD - Minetto Elementary  
Pace Project No.: 10365814

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10365814036	GANG BATH NEXT TO 226-NORTH	Water	09/29/16 23:25	10/11/16 18:30
10365814037	GANG BATH NEXT TO 226-MIDDLE	Water	09/29/16 23:46	10/11/16 18:30
10365814038	GANG BATH NEXT TO 226-SOUTH	Water	09/29/16 23:26	10/11/16 18:30
10365814039	ROOM 230-SINK	Water	09/29/16 23:47	10/11/16 18:30
10365814040	ROOM 231-SINK	Water	09/29/16 23:47	10/11/16 18:30
10365814041	ROOM 232-SINK	Water	09/29/16 23:49	10/11/16 18:30
10365814042	ROOM 234-SINK	Water	09/29/16 23:50	10/11/16 18:30
10365814043	ROOM 235-SINK	Water	09/29/16 23:52	10/11/16 18:30
10365814044	ROOM 237-SINK-NORTH	Water	09/29/16 23:56	10/11/16 18:30
10365814045	ROOM 238-SINK	Water	09/29/16 23:58	10/11/16 18:30
10365814046	ROOM 140-SINK	Water	09/29/16 23:04	10/11/16 18:30
10365814047	ROOM 126-BATH.SINK	Water	09/29/16 23:15	10/11/16 18:30
10365814048	ROOM 128-BATH. SINK	Water	09/29/16 23:16	10/11/16 18:30
10365814049	ROOM 130-BATH SINK	Water	09/29/16 23:20	10/11/16 18:30
10365814050	ROOM 237-SINK-SOUTH	Water	09/29/16 23:56	10/11/16 18:30
10365814051	CAFE GANG BATH. GIRLS SINK	Water	09/30/16 00:00	10/11/16 18:30
10365814052	CAFE GANG BATH. BOYS SINK	Water	09/30/16 00:00	10/11/16 18:30
10365814053	ROOM 149-SLOP SINK	Water	09/30/16 00:01	10/11/16 18:30
10365814054	BOYS GANG BATH.NEXT 124 EAST	Water	09/30/16 00:05	10/11/16 18:30
10365814055	BOYS GANG BATH.NEXT 124 WEST	Water	09/30/16 00:05	10/11/16 18:30
10365814056	GIRLS GANG BATH.NEXT 124 EAST	Water	09/30/16 00:07	10/11/16 18:30
10365814057	GIRLS GANG BATH.NEXT 124 WEST	Water	09/30/16 00:07	10/11/16 18:30

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### SAMPLE ANALYTE COUNT

Project: O CSD - Minetto Elementary  
Pace Project No.: 10365814

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10365814001	ROOM 142-RECEIVING-SLOP SINK	EPA 200.8	TT3	1	PASI-M
10365814002	RM 141-HAND WASH STATION SOUTH	EPA 200.8	TT3	1	PASI-M
10365814003	RM 141-HAND WASH STATION NORTH	EPA 200.8	TT3	1	PASI-M
10365814004	ROOM 141-BATHROOM SINK	EPA 200.8	TT3	1	PASI-M
10365814005	ROOM 140-SINK-NORTH	EPA 200.8	TT3	1	PASI-M
10365814006	BATHRM ACROSS BOILER RM SINK	EPA 200.8	TT3	1	PASI-M
10365814007	ROOM 107A-FOUNTAIN	EPA 200.8	TT3	1	PASI-M
10365814008	ROOM 107A-SINK	EPA 200.8	TT3	1	PASI-M
10365814009	ROOM 109-SINK	EPA 200.8	TT3	1	PASI-M
10365814010	ROOM 117-SINK	EPA 200.8	TT3	1	PASI-M
10365814011	ROOM 111-FOUNTAIN ELKAY-NORTH	EPA 200.8	TT3	1	PASI-M
10365814012	ROOM 116-SINK	EPA 200.8	TT3	1	PASI-M
10365814013	ROOM 126-SINK	EPA 200.8	TT3	1	PASI-M
10365814014	ROOM 128-SINK	EPA 200.8	TT3	1	PASI-M
10365814015	ROOM 119-SINK	EPA 200.8	TT3	1	PASI-M
10365814016	ROOM 123-SINK	EPA 200.8	TT3	1	PASI-M
10365814017	ROOM 130-SINK	EPA 200.8	TT3	1	PASI-M
10365814018	ROOM 222-SINK	EPA 200.8	TT3	1	PASI-M
10365814019	ROOM 220-SINK	EPA 200.8	TT3	1	PASI-M
10365814020	ROOM 218-SINK	EPA 200.8	TT3	1	PASI-M
10365814021	ROOM 216-SINK	EPA 200.8	AJM	1	PASI-M
10365814022	ROOM 214-SINK	EPA 200.8	AJM	1	PASI-M
10365814023	ROOM 212-SINK	EPA 200.8	AJM	1	PASI-M
10365814024	ROOM 211-SLOP SINK	EPA 200.8	AJM	1	PASI-M
10365814025	BOYS GANG BATH.NEXT RM211 EAST	EPA 200.8	AJM	1	PASI-M
10365814026	BOYS GANG BATH.NEXT RM211 WEST	EPA 200.8	AJM	1	PASI-M
10365814027	GIRL GANG BATH.NEXT RM205 EAST	EPA 200.8	AJM	1	PASI-M
10365814028	GIRL GANG BATH.NEXT RM205 WEST	EPA 200.8	AJM	1	PASI-M
10365814029	ROOM 208-SINK	EPA 200.8	AJM	1	PASI-M
10365814030	ROOM 206-SINK	EPA 200.8	AJM	1	PASI-M
10365814031	ROOM 205-SINK	EPA 200.8	AJM	1	PASI-M
10365814032	ROOM 204 -SINK	EPA 200.8	AJM	1	PASI-M
10365814033	ROOM 203-SINK	EPA 200.8	AJM	1	PASI-M
10365814034	ROOM 202-SINK	EPA 200.8	AJM	1	PASI-M
10365814035	ROOM 201-SINK	EPA 200.8	AJM	1	PASI-M
10365814036	GANG BATH NEXT TO 226-NORTH	EPA 200.8	AJM	1	PASI-M
10365814037	GANG BATH NEXT TO 226-MIDDLE	EPA 200.8	TT3	1	PASI-M

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### SAMPLE ANALYTE COUNT

Project: O CSD - Minetto Elementary

Pace Project No.: 10365814

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10365814038	GANG BATH NEXT TO 226-SOUTH	EPA 200.8	AJM	1	PASI-M
10365814039	ROOM 230-SINK	EPA 200.8	AJM	1	PASI-M
10365814040	ROOM 231-SINK	EPA 200.8	AJM	1	PASI-M
10365814041	ROOM 232-SINK	EPA 200.8	TT3	1	PASI-M
10365814042	ROOM 234-SINK	EPA 200.8	TT3	1	PASI-M
10365814043	ROOM 235-SINK	EPA 200.8	TT3	1	PASI-M
10365814044	ROOM 237-SINK-NORTH	EPA 200.8	TT3	1	PASI-M
10365814045	ROOM 238-SINK	EPA 200.8	TT3	1	PASI-M
10365814046	ROOM 140-SINK	EPA 200.8	TT3	1	PASI-M
10365814047	ROOM 126-BATH.SINK	EPA 200.8	TT3	1	PASI-M
10365814048	ROOM 128-BATH. SINK	EPA 200.8	TT3	1	PASI-M
10365814049	ROOM 130-BATH SINK	EPA 200.8	TT3	1	PASI-M
10365814050	ROOM 237-SINK-SOUTH	EPA 200.8	TT3	1	PASI-M
10365814051	CAFE GANG BATH. GIRLS SINK	EPA 200.8	TT3	1	PASI-M
10365814052	CAFE GANG BATH. BOYS SINK	EPA 200.8	TT3	1	PASI-M
10365814053	ROOM 149-SLOP SINK	EPA 200.8	TT3	1	PASI-M
10365814054	BOYS GANG BATH.NEXT 124 EAST	EPA 200.8	TT3	1	PASI-M
10365814055	BOYS GANG BATH.NEXT 124 WEST	EPA 200.8	TT3	1	PASI-M
10365814056	GIRLS GANG BATH.NEXT 124 EAST	EPA 200.8	TT3	1	PASI-M
10365814057	GIRLS GANG BATH.NEXT 124 WEST	EPA 200.8	TT3	1	PASI-M

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: O CSD - Minetto Elementary

Pace Project No.: 10365814

Sample: ROOM 142-RECEIVING-SLOP SINK		Lab ID: 10365814001	Collected: 09/29/16 23:00	Received: 10/11/16 18:30	Matrix: Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual		
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8								
Lead	5.4	ug/L	0.10	1		10/16/16 11:51	7439-92-1			
Sample: RM 141-HAND WASH STATION SOUTH		Lab ID: 10365814002	Collected: 09/29/16 23:00	Received: 10/11/16 18:30	Matrix: Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual		
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8								
Lead	3.2	ug/L	0.10	1		10/16/16 12:00	7439-92-1			
Sample: RM 141-HAND WASH STATION NORTH		Lab ID: 10365814003	Collected: 09/29/16 23:01	Received: 10/11/16 18:30	Matrix: Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual		
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8								
Lead	9.7	ug/L	0.10	1		10/16/16 12:01	7439-92-1			
Sample: ROOM 141-BATHROOM SINK		Lab ID: 10365814004	Collected: 09/29/16 23:02	Received: 10/11/16 18:30	Matrix: Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual		
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8								
Lead	17.6	ug/L	0.10	1		10/16/16 12:03	7439-92-1			
Sample: ROOM 140-SINK-NORTH		Lab ID: 10365814005	Collected: 09/29/16 23:04	Received: 10/11/16 18:30	Matrix: Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual		
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8								
Lead	1.4	ug/L	0.10	1		10/16/16 12:04	7439-92-1			
Sample: BATHRM ACROSS BOILER RM SINK		Lab ID: 10365814006	Collected: 09/29/16 23:05	Received: 10/11/16 18:30	Matrix: Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual		
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8								
Lead	1.6	ug/L	0.10	1		10/16/16 12:06	7439-92-1			

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: O CSD - Minetto Elementary

Pace Project No.: 10365814

Sample: ROOM 107A-FOUNTAIN		Lab ID: 10365814007	Collected: 09/29/16 23:09	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>23.3</b>	ug/L	0.10	1		10/16/16 12:07	7439-92-1	
Sample: ROOM 107A-SINK		Lab ID: 10365814008	Collected: 09/29/16 23:08	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>4.3</b>	ug/L	0.10	1		10/16/16 12:09	7439-92-1	
Sample: ROOM 109-SINK		Lab ID: 10365814009	Collected: 09/29/16 23:09	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>10.3</b>	ug/L	0.10	1		10/16/16 12:10	7439-92-1	
Sample: ROOM 117-SINK		Lab ID: 10365814010	Collected: 09/29/16 23:09	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>22.8</b>	ug/L	0.10	1		10/16/16 12:15	7439-92-1	
Sample: ROOM 111-FOUNTAIN ELKAY-NORTH		Lab ID: 10365814011	Collected: 09/29/16 23:11	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>6.6</b>	ug/L	0.10	1		10/16/16 12:16	7439-92-1	
Sample: ROOM 116-SINK		Lab ID: 10365814012	Collected: 09/29/16 23:12	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>3.0</b>	ug/L	0.10	1		10/16/16 12:19	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: O CSD - Minetto Elementary  
Pace Project No.: 10365814

Sample: ROOM 126-SINK		Lab ID: 10365814013	Collected: 09/29/16 23:14	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>1.1</b>	ug/L	0.10	1		10/16/16 12:21	7439-92-1	
Sample: ROOM 128-SINK		Lab ID: 10365814014	Collected: 09/29/16 23:14	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>1.3</b>	ug/L	0.10	1		10/16/16 12:22	7439-92-1	
Sample: ROOM 119-SINK		Lab ID: 10365814015	Collected: 09/29/16 23:17	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>0.62</b>	ug/L	0.10	1		10/16/16 12:24	7439-92-1	
Sample: ROOM 123-SINK		Lab ID: 10365814016	Collected: 09/29/16 23:18	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>0.48</b>	ug/L	0.10	1		10/16/16 12:25	7439-92-1	
Sample: ROOM 130-SINK		Lab ID: 10365814017	Collected: 09/29/16 23:20	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>0.65</b>	ug/L	0.10	1		10/16/16 12:27	7439-92-1	
Sample: ROOM 222-SINK		Lab ID: 10365814018	Collected: 09/29/16 23:29	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>2.1</b>	ug/L	0.10	1		10/16/16 12:28	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: O CSD - Minetto Elementary  
Pace Project No.: 10365814

Sample: ROOM 220-SINK		Lab ID: 10365814019	Collected: 09/29/16 23:30	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>1.2</b>	ug/L	0.10	1		10/16/16 12:36	7439-92-1	
Sample: ROOM 218-SINK		Lab ID: 10365814020	Collected: 09/29/16 23:31	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>0.79</b>	ug/L	0.10	1		10/16/16 12:37	7439-92-1	
Sample: ROOM 216-SINK		Lab ID: 10365814021	Collected: 09/29/16 23:31	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>0.66</b>	ug/L	0.10	1		10/17/16 16:13	7439-92-1	
Sample: ROOM 214-SINK		Lab ID: 10365814022	Collected: 09/29/16 23:32	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>1.2</b>	ug/L	0.10	1		10/17/16 16:17	7439-92-1	
Sample: ROOM 212-SINK		Lab ID: 10365814023	Collected: 09/29/16 23:33	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>5.0</b>	ug/L	0.10	1		10/17/16 16:18	7439-92-1	
Sample: ROOM 211-SLOP SINK		Lab ID: 10365814024	Collected: 09/29/16 23:35	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>6.0</b>	ug/L	0.10	1		10/17/16 16:20	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: O CSD - Minetto Elementary  
Pace Project No.: 10365814

**Sample: BOYS GANG BATH.NEXT RM211 EAST**      **Lab ID: 10365814025**      Collected: 09/29/16 23:36      Received: 10/11/16 18:30      Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b> Analytical Method: EPA 200.8								
Lead	2.2	ug/L	0.10	1		10/17/16 16:21	7439-92-1	

**Sample: BOYS GANG BATH.NEXT RM211 WEST**      **Lab ID: 10365814026**      Collected: 09/29/16 23:37      Received: 10/11/16 18:30      Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b> Analytical Method: EPA 200.8								
Lead	4.0	ug/L	0.10	1		10/17/16 16:27	7439-92-1	

**Sample: GIRL GANG BATH.NEXT RM205 EAST**      **Lab ID: 10365814027**      Collected: 09/29/16 23:37      Received: 10/11/16 18:30      Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b> Analytical Method: EPA 200.8								
Lead	2.5	ug/L	0.10	1		10/17/16 16:28	7439-92-1	

**Sample: GIRL GANG BATH.NEXT RM205 WEST**      **Lab ID: 10365814028**      Collected: 09/29/16 23:38      Received: 10/11/16 18:30      Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b> Analytical Method: EPA 200.8								
Lead	3.1	ug/L	0.10	1		10/17/16 16:29	7439-92-1	

**Sample: ROOM 208-SINK**      **Lab ID: 10365814029**      Collected: 09/29/16 23:39      Received: 10/11/16 18:30      Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b> Analytical Method: EPA 200.8								
Lead	2.1	ug/L	0.10	1		10/17/16 16:30	7439-92-1	

**Sample: ROOM 206-SINK**      **Lab ID: 10365814030**      Collected: 09/29/16 23:40      Received: 10/11/16 18:30      Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b> Analytical Method: EPA 200.8								
Lead	4.4	ug/L	0.10	1		10/17/16 16:31	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: O CSD - Minetto Elementary  
Pace Project No.: 10365814

<b>Sample: ROOM 205-SINK</b>		<b>Lab ID: 10365814031</b>	Collected: 09/29/16 23:40	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

**200.8 MET ICPMS, DW** Analytical Method: EPA 200.8

Lead	<b>3.0</b>	ug/L	0.10	1		10/17/16 16:33	7439-92-1	
------	------------	------	------	---	--	----------------	-----------	--

<b>Sample: ROOM 204 -SINK</b>		<b>Lab ID: 10365814032</b>	Collected: 09/29/16 23:41	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

**200.8 MET ICPMS, DW** Analytical Method: EPA 200.8

Lead	<b>6.1</b>	ug/L	0.10	1		10/17/16 16:34	7439-92-1	
------	------------	------	------	---	--	----------------	-----------	--

<b>Sample: ROOM 203-SINK</b>		<b>Lab ID: 10365814033</b>	Collected: 09/29/16 23:41	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

**200.8 MET ICPMS, DW** Analytical Method: EPA 200.8

Lead	<b>3.0</b>	ug/L	0.10	1		10/17/16 16:35	7439-92-1	
------	------------	------	------	---	--	----------------	-----------	--

<b>Sample: ROOM 202-SINK</b>		<b>Lab ID: 10365814034</b>	Collected: 09/29/16 23:43	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

**200.8 MET ICPMS, DW** Analytical Method: EPA 200.8

Lead	<b>3.0</b>	ug/L	0.10	1		10/17/16 16:36	7439-92-1	
------	------------	------	------	---	--	----------------	-----------	--

<b>Sample: ROOM 201-SINK</b>		<b>Lab ID: 10365814035</b>	Collected: 09/29/16 23:43	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

**200.8 MET ICPMS, DW** Analytical Method: EPA 200.8

Lead	<b>3.6</b>	ug/L	0.10	1		10/17/16 16:40	7439-92-1	
------	------------	------	------	---	--	----------------	-----------	--

<b>Sample: GANG BATH NEXT TO 226-NORTH</b>		<b>Lab ID: 10365814036</b>	Collected: 09/29/16 23:25	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

**200.8 MET ICPMS, DW** Analytical Method: EPA 200.8

Lead	<b>1.2</b>	ug/L	0.10	1		10/17/16 16:41	7439-92-1	
------	------------	------	------	---	--	----------------	-----------	--

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: O CSD - Minetto Elementary  
Pace Project No.: 10365814

**Sample: GANG BATH NEXT TO 226-MIDDLE**    **Lab ID: 10365814037**    Collected: 09/29/16 23:46    Received: 10/11/16 18:30    Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS</b> Analytical Method: EPA 200.8    Preparation Method: EPA 200.8								
Lead	1.8	ug/L	0.10	1	10/18/16 12:27	10/18/16 22:58	7439-92-1	

**Sample: GANG BATH NEXT TO 226-SOUTH**    **Lab ID: 10365814038**    Collected: 09/29/16 23:26    Received: 10/11/16 18:30    Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b> Analytical Method: EPA 200.8								
Lead	1.5	ug/L	0.10	1		10/17/16 16:42	7439-92-1	

**Sample: ROOM 230-SINK**    **Lab ID: 10365814039**    Collected: 09/29/16 23:47    Received: 10/11/16 18:30    Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b> Analytical Method: EPA 200.8								
Lead	15.7	ug/L	0.10	1		10/17/16 16:43	7439-92-1	

**Sample: ROOM 231-SINK**    **Lab ID: 10365814040**    Collected: 09/29/16 23:47    Received: 10/11/16 18:30    Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b> Analytical Method: EPA 200.8								
Lead	31.3	ug/L	0.10	1		10/17/16 16:44	7439-92-1	

**Sample: ROOM 232-SINK**    **Lab ID: 10365814041**    Collected: 09/29/16 23:49    Received: 10/11/16 18:30    Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b> Analytical Method: EPA 200.8								
Lead	11.5	ug/L	0.10	1		10/16/16 19:32	7439-92-1	

**Sample: ROOM 234-SINK**    **Lab ID: 10365814042**    Collected: 09/29/16 23:50    Received: 10/11/16 18:30    Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b> Analytical Method: EPA 200.8								
Lead	12.2	ug/L	0.10	1		10/16/16 19:38	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: O CSD - Minetto Elementary

Pace Project No.: 10365814

Sample: ROOM 235-SINK		Lab ID: 10365814043	Collected: 09/29/16 23:52	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>8.9</b>	ug/L	0.10	1		10/16/16 19:39	7439-92-1	
Sample: ROOM 237-SINK-NORTH		Lab ID: 10365814044	Collected: 09/29/16 23:56	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>19.4</b>	ug/L	0.10	1		10/16/16 19:41	7439-92-1	
Sample: ROOM 238-SINK		Lab ID: 10365814045	Collected: 09/29/16 23:58	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>33.6</b>	ug/L	0.10	1		10/16/16 19:45	7439-92-1	
Sample: ROOM 140-SINK		Lab ID: 10365814046	Collected: 09/29/16 23:04	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>13.6</b>	ug/L	0.10	1		10/16/16 19:47	7439-92-1	
Sample: ROOM 126-BATH.SINK		Lab ID: 10365814047	Collected: 09/29/16 23:15	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>1.6</b>	ug/L	0.10	1		10/16/16 19:48	7439-92-1	
Sample: ROOM 128-BATH. SINK		Lab ID: 10365814048	Collected: 09/29/16 23:16	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>1.9</b>	ug/L	0.10	1		10/16/16 19:50	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: O CSD - Minetto Elementary

Pace Project No.: 10365814

Sample: ROOM 130-BATH SINK		Lab ID: 10365814049	Collected: 09/29/16 23:20	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>0.35</b>	ug/L	0.10	1		10/16/16 19:51	7439-92-1	
Sample: ROOM 237-SINK-SOUTH		Lab ID: 10365814050	Collected: 09/29/16 23:56	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>4.1</b>	ug/L	0.10	1		10/16/16 19:53	7439-92-1	
Sample: CAFE GANG BATH. GIRLS SINK		Lab ID: 10365814051	Collected: 09/30/16 00:00	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>1.3</b>	ug/L	0.10	1		10/16/16 19:54	7439-92-1	
Sample: CAFE GANG BATH. BOYS SINK		Lab ID: 10365814052	Collected: 09/30/16 00:00	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>1.5</b>	ug/L	0.10	1		10/16/16 19:57	7439-92-1	
Sample: ROOM 149-SLOP SINK		Lab ID: 10365814053	Collected: 09/30/16 00:01	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>2.6</b>	ug/L	0.10	1		10/16/16 19:59	7439-92-1	
Sample: BOYS GANG BATH.NEXT 124 EAST		Lab ID: 10365814054	Collected: 09/30/16 00:05	Received: 10/11/16 18:30	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS, DW</b>		Analytical Method: EPA 200.8						
Lead	<b>0.71</b>	ug/L	0.10	1		10/16/16 20:04	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: O CSD - Minetto Elementary

Pace Project No.: 10365814

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

**Sample: BOYS GANG BATH.NEXT  
124 WEST**

Lab ID: 10365814055

Collected: 09/30/16 00:05 Received: 10/11/16 18:30 Matrix: Water

200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.64	ug/L	0.10	1		10/16/16 20:05	7439-92-1	

**Sample: GIRLS GANG BATH.NEXT  
124 EAST**

Lab ID: 10365814056

Collected: 09/30/16 00:07 Received: 10/11/16 18:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.73	ug/L	0.10	1		10/16/16 20:07	7439-92-1	

**Sample: GIRLS GANG BATH.NEXT  
124 WEST**

Lab ID: 10365814057

Collected: 09/30/16 00:07 Received: 10/11/16 18:30 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.86	ug/L	0.10	1		10/16/16 20:08	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA

Project: O CSD - Minetto Elementary

Pace Project No.: 10365814

QC Batch:	440813	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	ICPMS Metals, Drinking Water
Associated Lab Samples:	10365814001, 10365814002, 10365814003, 10365814004, 10365814005, 10365814006, 10365814007, 10365814008, 10365814009, 10365814010, 10365814011, 10365814012, 10365814013, 10365814014, 10365814015, 10365814016, 10365814017, 10365814018, 10365814019, 10365814020		

METHOD BLANK:	2398269	Matrix:	Water
Associated Lab Samples:	10365814001, 10365814002, 10365814003, 10365814004, 10365814005, 10365814006, 10365814007, 10365814008, 10365814009, 10365814010, 10365814011, 10365814012, 10365814013, 10365814014, 10365814015, 10365814016, 10365814017, 10365814018, 10365814019, 10365814020		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/16/16 11:48	

LABORATORY CONTROL SAMPLE:	2398270
----------------------------	---------

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	103	103	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE:	2402531	2402532									
--	---------	---------	--	--	--	--	--	--	--	--	--

Parameter	Units	10365814001 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	5.4	100	100	109	104	103	98	70-130	5	20	

MATRIX SPIKE SAMPLE:	2402533
----------------------	---------

Parameter	Units	10365814011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	6.6	100	103	96	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA

Project: O CSD - Minetto Elementary

Pace Project No.: 10365814

QC Batch:	440814	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	ICPMS Metals, Drinking Water
Associated Lab Samples:	10365814021, 10365814022, 10365814023, 10365814024, 10365814025, 10365814026, 10365814027, 10365814028, 10365814029, 10365814030, 10365814031, 10365814032, 10365814033, 10365814034, 10365814035, 10365814036, 10365814038, 10365814039, 10365814040		

METHOD BLANK:	2398272	Matrix:	Water
Associated Lab Samples:	10365814021, 10365814022, 10365814023, 10365814024, 10365814025, 10365814026, 10365814027, 10365814028, 10365814029, 10365814030, 10365814031, 10365814032, 10365814033, 10365814034, 10365814035, 10365814036, 10365814038, 10365814039, 10365814040		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/17/16 16:11	

LABORATORY CONTROL SAMPLE:	2398273					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	109	109	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE:	2403270			2403271								
Parameter	Units	10365814021 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	0.66	100	100	105	111	104	110	70-130	6	20	

MATRIX SPIKE SAMPLE:	2403272										
Parameter	Units	10365814030 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers				
Lead	ug/L	4.4	100	108	104	70-130					

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA

Project: O CSD - Minetto Elementary  
Pace Project No.: 10365814

QC Batch: 440815 Analysis Method: EPA 200.8  
QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water  
Associated Lab Samples: 10365814041, 10365814042, 10365814043, 10365814044, 10365814045, 10365814046, 10365814047, 10365814048, 10365814049, 10365814050, 10365814051, 10365814052, 10365814053, 10365814054, 10365814055, 10365814056, 10365814057

METHOD BLANK: 2398275 Matrix: Water  
Associated Lab Samples: 10365814041, 10365814042, 10365814043, 10365814044, 10365814045, 10365814046, 10365814047, 10365814048, 10365814049, 10365814050, 10365814051, 10365814052, 10365814053, 10365814054, 10365814055, 10365814056, 10365814057

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/16/16 19:27	

LABORATORY CONTROL SAMPLE: 2398276

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	104	104	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2402749 2402750

Parameter	Units	10365814041 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	11.5	100	100	108	108	96	96	70-130	0	20	

MATRIX SPIKE SAMPLE: 2402751

Parameter	Units	10365814051 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.3	100	100	99	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA

Project: O CSD - Minetto Elementary

Pace Project No.: 10365814

QC Batch: 441615	Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8	Analysis Description: 200.8 MET
Associated Lab Samples: 10365814037	

METHOD BLANK: 2403963 Matrix: Water  
Associated Lab Samples: 10365814037

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/18/16 22:41	

LABORATORY CONTROL SAMPLE: 2403964

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	107	107	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2403965 2403966

Parameter	Units	10365790057		MSD		MS		MSD		% Rec Limits	RPD	Max RPD	Qual
		Result	Conc.	Spike Conc.	Spike Conc.	Result	Result	% Rec	% Rec				
Lead	ug/L	43.3	100	100	100	140	140	97	97	70-130	0	20	

MATRIX SPIKE SAMPLE: 2403967

Parameter	Units	10366210062 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L		232	100	326	94	70-130

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALIFIERS

Project: O CSD - Minetto Elementary

Pace Project No.: 10365814

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

### LABORATORIES

PASI-M Pace Analytical Services - Minneapolis

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: O CSD - Minetto Elementary

Pace Project No.: 10365814

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10365814001	ROOM 142-RECEIVING-SLOP SINK	EPA 200.8	440813		
10365814002	RM 141-HAND WASH STATION SOUTH	EPA 200.8	440813		
10365814003	RM 141-HAND WASH STATION NORTH	EPA 200.8	440813		
10365814004	ROOM 141-BATHROOM SINK	EPA 200.8	440813		
10365814005	ROOM 140-SINK-NORTH	EPA 200.8	440813		
10365814006	BATHRM ACROSS BOILER RM SINK	EPA 200.8	440813		
10365814007	ROOM 107A-FOUNTAIN	EPA 200.8	440813		
10365814008	ROOM 107A-SINK	EPA 200.8	440813		
10365814009	ROOM 109-SINK	EPA 200.8	440813		
10365814010	ROOM 117-SINK	EPA 200.8	440813		
10365814011	ROOM 111-FOUNTAIN ELKAY-NORTH	EPA 200.8	440813		
10365814012	ROOM 116-SINK	EPA 200.8	440813		
10365814013	ROOM 126-SINK	EPA 200.8	440813		
10365814014	ROOM 128-SINK	EPA 200.8	440813		
10365814015	ROOM 119-SINK	EPA 200.8	440813		
10365814016	ROOM 123-SINK	EPA 200.8	440813		
10365814017	ROOM 130-SINK	EPA 200.8	440813		
10365814018	ROOM 222-SINK	EPA 200.8	440813		
10365814019	ROOM 220-SINK	EPA 200.8	440813		
10365814020	ROOM 218-SINK	EPA 200.8	440813		
10365814021	ROOM 216-SINK	EPA 200.8	440814		
10365814022	ROOM 214-SINK	EPA 200.8	440814		
10365814023	ROOM 212-SINK	EPA 200.8	440814		
10365814024	ROOM 211-SLOP SINK	EPA 200.8	440814		
10365814025	BOYS GANG BATH.NEXT RM211 EAST	EPA 200.8	440814		
10365814026	BOYS GANG BATH.NEXT RM211 WEST	EPA 200.8	440814		
10365814027	GIRL GANG BATH.NEXT RM205 EAST	EPA 200.8	440814		
10365814028	GIRL GANG BATH.NEXT RM205 WEST	EPA 200.8	440814		
10365814029	ROOM 208-SINK	EPA 200.8	440814		
10365814030	ROOM 206-SINK	EPA 200.8	440814		
10365814031	ROOM 205-SINK	EPA 200.8	440814		
10365814032	ROOM 204 -SINK	EPA 200.8	440814		
10365814033	ROOM 203-SINK	EPA 200.8	440814		
10365814034	ROOM 202-SINK	EPA 200.8	440814		
10365814035	ROOM 201-SINK	EPA 200.8	440814		
10365814036	GANG BATH NEXT TO 226-NORTH	EPA 200.8	440814		
10365814038	GANG BATH NEXT TO 226-SOUTH	EPA 200.8	440814		
10365814039	ROOM 230-SINK	EPA 200.8	440814		
10365814040	ROOM 231-SINK	EPA 200.8	440814		
10365814041	ROOM 232-SINK	EPA 200.8	440815		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

**QUALITY CONTROL DATA CROSS REFERENCE TABLE**

Project: O CSD - Minetto Elementary  
Pace Project No.: 10365814

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10365814042	ROOM 234-SINK	EPA 200.8	440815		
10365814043	ROOM 235-SINK	EPA 200.8	440815		
10365814044	ROOM 237-SINK-NORTH	EPA 200.8	440815		
10365814045	ROOM 238-SINK	EPA 200.8	440815		
10365814046	ROOM 140-SINK	EPA 200.8	440815		
10365814047	ROOM 126-BATH.SINK	EPA 200.8	440815		
10365814048	ROOM 128-BATH. SINK	EPA 200.8	440815		
10365814049	ROOM 130-BATH SINK	EPA 200.8	440815		
10365814050	ROOM 237-SINK-SOUTH	EPA 200.8	440815		
10365814051	CAFE GANG BATH. GIRLS SINK	EPA 200.8	440815		
10365814052	CAFE GANG BATH. BOYS SINK	EPA 200.8	440815		
10365814053	ROOM 149-SLOP SINK	EPA 200.8	440815		
10365814054	BOYS GANG BATH.NEXT 124 EAST	EPA 200.8	440815		
10365814055	BOYS GANG BATH.NEXT 124 WEST	EPA 200.8	440815		
10365814056	GIRLS GANG BATH.NEXT 124 EAST	EPA 200.8	440815		
10365814057	GIRLS GANG BATH.NEXT 124 WEST	EPA 200.8	440815		
10365814037	GANG BATH NEXT TO 226- MIDDLE	EPA 200.8	441615	EPA 200.8	441832

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

10365814

**Section A**  
 Required Client Information:  
 Company: Oswego CSD  
 Address: 224 West Ulica St  
 Oswego, NY 13126  
 Email To: [dcrisafu@oswego.org](mailto:dcrisafu@oswego.org)  
 Phone: \_\_\_\_\_  
 Requested Due Date/TAT: \_\_\_\_\_

**Section B**  
 Required Project Information:  
 Report To: \_\_\_\_\_  
 Copy To: \_\_\_\_\_  
 Purchase Order No.: \_\_\_\_\_  
 Project Name: Minetto Elementary  
 Project Number: \_\_\_\_\_

**Section C**  
 Invoice Information:  
 Attention: \_\_\_\_\_  
 Company Name: \_\_\_\_\_  
 Address: \_\_\_\_\_  
 Pace Quote Reference: \_\_\_\_\_  
 Pace Project Manager: \_\_\_\_\_  
 Pace Profile #: \_\_\_\_\_

**REGULATORY AGENCY**

NPDES  GROUND WATER  DRINKING WATER  
 UST  RCRA  OTHER \_\_\_\_\_

**SITE LOCATION**

GA  IL  IN  MI  NC  
 OH  SC  WI  OTHER\_NY \_\_\_\_\_

#	SAMPLE ID (A-Z, 0-9 / -)	Valid Matrix Codes MATRIX DRINKING WATER WATER WASTEWATER PRODUCT SOLID GAS OIL AIR ART TISSE	MATRIX CODE	COLLECTED		# OF CONTAINERS	PRESERVATIVES	Filtered (Y/N)	Requested	Pace Project No. Lab I.D.
				COMPOSITE START	COMPOSITE END/GRAB					
ITM	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME
1	ROOM 142 - RECEIVING-SLOP SINK	DW	DW	9/29	13:00	1	Unpreserved		X	001
2	ROOM 141 - HAND WASH STATION SOUTH	DW	DW		13:00	1	H2SO4		X	002
3	ROOM 141 - HAND WASH STATION NORTH	DW	DW		13:01	1	HNO3		X	003
4	ROOM 141 - BATHROOM SINK	DW	DW		13:02	1	HCl		X	004
5	ROOM 140 - SINK-NORTH	DW	DW		13:04	1	NaOH		X	005
6	BATHROOM ACROSS FROM BOILER ROOM-SINK	DW	DW		13:05	1	Na2SO4		X	006
7	ROOM 107A - FOUNTAIN	DW	DW		13:09	1	Methanol		X	007
8	ROOM 107A - SINK	DW	DW		13:08	1	Na2S2O8		X	008
9	ROOM 109-SINK	DW	DW		13:09	1			X	009
10	ROOM 117 - SINK	DW	DW		13:09	1			X	010
11	ROOM 111 - FOUNTAIN ELKAY-NORTH	DW	DW		13:11	1			X	011
12	ROOM 116 - SINK	DW	DW		13:12	1			X	012

**ADDITIONAL COMMENTS**  
 Relinquished by / Affiliation: *James Murphy PACE*  
 Date: 10/10/16 18:30  
 Accepted by / Affiliation: \_\_\_\_\_  
 Date: \_\_\_\_\_

**SAMPLE CONDITIONS**

Received on Ice	Y/N
Custody Sealed	Y/N
Cooler	Y/N
Samples Intact	Y/N

Temp in C: \_\_\_\_\_

**SAMPLER NAME AND SIGNATURE**  
 PRINT Name of SAMPLER: James Murphy - PACE Analytical  
 SIGNATURE of SAMPLER: *James Murphy*  
 DATE Signed (MM/DD/YY): 9/29/16



# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

**Section A**  
Required Client Information:

Company: Oswego CSD  
Address: 224 West Ulca St  
Oswego, NY 13126  
Email To: [dcisafu@oswego.org](mailto:dcisafu@oswego.org)  
Phone: \_\_\_\_\_ Fax: \_\_\_\_\_

Requested Due Date/TAT: \_\_\_\_\_

**Section B**  
Required Project Information:

Report To: \_\_\_\_\_  
Copy To: \_\_\_\_\_  
Purchase Order No.: \_\_\_\_\_  
Project Name: Minetto Elementary  
Project Number: \_\_\_\_\_

**Section C**  
Invoice Information:

Attention: \_\_\_\_\_  
Company Name: \_\_\_\_\_  
Address: \_\_\_\_\_  
Pace Quote Reference: \_\_\_\_\_  
Pace Project Manager: \_\_\_\_\_  
Pace Profile #: \_\_\_\_\_

**REGULATORY AGENCY**

NPDES  GROUND WATER  DRINKING WATER  
 UST  RCRA  OTHER \_\_\_\_\_

**SITE**  GA  IL  IN  MI  NC  
 OH  SC  WI  OTHER \_\_\_\_\_ NY

**LOCATION**

Filtered (Y/N) \_\_\_\_\_  
 Requested \_\_\_\_\_  
 Ate \_\_\_\_\_  
 Pace Project No. Lab I.D. \_\_\_\_\_

#	ITEM	Valid Matrix Codes	MATRIX	CODE	MATRIX	COLLECTED		SAMPLE TYPE	G-GRAB C-COMP	# OF CONTAINERS	PRESERVATIVES	UNPRESERVED	H2SO4	HNO3	HCl	NaOH	Na2S2O8	Methanol	Na2SO4	Requested	Ate	Filtered (Y/N)	SITE	LOCATION	REGULATORY AGENCY	Temp In C	Received on Ice	Custody Sealed	Cooler	Samples Intact	
						COMPOSITE START	COMPOSITE END/GRAB																								
				DATE	TIME	DATE	TIME			DATE	TIME			DATE	TIME			DATE	TIME			DATE	TIME			DATE	TIME			DATE	TIME
1			ROOM 126 - SINK	DW	G	9/29	23:14	DW	G	1										X											013
2			ROOM 128 - SINK	DW	G		23:14	DW	G	1										X											014
3			ROOM 119 - SINK	DW	G		23:17	DW	G	1										X											015
4			ROOM 123 - SINK	DW	G		23:18	DW	G	1										X											016
5			ROOM 130 - SINK	DW	G		23:20	DW	G	1										X											017
6			ROOM 222 - SINK	DW	G		23:24	DW	G	1										X											018
7			ROOM 220 - SINK	DW	G		23:24	DW	G	1										X											019
8			ROOM 218 - SINK	DW	G		23:23	DW	G	1										X											020
9			ROOM 216 - SINK	DW	G		23:23	DW	G	1										X											021
10			ROOM 214 - SINK	DW	G		23:23	DW	G	1										X											022
11			ROOM 212 - SINK	DW	G		23:23	DW	G	1										X											023
12			ROOM 211 - SLOP SINK	DW	G		23:25	DW	G	1										X											024

**ADDITIONAL COMMENTS**

*James Murphy* *PACE* 9/29/16 18:30

**RELINQUISHED BY / AFFILIATION** DATE TIME

*James Murphy* *PACE* 9/29/16 18:30

**ACCEPTED BY / AFFILIATION** DATE TIME

\_\_\_\_\_

**SAMPLER NAME AND SIGNATURE**

PRINT Name of SAMPLER: James Murphy - PACE Analytical  
 SIGNATURE of SAMPLER: *James Murphy*  
 DATE Signed (MM / DD / YY): 9/29/16



# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



www.pacelabs.com

Page: **4** of **5**

### Section A

Required Client Information:

Company: **Oswego CSD**  
 Address: **224 West Ullica St**  
 Oswego, NY 13126  
 Email To: **dcrisafu@oswego0100**  
 Phone: \_\_\_\_\_  
 Project Name: **Minetto Elementary**  
 Project Number: \_\_\_\_\_

### Section B

Required Project Information:

Attention: \_\_\_\_\_  
 Company Name: \_\_\_\_\_  
 Address: \_\_\_\_\_  
 Pace Quote Reference: \_\_\_\_\_  
 Pace Project Manager: \_\_\_\_\_  
 Pace Profile #: \_\_\_\_\_

### Section C

Invoice Information:

REGULATORY AGENCY  
 NPDES  GROUND WATER  DRINKING WATER  
 UST  RCRA  OTHER \_\_\_\_\_  
 SITE LOCATION  
 GA  IL  IN  MI  NC  
 OH  SC  WI  OTHER NY \_\_\_\_\_

ITEM #	Section D Required Client Information	Valid Matrix Codes	MATRIX CODE	SAMPLE TYPE	COLLECTED		# OF CONTAINERS	PRESERVATIVES	Requested	Pace Project No.	Lab I.D.
					COMPOSITE START	COMPOSITE END/GRAB					
1	GANG BATH NEXT TO 226-MIDDLE SINK	DW	DW G	G	9/29	23:46	1	Unpreserved	X	037	
2	GANG BATH NEXT TO 226-SOUTH SINK	DW	DW G	G	23:26	23:26	1	H2SO4	X	038	
3	ROOM 230-SINK	DW	DW G	G	23:47	23:47	1	HNO3	X	039	
4	ROOM 231-SINK	DW	DW G	G	23:47	23:47	1	HCl	X	040	
5	ROOM 232 - SINK	DW	DW G	G	23:49	23:49	1	NaOH	X	041	
6	ROOM 234 - SINK	DW	DW G	G	23:50	23:50	1	Na2S2O3	X	042	
7	ROOM 235 - SINK	DW	DW G	G	23:52	23:52	1	Na2SO4	X	043	
8	ROOM 237 - SINK - NORTH	DW	DW G	G	23:56	23:56	1	Methano	X	044	
9	ROOM 238 - SINK	DW	DW G	G	23:56	23:56	1		X	045	
10	ROOM 140 - SINK	DW	DW G	G	23:01	23:01	1		X	046	
11	ROOM 126 - BATH-SINK	DW	DW G	G	23:15	23:15	1		X	047	
12	ROOM 128 - BATH- SINK	DW	DW G	G	23:16	23:16	1		X	048	

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
	<i>James Murphy</i>	9/29/16	18:30				Temp in °C
							Received on Ice
							Custody Sealed Cooler
							Samples Intact


SAMPLER NAME AND SIGNATURE  
 PRINT Name of SAMPLER: **James Murphy - PACE Analytical**  
 SIGNATURE of SAMPLER: *James Murphy*  
 DATE Signed (MM / DD / YY): **9/29/16**



**Sample Condition Upon Receipt**

Client Name: Swego CSD Project #: \_\_\_\_\_

**WO#: 10365814**



10365814

Courier:  Fed Ex  UPS  USPS  Client  
 Commercial  Pace  Speedee  Other: \_\_\_\_\_  
 Tracking Number: 7744463863

Custody Seal on Cooler/Box Present?  Yes  No Seals Intact?  Yes  No  
 Optional: Proj. Due Date: \_\_\_\_\_ Proj. Name: \_\_\_\_\_

Packing Material:  Bubble Wrap  Bubble Bags  None  Other: \_\_\_\_\_ Temp Blank?  Yes  No

Thermometer  151401163  B88A912167504  B88A0143310098  
 Used:  151401164 Type of Ice:  Wet  Blue  None  Samples on ice, cooling process has begun

Cooler Temp Read (°C): 18.8 Cooler Temp Corrected (°C): 19.0 Biological Tissue Frozen?  Yes  No  N/A  
 Temp should be above freezing to 6°C Correction Factor: +0.2 Date and Initials of Person Examining Contents: EL 10/12/16

**USDA Regulated Soil** ( N/A, water sample)  
 Did samples originate in a quarantine zone within the United States: AL, AR, AZ, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX or VA (check maps)?  Yes  No  
 Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)?  Yes  No  
**If Yes to either question, fill out a Regulated Soil Checklist (F-MN-Q-338) and include with SCUR/COC paperwork.**

	COMMENTS:
Chain of Custody Present? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	1.
Chain of Custody Filled Out? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	2.
Chain of Custody Relinquished? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	3.
Sampler Name and/or Signature on COC? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	5.
Short Hold Time Analysis (<72 hr)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	6.
Rush Turn Around Time Requested? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	7.
Sufficient Volume? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	8.
Correct Containers Used? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	9.
-Pace Containers Used? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Containers Intact? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	10.
Filtered Volume Received for Dissolved Tests? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container
Sample Labels Match COC? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A -Includes Date/Time/ID/Analysis Matrix: <u>WJ</u>	12.
All containers needing acid/base preservation have been checked? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A All containers needing preservation are found to be in compliance with EPA recommendation? (HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl<2; NaOH >9 Sulfide, NaOH>12 Cyanide) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Exceptions: VOA, Coliform, TOC, Oil and Grease, DRO/8015 (water) DOC <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	13. <input checked="" type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl Sample # <u>1-57</u> Initial when completed: _____ Lot # of added preservative: _____
Headspace in VOA Vials (>6mm)? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14.
Trip Blank Present? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Trip Blank Custody Seals Present? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if purchased): _____	

**CLIENT NOTIFICATION/RESOLUTION** Field Data Required?  Yes  No

Person Contacted: \_\_\_\_\_ Date/Time: \_\_\_\_\_  
 Comments/Resolution: Temp OK

Project Manager Review: Awanda J. Albrecht Date: 10/14/16

Note: Whenever there is a discrepancy affecting North Carolina compliance samples, a copy of this form will be sent to the North Carolina DEHNR Certification Office (i.e. out of hold, incorrect preservative, out of temp, incorrect containers).