

November 02, 2016

David Crisafulli
Oswego CSD
225 West Utica St
Oswego, NY 12126

RE: Project: Oswego CSD Middle School
Pace Project No.: 10367170

Dear David Crisafulli:

Enclosed are the analytical results for sample(s) received by the laboratory on October 21, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

Samples, in the electronic data deliverable (EDD) that accompanied this report, were flagged yellow if they exceeded the NYSDOH 15 ppb action level.

The space designated for the sampler on the chain of custody (COC) indicates if these samples were collected by Pace Analytical or were collected by the school district and just relinquished to Pace Analytical.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Amanda Albrecht
amanda.albrecht@pacelabs.com
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: Oswego CSD Middle School

Pace Project No.: 10367170

Minnesota Certification IDs

1700 Elm Street SE Suite 200, Minneapolis, MN 55414

Alaska Certification UST-107

525 N 8th Street, Salina, KS 67401

A2LA Certification #: 2926.01

Alaska Certification #: UST-078

Alaska Certification #MN00064

Alabama Certification #40770

Arizona Certification #: AZ-0014

Arkansas Certification #: 88-0680

California Certification #: 01155CA

Colorado Certification #Pace

Connecticut Certification #: PH-0256

EPA Region 8 Certification #: 8TMS-L

Florida/NELAP Certification #: E87605

Guam Certification #:14-008r

Georgia Certification #: 959

Georgia EPD #: Pace

Idaho Certification #: MN00064

Hawaii Certification #MN00064

Illinois Certification #: 200011

Indiana Certification#C-MN-01

Iowa Certification #: 368

Kansas Certification #: E-10167

Kentucky Dept of Envi. Protection - DW #90062

Kentucky Dept of Envi. Protection - WW #:90062

Louisiana DEQ Certification #: 3086

Louisiana DHH #: LA140001

Maine Certification #: 2013011

Maryland Certification #: 322

Michigan DEPH Certification #: 9909

Minnesota Certification #: 027-053-137

Mississippi Certification #: Pace

Montana Certification #: MT0092

Nevada Certification #: MN_00064

Nebraska Certification #: Pace

New Jersey Certification #: MN-002

New York Certification #: 11647

North Carolina Certification #: 530

North Carolina State Public Health #: 27700

North Dakota Certification #: R-036

Ohio EPA #: 4150

Ohio VAP Certification #: CL101

Oklahoma Certification #: 9507

Oregon Certification #: MN200001

Oregon Certification #: MN300001

Pennsylvania Certification #: 68-00563

Puerto Rico Certification

Saipan (CNMI) #:MP0003

South Carolina #:74003001

Texas Certification #: T104704192

Tennessee Certification #: 02818

Utah Certification #: MN000642013-4

Virginia DGS Certification #: 251

Virginia/VELAP Certification #: Pace

Washington Certification #: C486

West Virginia Certification #: 382

West Virginia DHHR #:9952C

Wisconsin Certification #: 999407970

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: Oswego CSD Middle School
Pace Project No.: 10367170

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10367170001	Room 019/East Sink	Water	10/13/16 23:00	10/21/16 09:45
10367170002	Room 019/Middle Sink	Water	10/13/16 23:00	10/21/16 09:45
10367170003	Room 019/West Sink	Water	10/13/16 23:01	10/21/16 09:45
10367170004	Room 018/East Sink	Water	10/13/16 23:02	10/21/16 09:45
10367170005	Room 018/Middle Sink	Water	10/13/16 23:02	10/21/16 09:45
10367170006	Room 018/West Sink	Water	10/13/16 23:03	10/21/16 09:45
10367170007	Room 017/East Sink	Water	10/13/16 23:05	10/21/16 09:45
10367170008	Room 017/Middle Sink	Water	10/13/16 23:05	10/21/16 09:45
10367170009	Room 017/West Sink	Water	10/13/16 23:06	10/21/16 09:45
10367170010	Room 021/Sink	Water	10/13/16 23:06	10/21/16 09:45
10367170011	Room 035/Sink	Water	10/13/16 23:07	10/21/16 09:45
10367170012	Room 040/Girls Bathroom Sink	Water	10/13/16 23:08	10/21/16 09:45
10367170013	Room 040/Boys Bathroom Sink	Water	10/13/16 23:08	10/21/16 09:45
10367170014	Room 043/Sink	Water	10/13/16 23:10	10/21/16 09:45
10367170015	Room 046/Slop Sink	Water	10/13/16 23:11	10/21/16 09:45
10367170016	Bottom Flr Boys Gang Bathroom	Water	10/13/16 23:12	10/21/16 09:45
10367170017	Bottom Flr Girls Gang Bathroom	Water	10/13/16 23:13	10/21/16 09:45
10367170018	Room 011 Pool Filter Room Hose	Water	10/13/16 23:14	10/21/16 09:45
10367170019	Room 008 Girls Faculty Bathroo	Water	10/13/16 23:15	10/21/16 09:45
10367170020	Room 008 Boys Faculty Bathroom	Water	10/13/16 23:14	10/21/16 09:45
10367170021	Room 126/Sink	Water	10/13/16 23:17	10/21/16 09:45
10367170022	Room 130/Sink	Water	10/13/16 23:18	10/21/16 09:45
10367170023	Room 130/Storage Room Sink	Water	10/13/16 23:19	10/21/16 09:45
10367170024	Room 132 Art Rm-Trough Sink Ea	Water	10/13/16 23:20	10/21/16 09:45
10367170025	Room 132 Art Rm-Trough Sink We	Water	10/13/16 23:22	10/21/16 09:45
10367170026	Room 131/Sink	Water	10/13/16 23:23	10/21/16 09:45
10367170027	Room 135/Faucet	Water	10/13/16 23:24	10/21/16 09:45
10367170028	Room 140/Sink	Water	10/13/16 23:24	10/21/16 09:45
10367170029	Room 154/Sink	Water	10/13/16 23:25	10/21/16 09:45
10367170030	Room 154/Pod Sink	Water	10/13/16 23:26	10/21/16 09:45
10367170031	Room 159/Boys Bathroom Sink	Water	10/13/16 23:28	10/21/16 09:45
10367170032	Room 159/Girls Bathroom Sink	Water	10/13/16 23:28	10/21/16 09:45
10367170033	Room 159/Sink	Water	10/13/16 23:29	10/21/16 09:45
10367170034	Room 162/Pod Sink	Water	10/13/16 23:31	10/21/16 09:45
10367170035	Room 162/Sink	Water	10/13/16 23:30	10/21/16 09:45
10367170036	Room 163/Slop Sink	Water	10/13/16 23:32	10/21/16 09:45
10367170037	Room 116A/Laundry Room Sink	Water	10/13/16 23:33	10/21/16 09:45

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: Oswego CSD Middle School
Pace Project No.: 10367170

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10367170038	Hand Sink Next to 116A	Water	10/13/16 23:34	10/21/16 09:45
10367170039	Room 118 Hand Sink Across From	Water	10/13/16 23:37	10/21/16 09:45
10367170040	Room 118 Hand Sink next to Sli	Water	10/13/16 23:36	10/21/16 09:45
10367170041	Room 118 Hand Sink in back of	Water	10/13/16 23:35	10/21/16 09:45
10367170042	Room 118 Hand Sink next to Sto	Water	10/13/16 23:37	10/21/16 09:45
10367170043	Loading Dock/Mens Room Sink	Water	10/13/16 23:39	10/21/16 09:45
10367170044	Loading Dock/Ladies Room Sink	Water	10/13/16 23:38	10/21/16 09:45
10367170045	Room 115/Slop Sink	Water	10/13/16 23:46	10/21/16 09:45
10367170046	Room 113 Boys Locker Rm- Coache	Water	10/13/16 23:43	10/21/16 09:45
10367170047	Room 113 Boys Locker Rm- Bathro	Water	10/13/16 23:45	10/21/16 09:45
10367170048	Room 116 Girls Locker Rm-Coach	Water	10/13/16 23:49	10/21/16 09:45
10367170049	Room 116 Girls Locker Rm-Bathr	Water	10/13/16 23:42	10/21/16 09:45
10367170050	Room 104B-Boys Locker Room Ent	Water	10/13/16 23:44	10/21/16 09:45
10367170051	Room 104C-Girls Locker Room En	Water	10/13/16 23:50	10/21/16 09:45
10367170052	Top Floor Girls Gang Bathroom	Water	10/13/16 23:56	10/21/16 09:45
10367170053	Top Floor Boys Gang Bathroom S	Water	10/13/16 23:55	10/21/16 09:45
10367170054	Room 102G Nurses Office Bathro	Water	10/13/16 23:53	10/21/16 09:45
10367170055	Room 108/Slop Sink	Water	10/13/16 23:51	10/21/16 09:45
10367170056	Room 107/Sink	Water	10/13/16 23:52	10/21/16 09:45
10367170057	Upper Gym/Tub Room Sink	Water	10/13/16 23:40	10/21/16 09:45
10367170058	Room 102/Office Bath	Water	10/13/16 23:53	10/21/16 09:45

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: Oswego CSD Middle School
Pace Project No.: 10367170

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10367170001	Room 019/East Sink	EPA 200.8	WBS	1	PASI-M
10367170002	Room 019/Middle Sink	EPA 200.8	WBS	1	PASI-M
10367170003	Room 019/West Sink	EPA 200.8	WBS	1	PASI-M
10367170004	Room 018/East Sink	EPA 200.8	WBS	1	PASI-M
10367170005	Room 018/Middle Sink	EPA 200.8	WBS	1	PASI-M
10367170006	Room 018/West Sink	EPA 200.8	WBS	1	PASI-M
10367170007	Room 017/East Sink	EPA 200.8	WBS	1	PASI-M
10367170008	Room 017/Middle Sink	EPA 200.8	WBS	1	PASI-M
10367170009	Room 017/West Sink	EPA 200.8	WBS	1	PASI-M
10367170010	Room 021/Sink	EPA 200.8	WBS	1	PASI-M
10367170011	Room 035/Sink	EPA 200.8	WBS	1	PASI-M
10367170012	Room 040/Girls Bathroom Sink	EPA 200.8	WBS	1	PASI-M
10367170013	Room 040/Boys Bathroom Sink	EPA 200.8	WBS	1	PASI-M
10367170014	Room 043/Sink	EPA 200.8	WBS	1	PASI-M
10367170015	Room 046/Slop Sink	EPA 200.8	WBS	1	PASI-M
10367170016	Bottom Flr Boys Gang Bathroom	EPA 200.8	WBS	1	PASI-M
10367170017	Bottom Flr Girls Gang Bathroom	EPA 200.8	WBS	1	PASI-M
10367170018	Room 011 Pool Filter Room Hose	EPA 200.8	WBS	1	PASI-M
10367170019	Room 008 Girls Faculty Bathroo	EPA 200.8	WBS	1	PASI-M
10367170020	Room 008 Boys Faculty Bathroom	EPA 200.8	WBS	1	PASI-M
10367170021	Room 126/Sink	EPA 200.8	TT3	1	PASI-M
10367170022	Room 130/Sink	EPA 200.8	TT3	1	PASI-M
10367170023	Room 130/Storage Room Sink	EPA 200.8	TT3	1	PASI-M
10367170024	Room 132 Art Rm-Trough Sink Ea	EPA 200.8	TT3	1	PASI-M
10367170025	Room 132 Art Rm-Trough Sink We	EPA 200.8	TT3	1	PASI-M
10367170026	Room 131/Sink	EPA 200.8	TT3	1	PASI-M
10367170027	Room 135/Faucet	EPA 200.8	TT3	1	PASI-M
10367170028	Room 140/Sink	EPA 200.8	TT3	1	PASI-M
10367170029	Room 154/Sink	EPA 200.8	TT3	1	PASI-M
10367170030	Room 154/Pod Sink	EPA 200.8	TT3	1	PASI-M
10367170031	Room 159/Boys Bathroom Sink	EPA 200.8	TT3	1	PASI-M
10367170032	Room 159/Girls Bathroom Sink	EPA 200.8	TT3	1	PASI-M
10367170033	Room 159/Sink	EPA 200.8	TT3	1	PASI-M
10367170034	Room 162/Pod Sink	EPA 200.8	TT3	1	PASI-M
10367170035	Room 162/Sink	EPA 200.8	TT3	1	PASI-M
10367170036	Room 163/Slop Sink	EPA 200.8	WBS	1	PASI-M
10367170037	Room 116A/Laundry Room Sink	EPA 200.8	WBS	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: Oswego CSD Middle School

Pace Project No.: 10367170

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10367170038	Hand Sink Next to 116A	EPA 200.8	WBS	1	PASI-M
10367170039	Room 118 Hand Sink Across From	EPA 200.8	WBS	1	PASI-M
10367170040	Room 118 Hand Sink next to Sli	EPA 200.8	WBS	1	PASI-M
10367170041	Room 118 Hand Sink in back of	EPA 200.8	WBS	1	PASI-M
10367170042	Room 118 Hand Sink next to Sto	EPA 200.8	WBS	1	PASI-M
10367170043	Loading Dock/Mens Room Sink	EPA 200.8	WBS	1	PASI-M
10367170044	Loading Dock/Ladies Room Sink	EPA 200.8	WBS	1	PASI-M
10367170045	Room 115/Slop Sink	EPA 200.8	WBS	1	PASI-M
10367170046	Room 113 Boys Locker Rm-Coache	EPA 200.8	WBS	1	PASI-M
10367170047	Room 113 Boys Locker Rm-Bathro	EPA 200.8	WBS	1	PASI-M
10367170048	Room 116 Girls Locker Rm-Coach	EPA 200.8	WBS	1	PASI-M
10367170049	Room 116 Girls Locker Rm-Bathr	EPA 200.8	WBS	1	PASI-M
10367170050	Room 104B-Boys Locker Room Ent	EPA 200.8	WBS	1	PASI-M
10367170051	Room 104C-Girls Locker Room En	EPA 200.8	WBS	1	PASI-M
10367170052	Top Floor Girls Gang Bathroom	EPA 200.8	WBS	1	PASI-M
10367170053	Top Floor Boys Gang Bathroom S	EPA 200.8	WBS	1	PASI-M
10367170054	Room 102G Nurses Office Bathro	EPA 200.8	WBS	1	PASI-M
10367170055	Room 108/Slop Sink	EPA 200.8	WBS	1	PASI-M
10367170056	Room 107/Sink	EPA 200.8	WBS	1	PASI-M
10367170057	Upper Gym/Tub Room Sink	EPA 200.8	WBS	1	PASI-M
10367170058	Room 102/Office Bath	EPA 200.8	WBS	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: Oswego CSD Middle School
Pace Project No.: 10367170

Sample: Room 019/East Sink		Lab ID: 10367170001	Collected: 10/13/16 23:00	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	7.6	ug/L	0.10	1		10/27/16 19:39	7439-92-1	
Sample: Room 019/Middle Sink		Lab ID: 10367170002	Collected: 10/13/16 23:00	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	6.4	ug/L	0.10	1		10/27/16 19:44	7439-92-1	
Sample: Room 019/West Sink		Lab ID: 10367170003	Collected: 10/13/16 23:01	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	6.5	ug/L	0.10	1		10/27/16 19:45	7439-92-1	
Sample: Room 018/East Sink		Lab ID: 10367170004	Collected: 10/13/16 23:02	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	9.3	ug/L	0.10	1		10/27/16 19:46	7439-92-1	
Sample: Room 018/Middle Sink		Lab ID: 10367170005	Collected: 10/13/16 23:02	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	4.5	ug/L	0.10	1		10/27/16 19:49	7439-92-1	
Sample: Room 018/West Sink		Lab ID: 10367170006	Collected: 10/13/16 23:03	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	7.4	ug/L	0.10	1		10/27/16 19:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: Oswego CSD Middle School

Pace Project No.: 10367170

Sample: Room 017/East Sink		Lab ID: 10367170007	Collected: 10/13/16 23:05	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	5.7	ug/L	0.10	1		10/27/16 19:51	7439-92-1	
Sample: Room 017/Middle Sink		Lab ID: 10367170008	Collected: 10/13/16 23:05	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.5	ug/L	0.10	1		10/27/16 19:52	7439-92-1	
Sample: Room 017/West Sink		Lab ID: 10367170009	Collected: 10/13/16 23:06	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	8.5	ug/L	0.10	1		10/27/16 19:53	7439-92-1	
Sample: Room 021/Sink		Lab ID: 10367170010	Collected: 10/13/16 23:06	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	15.1	ug/L	0.10	1		10/27/16 19:54	7439-92-1	
Sample: Room 035/Sink		Lab ID: 10367170011	Collected: 10/13/16 23:07	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	20.9	ug/L	0.10	1		10/27/16 19:56	7439-92-1	
Sample: Room 040/Girls Bathroom Sink		Lab ID: 10367170012	Collected: 10/13/16 23:08	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.70	ug/L	0.10	1		10/27/16 19:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: Oswego CSD Middle School

Pace Project No.: 10367170

Sample: Room 040/Boys Bathroom Sink		Lab ID: 10367170013	Collected: 10/13/16 23:08	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.34	ug/L	0.10	1		10/27/16 19:59	7439-92-1	
Sample: Room 043/Sink		Lab ID: 10367170014	Collected: 10/13/16 23:10	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	14.5	ug/L	0.10	1		10/27/16 20:02	7439-92-1	
Sample: Room 046/Slop Sink		Lab ID: 10367170015	Collected: 10/13/16 23:11	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	28.3	ug/L	0.10	1		10/27/16 20:03	7439-92-1	
Sample: Bottom Fir Boys Gang Bathroom		Lab ID: 10367170016	Collected: 10/13/16 23:12	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.7	ug/L	0.10	1		10/27/16 20:04	7439-92-1	
Sample: Bottom Fir Girls Gang Bathroom		Lab ID: 10367170017	Collected: 10/13/16 23:13	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.5	ug/L	0.10	1		10/27/16 20:05	7439-92-1	
Sample: Room 011 Pool Filter Room Hose		Lab ID: 10367170018	Collected: 10/13/16 23:14	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	11.3	ug/L	0.10	1		10/27/16 20:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: Oswego CSD Middle School

Pace Project No.: 10367170

Sample: Room 008 Girls Faculty Bathroom		Lab ID: 10367170019	Collected: 10/13/16 23:15	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.65	ug/L	0.10	1		10/27/16 20:08	7439-92-1	
Sample: Room 008 Boys Faculty Bathroom		Lab ID: 10367170020	Collected: 10/13/16 23:14	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.2	ug/L	0.10	1		10/27/16 20:09	7439-92-1	
Sample: Room 126/Sink		Lab ID: 10367170021	Collected: 10/13/16 23:17	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	10	ug/L	0.10	1		10/31/16 19:40	7439-92-1	
Sample: Room 130/Sink		Lab ID: 10367170022	Collected: 10/13/16 23:18	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	3.7	ug/L	0.10	1		10/31/16 19:46	7439-92-1	
Sample: Room 130/Storage Room Sink		Lab ID: 10367170023	Collected: 10/13/16 23:19	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	4.8	ug/L	0.10	1		10/31/16 19:47	7439-92-1	
Sample: Room 132 Art Rm-Trough Sink Ea		Lab ID: 10367170024	Collected: 10/13/16 23:20	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.59	ug/L	0.10	1		10/31/16 19:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: Oswego CSD Middle School

Pace Project No.: 10367170

Sample: Room 132 Art Rm-Trough Sink We **Lab ID: 10367170025** Collected: 10/13/16 23:22 Received: 10/21/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW								
Analytical Method: EPA 200.8								
Lead	0.53	ug/L	0.10	1		10/31/16 19:50	7439-92-1	

Sample: Room 131/Sink **Lab ID: 10367170026** Collected: 10/13/16 23:23 Received: 10/21/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW								
Analytical Method: EPA 200.8								
Lead	9.9	ug/L	0.10	1		10/31/16 19:54	7439-92-1	

Sample: Room 135/Faucet **Lab ID: 10367170027** Collected: 10/13/16 23:24 Received: 10/21/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW								
Analytical Method: EPA 200.8								
Lead	1.9	ug/L	0.10	1		10/31/16 19:55	7439-92-1	

Sample: Room 140/Sink **Lab ID: 10367170028** Collected: 10/13/16 23:24 Received: 10/21/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW								
Analytical Method: EPA 200.8								
Lead	3.8	ug/L	0.10	1		10/31/16 19:57	7439-92-1	

Sample: Room 154/Sink **Lab ID: 10367170029** Collected: 10/13/16 23:25 Received: 10/21/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW								
Analytical Method: EPA 200.8								
Lead	25.2	ug/L	0.10	1		10/31/16 19:58	7439-92-1	

Sample: Room 154/Pod Sink **Lab ID: 10367170030** Collected: 10/13/16 23:26 Received: 10/21/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW								
Analytical Method: EPA 200.8								
Lead	2.2	ug/L	0.10	1		10/31/16 19:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: Oswego CSD Middle School
Pace Project No.: 10367170

Sample: Room 159/Boys Bathroom Sink **Lab ID: 10367170031** Collected: 10/13/16 23:28 Received: 10/21/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.72	ug/L	0.10	1		10/31/16 20:01	7439-92-1	

Sample: Room 159/Girls Bathroom Sink **Lab ID: 10367170032** Collected: 10/13/16 23:28 Received: 10/21/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.66	ug/L	0.10	1		10/31/16 20:04	7439-92-1	

Sample: Room 159/Sink **Lab ID: 10367170033** Collected: 10/13/16 23:29 Received: 10/21/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.50	ug/L	0.10	1		10/31/16 20:05	7439-92-1	

Sample: Room 162/Pod Sink **Lab ID: 10367170034** Collected: 10/13/16 23:31 Received: 10/21/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	9.7	ug/L	0.10	1		10/31/16 20:06	7439-92-1	

Sample: Room 162/Sink **Lab ID: 10367170035** Collected: 10/13/16 23:30 Received: 10/21/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	14.2	ug/L	0.10	1		10/31/16 20:12	7439-92-1	

Sample: Room 163/Slop Sink **Lab ID: 10367170036** Collected: 10/13/16 23:32 Received: 10/21/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	16.7	ug/L	0.10	1		10/27/16 18:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: Oswego CSD Middle School

Pace Project No.: 10367170

Sample: Room 116A/Laundry Room Sink		Lab ID: 10367170037	Collected: 10/13/16 23:33	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.31	ug/L	0.10	1		10/27/16 18:57	7439-92-1	
Sample: Hand Sink Next to 116A		Lab ID: 10367170038	Collected: 10/13/16 23:34	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.78	ug/L	0.10	1		10/27/16 18:58	7439-92-1	
Sample: Room 118 Hand Sink Across From		Lab ID: 10367170039	Collected: 10/13/16 23:37	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.8	ug/L	0.10	1		10/27/16 18:59	7439-92-1	
Sample: Room 118 Hand Sink next to Sli		Lab ID: 10367170040	Collected: 10/13/16 23:36	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.58	ug/L	0.10	1		10/27/16 19:00	7439-92-1	
Sample: Room 118 Hand Sink in back of		Lab ID: 10367170041	Collected: 10/13/16 23:35	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.7	ug/L	0.10	1		10/27/16 16:56	7439-92-1	
Sample: Room 118 Hand Sink next to Sto		Lab ID: 10367170042	Collected: 10/13/16 23:37	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.36	ug/L	0.10	1		10/27/16 17:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: Oswego CSD Middle School
Pace Project No.: 10367170

Sample: Loading Dock/Mens Room Sink **Lab ID: 10367170043** Collected: 10/13/16 23:39 Received: 10/21/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	5.8	ug/L	0.10	1		10/27/16 17:02	7439-92-1	

Sample: Loading Dock/Ladies Room Sink **Lab ID: 10367170044** Collected: 10/13/16 23:38 Received: 10/21/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	0.62	ug/L	0.10	1		10/27/16 17:03	7439-92-1	

Sample: Room 115/Slop Sink **Lab ID: 10367170045** Collected: 10/13/16 23:46 Received: 10/21/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	16.7	ug/L	0.10	1		10/27/16 17:04	7439-92-1	

Sample: Room 113 Boys Locker Rm-Coache **Lab ID: 10367170046** Collected: 10/13/16 23:43 Received: 10/21/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	0.92	ug/L	0.10	1		10/27/16 17:07	7439-92-1	

Sample: Room 113 Boys Locker Rm-Bathro **Lab ID: 10367170047** Collected: 10/13/16 23:45 Received: 10/21/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	2.8	ug/L	0.10	1		10/27/16 17:08	7439-92-1	

Sample: Room 116 Girls Locker Rm-Coach **Lab ID: 10367170048** Collected: 10/13/16 23:49 Received: 10/21/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW Analytical Method: EPA 200.8								
Lead	1.2	ug/L	0.10	1		10/27/16 17:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: Oswego CSD Middle School

Pace Project No.: 10367170

Sample:	Room 116 Girls Locker Rm-Bathr	Lab ID:	10367170049	Collected:	10/13/16 23:42	Received:	10/21/16 09:45	Matrix:	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8								
Lead	1.4	ug/L	0.10	1		10/27/16 17:11	7439-92-1		
Sample:	Room 104B-Boys Locker Room Ent	Lab ID:	10367170050	Collected:	10/13/16 23:44	Received:	10/21/16 09:45	Matrix:	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8								
Lead	10.4	ug/L	0.10	1		10/27/16 17:12	7439-92-1		
Sample:	Room 104C-Girls Locker Room En	Lab ID:	10367170051	Collected:	10/13/16 23:50	Received:	10/21/16 09:45	Matrix:	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8								
Lead	7.5	ug/L	0.10	1		10/27/16 17:13	7439-92-1		
Sample:	Top Floor Girls Gang Bathroom	Lab ID:	10367170052	Collected:	10/13/16 23:56	Received:	10/21/16 09:45	Matrix:	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8								
Lead	1.4	ug/L	0.10	1		10/27/16 17:15	7439-92-1		
Sample:	Top Floor Boys Gang Bathroom S	Lab ID:	10367170053	Collected:	10/13/16 23:55	Received:	10/21/16 09:45	Matrix:	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8								
Lead	0.61	ug/L	0.10	1		10/27/16 17:16	7439-92-1		
Sample:	Room 102G Nurses Office Bathro	Lab ID:	10367170054	Collected:	10/13/16 23:53	Received:	10/21/16 09:45	Matrix:	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8								
Lead	1.2	ug/L	0.10	1		10/27/16 17:17	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: Oswego CSD Middle School

Pace Project No.: 10367170

Sample: Room 108/Slop Sink		Lab ID: 10367170055	Collected: 10/13/16 23:51	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	2.5	ug/L	0.10	1		10/27/16 17:20	7439-92-1	
------	------------	------	------	---	--	----------------	-----------	--

Sample: Room 107/Sink		Lab ID: 10367170056	Collected: 10/13/16 23:52	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	1.4	ug/L	0.10	1		10/27/16 17:21	7439-92-1	
------	------------	------	------	---	--	----------------	-----------	--

Sample: Upper Gym/Tub Room Sink		Lab ID: 10367170057	Collected: 10/13/16 23:40	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	4.8	ug/L	0.10	1		10/27/16 17:22	7439-92-1	
------	------------	------	------	---	--	----------------	-----------	--

Sample: Room 102/Office Bath		Lab ID: 10367170058	Collected: 10/13/16 23:53	Received: 10/21/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	1.4	ug/L	0.10	1		10/27/16 17:23	7439-92-1	
------	------------	------	------	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: Oswego CSD Middle School

Pace Project No.: 10367170

QC Batch: 442746 Analysis Method: EPA 200.8
 QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
 Associated Lab Samples: 10367170001, 10367170002, 10367170003, 10367170004, 10367170005, 10367170006, 10367170007, 10367170008, 10367170009, 10367170010, 10367170011, 10367170012, 10367170013, 10367170014, 10367170015, 10367170016, 10367170017, 10367170018, 10367170019, 10367170020

METHOD BLANK: 2413078 Matrix: Water
 Associated Lab Samples: 10367170001, 10367170002, 10367170003, 10367170004, 10367170005, 10367170006, 10367170007, 10367170008, 10367170009, 10367170010, 10367170011, 10367170012, 10367170013, 10367170014, 10367170015, 10367170016, 10367170017, 10367170018, 10367170019, 10367170020

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/27/16 19:36	

LABORATORY CONTROL SAMPLE: 2413079

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	106	106	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2419599 2419600

Parameter	Units	10367170001 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	7.6	100	100	114	117	106	109	70-130	3	20	

MATRIX SPIKE SAMPLE: 2419601

Parameter	Units	10367170011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	20.9	100	126	105	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: Oswego CSD Middle School
Pace Project No.: 10367170

QC Batch: 442748 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
Associated Lab Samples: 10367170021, 10367170022, 10367170023, 10367170024, 10367170025, 10367170026, 10367170027, 10367170028, 10367170029, 10367170030, 10367170031, 10367170032, 10367170033, 10367170034, 10367170035, 10367170036, 10367170037, 10367170038, 10367170039, 10367170040

METHOD BLANK: 2413082 Matrix: Water
Associated Lab Samples: 10367170021, 10367170022, 10367170023, 10367170024, 10367170025, 10367170026, 10367170027, 10367170028, 10367170029, 10367170030, 10367170031, 10367170032, 10367170033, 10367170034, 10367170035, 10367170036, 10367170037, 10367170038, 10367170039, 10367170040

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/31/16 19:38	

LABORATORY CONTROL SAMPLE: 2413083

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	107	107	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2419229 2419230

Parameter	Units	10367170021 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	10	100	100	110	119	100	109	70-130	8	20	

MATRIX SPIKE SAMPLE: 2419231

Parameter	Units	10367170031 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	0.72	100	99.8	99	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: Oswego CSD Middle School

Pace Project No.: 10367170

QC Batch: 442750 Analysis Method: EPA 200.8
 QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
 Associated Lab Samples: 10367170041, 10367170042, 10367170043, 10367170044, 10367170045, 10367170046, 10367170047, 10367170048, 10367170049, 10367170050, 10367170051, 10367170052, 10367170053, 10367170054, 10367170055, 10367170056, 10367170057, 10367170058

METHOD BLANK: 2413087 Matrix: Water
 Associated Lab Samples: 10367170041, 10367170042, 10367170043, 10367170044, 10367170045, 10367170046, 10367170047, 10367170048, 10367170049, 10367170050, 10367170051, 10367170052, 10367170053, 10367170054, 10367170055, 10367170056, 10367170057, 10367170058

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/27/16 16:54	

LABORATORY CONTROL SAMPLE: 2413088

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	102	102	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2419051 2419052

Parameter	Units	10367170041 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	1.7	100	100	109	112	107	110	70-130	3	20	

MATRIX SPIKE SAMPLE: 2419053

Parameter	Units	10367170051 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	7.5	100	118	110	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: Oswego CSD Middle School

Pace Project No.: 10367170

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

LABORATORIES

PASI-M Pace Analytical Services - Minneapolis

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Oswego CSD Middle School
Pace Project No.: 10367170

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10367170001	Room 019/East Sink	EPA 200.8	442746		
10367170002	Room 019/Middle Sink	EPA 200.8	442746		
10367170003	Room 019/West Sink	EPA 200.8	442746		
10367170004	Room 018/East Sink	EPA 200.8	442746		
10367170005	Room 018/Middle Sink	EPA 200.8	442746		
10367170006	Room 018/West Sink	EPA 200.8	442746		
10367170007	Room 017/East Sink	EPA 200.8	442746		
10367170008	Room 017/Middle Sink	EPA 200.8	442746		
10367170009	Room 017/West Sink	EPA 200.8	442746		
10367170010	Room 021/Sink	EPA 200.8	442746		
10367170011	Room 035/Sink	EPA 200.8	442746		
10367170012	Room 040/Girls Bathroom Sink	EPA 200.8	442746		
10367170013	Room 040/Boys Bathroom Sink	EPA 200.8	442746		
10367170014	Room 043/Sink	EPA 200.8	442746		
10367170015	Room 046/Slop Sink	EPA 200.8	442746		
10367170016	Bottom Flr Boys Gang Bathroom	EPA 200.8	442746		
10367170017	Bottom Flr Girls Gang Bathroom	EPA 200.8	442746		
10367170018	Room 011 Pool Filter Room Hose	EPA 200.8	442746		
10367170019	Room 008 Girls Faculty Bathroo	EPA 200.8	442746		
10367170020	Room 008 Boys Faculty Bathroom	EPA 200.8	442746		
10367170021	Room 126/Sink	EPA 200.8	442748		
10367170022	Room 130/Sink	EPA 200.8	442748		
10367170023	Room 130/Storage Room Sink	EPA 200.8	442748		
10367170024	Room 132 Art Rm-Trough Sink Ea	EPA 200.8	442748		
10367170025	Room 132 Art Rm-Trough Sink We	EPA 200.8	442748		
10367170026	Room 131/Sink	EPA 200.8	442748		
10367170027	Room 135/Faucet	EPA 200.8	442748		
10367170028	Room 140/Sink	EPA 200.8	442748		
10367170029	Room 154/Sink	EPA 200.8	442748		
10367170030	Room 154/Pod Sink	EPA 200.8	442748		
10367170031	Room 159/Boys Bathroom Sink	EPA 200.8	442748		
10367170032	Room 159/Girls Bathroom Sink	EPA 200.8	442748		
10367170033	Room 159/Sink	EPA 200.8	442748		
10367170034	Room 162/Pod Sink	EPA 200.8	442748		
10367170035	Room 162/Sink	EPA 200.8	442748		
10367170036	Room 163/Slop Sink	EPA 200.8	442748		
10367170037	Room 116A/Laundry Room Sink	EPA 200.8	442748		
10367170038	Hand Sink Next to 116A	EPA 200.8	442748		
10367170039	Room 118 Hand Sink Across From	EPA 200.8	442748		
10367170040	Room 118 Hand Sink next to Sli	EPA 200.8	442748		
10367170041	Room 118 Hand Sink in back of	EPA 200.8	442750		
10367170042	Room 118 Hand Sink next to Sto	EPA 200.8	442750		
10367170043	Loading Dock/Mens Room Sink	EPA 200.8	442750		
10367170044	Loading Dock/Ladies Room Sink	EPA 200.8	442750		
10367170045	Room 115/Slop Sink	EPA 200.8	442750		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Oswego CSD Middle School

Pace Project No.: 10367170

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10367170046	Room 113 Boys Locker Rm- Coache	EPA 200.8	442750		
10367170047	Room 113 Boys Locker Rm- Bathro	EPA 200.8	442750		
10367170048	Room 116 Girls Locker Rm-Coach	EPA 200.8	442750		
10367170049	Room 116 Girls Locker Rm-Bathr	EPA 200.8	442750		
10367170050	Room 104B-Boys Locker Room Ent	EPA 200.8	442750		
10367170051	Room 104C-Girls Locker Room En	EPA 200.8	442750		
10367170052	Top Floor Girls Gang Bathroom	EPA 200.8	442750		
10367170053	Top Floor Boys Gang Bathroom S	EPA 200.8	442750		
10367170054	Room 102G Nurses Office Bathro	EPA 200.8	442750		
10367170055	Room 108/Slop Sink	EPA 200.8	442750		
10367170056	Room 107/Sink	EPA 200.8	442750		
10367170057	Upper Gym/Tub Room Sink	EPA 200.8	442750		
10367170058	Room 102/Office Bath	EPA 200.8	442750		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

10367170

Page: 1 of 5

Section A

Required Client Information:

Company: Oswego CSD
 Address: 224 West Seneca St
 Oswego, NY 13126
 Email To: dorisafu@oswego.org
 Phone: _____
 Project Name: Middle School
 Project Number: _____

Section B

Required Project Information:

Report To: _____
 Copy To: _____
 Purchase Order No.: _____
 Project Name: Middle School
 Pace Project Manager: _____
 Pace Profile #: _____

Section C

Invoice Information:

Attention: _____
 Company Name: _____
 Address: _____
 Pace Quote Reference: _____
 Pace Project Manager: _____
 Pace Profile #: _____

REGULATORY AGENCY

NPDES GROUND WATER DRINKING WATER
 UST RCRA OTHER _____

SITE GA IL IN MI NC
LOCATION OH SC WI OTHER_NY _____

ITEM #	Section D Required Client Information SAMPLE ID (A-Z, 0-9 / . -) Sample IDs MUST BE UNIQUE	Valid Matrix Codes MATRIX DW DRINKING WATER WW WASTE WATER P PRODUCT S SOLID O OIL L LIQUID G GAS T TISSUE	CODE	COLLECTED		# OF CONTAINERS	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
				COMPOSITE START	COMPOSITE END/GRAB					
Section E Required Project Information		SAMPLE TYPE	MATRIX CODE	DATE	TIME	DATE	TIME	DATE	TIME	TEMP IN °C
1	Room 019/EAST SINK	DW	G	10/13	23:00	1	JAMMY PACE	10/13/16	17:00	18.5
2	Room 019/MIDDLE SINK				23:00	1				
3	Room 019/WEST SINK				23:00	1				
4	Room 018/EAST SINK				23:02	1				
5	Room 018/MIDDLE SINK				23:02	1				
6	Room 018/WEST SINK				23:03	1				
7	Room 017/EAST SINK				23:05	1				
8	Room 017/MIDDLE SINK				23:05	1				
9	Room 017/WEST SINK				23:06	1				
10	Room 021/SINK				23:06	1				
11	Room 035/SINK				23:07	1				
12	Room 040/Gaols Between Sink				23:08	1				

Requested _____ **Requested** _____
Anne _____ **Requested** _____
Filtered (Y/N) _____ **Requested** _____
Preservatives _____ **Requested** _____
 H₂SO₄ _____ HNO₃ _____ HCl _____ NaOH _____ Na₂SO₃ _____ Methanol _____ Na₂SO₄ _____
 Pace Project No. Lab I.D. _____
 001
 002
 003
 004
 005
 006
 007
 008
 009
 010
 011
 012

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: James Murphy - PACE Analytical
 SIGNATURE of SAMPLER: *Jammy*
 DATE Signed (MM/DD/YYYY): 10/13/16



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

10367170

Section A
Required Client Information:

Company: Oswego CSD
Address: 224 West Seneca St
Oswego, NY 13126

Email To: glorisafu@oswego.org
Phone: _____
Fax: _____

Requested Due Date/FAT: _____

Section B
Required Project Information:

Report To: _____
Copy To: _____

Purchase Order No.: _____
Project Name: Middle School
Project Number: _____

Section C
Invoice Information:

Attention: _____
Company Name: _____
Address: _____

Pace Quote Reference: _____
Pace Project Manager: _____
Pace Profile #: _____

REGULATORY AGENCY

NPDES GROUND WATER DRINKING WATER

UST RCRA OTHER _____

SITE GA IL IN MI NC

LOCATION OH SC WI OTHER NY

ITEM #	Section D Required Client Information SAMPLE ID (A-Z, 0-9 / -) Sample IDs MUST BE UNIQUE	Valid Matrix Codes MATRIX DW DRINKING WATER WW WASTE WATER P WASTEWATER SL SOLID SL SOLID OIL LIFE AIR DT TS	MATRIX CODE	SAMPLE TYPE G-GRAB C-COMP	COLLECTED		# OF CONTAINERS COLLECTION	PRESERVATIVES	Requested Ant	Pace Project No. Lab I.D.
					COMPOSITE START DATE TIME	COMPOSITE ENDING DATE TIME				
1	Room 040/Boys Bathroom Sink			G		10/17 23:08	1	Unpreserved H ₂ SO ₄ HNO ₃ HCl NaOH Na ₂ SO ₄ Methanol Na ₂ SO ₄	X	013
2	Room 043 / SINK			G		23:10	1		X	014
3	Room 046 / SINK			G		23:11	1		X	015
4	BATH FLR BOYS BATH BATHROOM SINK			G		23:12	1		X	016
5	BATH FLR GIRLS BATH BATHROOM SINK			G		23:13	1		X	017
6	ROOM 011 FEE FEE FEE ROOM HISS SUPPLY			G		23:14	1		X	018
7	ROOM 008 GIRLS FACULTY BATHROOM SINK			G		23:15	1		X	019
8	ROOM 008 BOYS FACULTY BATHROOM SINK			G		23:14	1		X	020
9	Room 126 / SINK			G		23:17	1		X	021
10	Room 130 / SINK			G		23:18	1		X	022
11	ROOM 130 STORAGE ROOM SINK			G		23:19	1		X	023
12	ART ROOM - TROUGH SINK EAST			G		23:20	1		X	024

ADDITIONAL COMMENTS

JAMMY PACE 10/16/16 17:00
DRL Pace 10/11/16 945

RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
JAMMY PACE	10/11/16	17:00	DRL Pace	10/11/16	945	Y/N Y/N Y/N Y/N Y/N Y/N
						Y/N Y/N Y/N Y/N Y/N Y/N
						Y/N Y/N Y/N Y/N Y/N Y/N

SAMPLER NAME AND SIGNATURE
PRINT Name of SAMPLER: James Murphy - PACE Analytical
SIGNATURE of SAMPLER:
DATE Signed (MM/DD/YY): 10/13/16

Section A
Requested Client Information:
Company: Oswego CSD
Address: 224 West Seneca St
Oswego, NY 13126
Email To: dctisafu@oswego.org
Phone: _____ Fax: _____

Section B
Required Project Information:
Report To: _____
Copy To: _____
Purchase Order No.: _____
Project Name: Middle School
Project Number: _____

Section C
Invoice Information:
Attention: _____
Company Name: _____
Address: _____
Pace Quote Reference: _____
Pace Project Manager: _____
Pace Profile #: _____

Page: **3** of **5**

REGULATORY AGENCY
 NPDES GROUND WATER DRINKING WATER
 UST RCRA OTHER _____

SITE
 GA IL IN MI NC
 OH SC WI OTHER_NY _____

LOCATION

ITEM #	SAMPLE ID (A-Z, 0-9 / -)	Valid Matrix Codes MATRIX DRINKING WATER WASTE WATER PRODUCT RESIDUAL CHROME WIRE OTHER TERRAZO	CODE DW WW P S CL WP OT TS	MATRIX CODE	SAMPLE TYPE G-RAB C-COMP	COLLECTED		# OF CONTAINERS	PRESERVATIVES	Requester Ant	Filtered (Y/N)	Temp in °C	Received on Ice	Custody Sealed	Cooler	Samples Intact
						COMPOSITE START	COMPOSITE END/GRAB									
1	ROOM 132 ART ROOM - TROUGH SINK/NEST			DW G		10/13	23:22	1	Unpreserved	X		025				
2	ROOM 131 / SINK						23:23	1		X		026				
3	ROOM 133 / FAUCET						23:24	1		X		027				
4	ROOM 140 / SINK						23:24	1		X		028				
5	ROOM 154 / SINK						23:25	1		X		029				
6	ROOM 154 / POD SINK						23:26	1		X		030				
7	ROOM 159 / Boys Bathroom SINK						23:28	1		X		031				
8	ROOM 159 / Girls Bathroom SINK						23:28	1		X		032				
9	ROOM 159 / SINK						23:29	1		X		033				
10	ROOM 162 / POD SINK						23:31	1		X		034				
11	ROOM 162 / SINK						23:30	1		X		035				
12	ROOM 163 / SLOP SINK						23:32	1		X		036				

ADDITIONAL COMMENTS
James Murphy PACE

RELINQUISHED BY / AFFILIATION
James Murphy PACE

DATE
10/16/16

TIME
17:00

ACCEPTED BY / AFFILIATION
James Murphy PACE

DATE
10/16/16

TIME
9:45

SAMPLE CONDITIONS

Temp in °C	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N
Received on Ice							
Custody Sealed							
Cooler							
Samples Intact							

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: James Murphy - PACE Analytical
 SIGNATURE of SAMPLER: *James Murphy*
 DATE Signed (MM/DD/YYYY): 10/13/16



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

10367170

Section A Required Client Information:	Section B Required Project Information:	Section C Invoice Information:
Company: Oswego CSD	Report To:	Attention:
Address: 224 West Seneca St	Copy To:	Company Name:
Oswego, NY 13126	Purchase Order No.:	Address:
Email To: gcorisafu@oswego.org	Project Name: Middle School	Pace Quote Reference:
Phone:	Project Number:	Pace Project Manager:
Requested Due Date/TAT:		Pace Profile #:

Page: **4** of **5**

REGULATORY AGENCY

NPDES GROUND WATER DRINKING WATER

UST RORA OTHER

SITE GA IL IN MI NC

LOCATION OH SC WI OTHER_NY

#	ITEM	Valid Matrix Codes	MATRIX CODE	COLLECTED		# OF CONTAINERS	SAMPLER TYPE	SAMPLER TYPE	SAMPLER TYPE	PRESERVATIVES		Requested	Pace Project No. Lab I.D.
				COMPOSITE START	COMPOSITE END/GRAB					Unpreserved	H ₂ O ₂		
DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME
1	Room 116A/LAUNDRY ROOM SINK	DW	DW	10/13	23:13	1	G					X	037
2	HAND SINK NEXT TO 116A				23:34	1						X	038
3	HAND SINK ACCESS FROM DRESSING RM				23:37	1						X	039
4	HAND SINK NEXT TO SLICER				23:36	1						X	040
5	ROOM 118				23:35	1						X	041
6	HAND SINK IN BACK OF LINE 2				23:37	1						X	042
7	HAND SINK NEXT TO STOVE ROOM				23:39	1						X	043
8	LOADING DOCK/MEN'S ROOM SINK				23:38	1						X	044
9	LOADING DOCK/LADIES ROOM SINK				23:46	1						X	045
10	ROOM 115/ SLOP SINK				23:43	1						X	046
11	BOYS LOCKER RM - COACHES OFFICE SINK				23:45	1						X	047
12	ROOM 116				23:44	1						X	048

RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
James Murphy - PACE	10/21/16	17:00	James Murphy - PACE	10/21/16	09:45	Temp in °C Received on Ice Custody Sealed Cooler Samples Intact

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: James Murphy - PACE Analytical

SIGNATURE of SAMPLER: *James Murphy*

DATE Signed (MM / DD / YY): 10/13/16

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



Section A Required Client Information:

Company: Oswego CSD
 Address: 224 West Seneca St
 Oswego, NY 13126
 E-mail To: dctisafu@oswego.org
 Phone: _____ Fax: _____
 Project Name: Middle School
 Project Number: _____

Section B Required Project Information:

Report To: _____
 Copy To: _____
 Purchase Order No.: _____
 Project Name: Middle School
 Project Number: _____

Section C Invoice Information:

Attention: _____
 Company Name: _____
 Address: _____
 Pace Quote Reference: _____
 Pace Project Manager: _____
 Pace Profile #: _____

REGULATORY AGENCY
 NPDES GROUND WATER DRINKING WATER
 UST RCRA OTHER _____


SITE LOCATION
 GA IL IN MI NC
 OH SC WI OTHER NY _____

ITEM #	Section D Required Client Information	Valid Matrix Codes	MATRIX CODE	SAMPLE TYPE	COLLECTED		# OF CONTAINERS	PRESERVATIVES							Requested Ane	Filtered (Y/N)	Pace Project No. Lab I.D.
					COMPOSITE START	COMPOSITE END		Unpreserved	H ₂ O ₂	HNO ₃	HCl	NaOH	Na ₂ S ₂ O ₈	Methanol			
1	ROOM 116	DW	DW	G	10/13	23:47	1								X	049	
2	GRILLS LOCKER RM - BATHROOM SINK														X	050	
3	ROOM 104B - BOYS LOCKER ROOM														X	051	
4	ENTRANCE FROM POOL - SINK														X	052	
5	ROOM 104C - GRILLS LOCKER ROOM														X	053	
6	ENTRANCE FROM POOL - SINK														X	054	
7	TOP FLOOR														X	055	
8	GRILLS GALLIE BATHROOM SINK														X	056	
9	TOP FLOOR														X	057	
10	BOYS GALLIE BATHROOM SINK														X	058	
11	ROOM 102G														X		
12	MURKES OFFICE BATHROOM														X		
	ROOM 108 / SLOP SINK														X		
	Room 107 / SINK														X		
	UPPER GYM / BOYS ROOM SINK														X		
	Room 102 / OFFICE BATH														X		

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
	JAMMY PACE	10/16/16	17:00	ERIN PACE	10/16/16	9:45	Y/N Y/N Y/N Y/N Y/N Y/N

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: James Murphy - PACE Analytical
 SIGNATURE of SAMPLER: *Jammy P*
 DATE Signed (MM/DD/YYYY): 10/13/16

Sample Condition Upon Receipt Client Name: Pace NY Project #: **WO# : 10367170**
 Courier: Fed Ex UPS USPS Client
 Commercial Pace Speedee Other: _____
 Tracking Number: 7752207530



Custody Seal on Cooler/Box Present? Yes No Seals Intact? Yes No
 Packing Material: Bubble Wrap Bubble Bags None Other: _____ Temp Blank? Yes No
 Thermometer 151401163 B88A912167504 B88A0143310098 Type of Ice: Wet Blue None Samples on ice, cooling process has begun
 Used: 151401164
 Cooler Temp Read (°C): 18.3 Cooler Temp Corrected (°C): 18.5 Biological Tissue Frozen? Yes No N/A
 Temp should be above freezing to 6°C Correction Factor: +0.2 Date and Initials of Person Examining Contents: WT 10/21/16
USDA Regulated Soil N/A, water sample
 Did samples originate in a quarantine zone within the United States: AL, AR, AZ, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX or VA (check maps)? Yes No
 Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? Yes No
 If Yes to either question, fill out a Regulated Soil Checklist (F-MN-Q-338) and include with SCUR/COC paperwork.

	COMMENTS:
Chain of Custody Present? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	1.
Chain of Custody Filled Out? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	2.
Chain of Custody Relinquished? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	3.
Sampler Name and/or Signature on COC? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	5.
Short Hold Time Analysis (<72 hr)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	6.
Rush Turn Around Time Requested? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	7.
Sufficient Volume? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	8.
Correct Containers Used? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	9.
-Pace Containers Used? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Containers Intact? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	10.
Filtered Volume Received for Dissolved Tests? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container
Sample Labels Match COC? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	12.
-Includes Date/Time/ID/Analysis Matrix: <u>WT</u>	
All containers needing acid/base preservation have been checked? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input checked="" type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl Sample # <u>L-58</u>
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO ₃ , H ₂ SO ₄ , HCl<2; NaOH >9 Sulfide, NaOH >12 Cyanide) <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Initial when completed: _____ Lot # of added preservative: _____
Exceptions: VOA, Coliform, TOC, Oil and Grease, DRO/8015 (water) DOC <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Headspace in VOA Vials (>6mm)? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14.
Trip Blank Present? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Trip Blank Custody Seals Present? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if purchased): _____	

CLIENT NOTIFICATION/RESOLUTION Field Data Required? Yes No
 Person Contacted: _____ Date/Time: _____
 Comments/Resolution: Temp OK

Project Manager Review: Awanda J. Albrecht Date: 10/24/16
 Note: Whenever there is a discrepancy affecting North Carolina compliance samples, a copy of this form will be sent to the North Carolina DEHNR Certification Office (i.e. out of hold, incorrect preservative, out of temp, incorrect containers).