



**Sample Information:**

Type : Potable Water  
 Origin: Raw Well  
 Routine

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Oswego City School District**  
**120 East First Street**  
**Oswego, NY 13126**

**Lab No. : 1606B99-001**  
**Client Sample ID. : OUTSIDE DF**

**Attn To : David Chrisafulli**

**Middle School Storage Building**

Federal ID :

Collected : 06/10/2016 4:56 AM Point No

Received : 06/11/2016 9:50 AM Location:

Collected By :

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.1		1	ug/L	15	06/28/2016 5:11 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/29/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



PACE ANALYTICAL  
 575 Broad Hollow Road  
 Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
 Website: [www.pacelabs.com](http://www.pacelabs.com)

# QC SUMMARY REPORT

WO#: 1606B99  
 29-Jun-16

**Client:** Oswego City School District  
**Project:** Oswego City School District

**BatchID:** R100798

Sample ID	CalBlank	SampType: MBLK	TestCode: 200.8_DW_R	Units: ug/L	Prep Date:	RunNo: 100798
Client ID:	PBW	Batch ID: R100798	TestNo: E200.8	Analysis Date: 6/28/2016	SeqNo: 2217085	
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead		< 1.0	1.0			

**Qualifiers:**

* Value exceeds Maximum Contaminant Level	D Dilution was required.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	M Manual Integration used to determine area response	ND Not Detected at the Reporting Limit
O RSD is greater than RSDlimit	P Second column confirmation exceeds	R RPD outside accepted recovery limits
S Spike Recovery outside accepted recovery limits	W Sample container temperature is out of limit as specified	



PACE ANALYTICAL  
 575 Broad Hollow Road  
 Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
 Website: www.pacelabs.com

# Sample Receipt Checklist

Client Name **CITI**

Date and Time Received: **6/11/2016 9:50:00 AM**

Work Order Number: **1606B99**

RcptNo: **1**

Received by **Edward Domaradzki**

Completed by: *George A. Cappadona*

Reviewed by: *Elizabeth Harrison*

Completed Date: 6/12/2016 11:51:07 AM

Reviewed Date: 6/17/2016 2:02:32 PM

Carrier name: FedEx

- Chain of custody present? Yes  No
- Chain of custody signed when relinquished and received? Yes  No
- Chain of custody agrees with sample labels? Yes  No
- Are matrices correctly identified on Chain of custody? Yes  No
- Is it clear what analyses were requested? Yes  No
- Custody seals intact on sample bottles? Yes  No  Not Present
- Samples in proper container/bottle? Yes  No
- Were correct preservatives used and noted? Yes  No  NA
- Preservative added to bottles:
- Sample Condition? Intact  Broken  Leaking
- Sufficient sample volume for indicated test? Yes  No
- Were container labels complete (ID, Pres, Date)? Yes  No
- All samples received within holding time? Yes  No
- Was an attempt made to cool the samples? Yes  No  NA
- All samples received at a temp. of > 0° C to 6.0° C? Yes  No  NA
- Response when temperature is outside of range:
- Sample Temp. taken and recorded upon receipt? Yes  No  To °
- Water - Were bubbles absent in VOC vials? Yes  No  No Vials
- Water - Was there Chlorine Present? Yes  No  NA
- Water - pH acceptable upon receipt? Yes  No  No Water
- Are Samples considered acceptable? Yes  No
- Custody Seals present? Yes  No
- Airbill or Sticker? Air Bil  Sticker  Not Present
- Airbill No: 7764-9503-9830

Case Number:

SDG:

SAS:

Any No response should be detailed in the comments section below, if applicable.

Client Contacted?  Yes  No  NA Person Contacted:  
 Contact Mode:  Phone:  Fax:  Email:  In Person:  
 Client Instructions:  
 Date Contacted: Contacted By:  
 Regarding:  
 Comments:  
 CorrectiveAction:

WorkOrder :  
1606B99

## Certifications

---

STATE	CERTIFICATION #
NEW YORK	10478
NEW JERSEY	NY158
CONNECTICUT	PH-0435
MARYLAND	208
MAS S ACHUS E TTS	M-NY026
NE W HAMP S HIRE	2987
RHODE IS LAND	LAO00340
P E NNS YLVANIA	68-00350