



**Sample Information:**  
 Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Oswego City School District**  
**120 East First Street**  
**Oswego, NY 13126**  
**Attn To : David Chrisafulli**

**Lab No. : 1606C01-001**  
**Client Sample ID. : SINK IN BREAK ROOM-BUSINESS**  
**OFFICE - 3RD FLR**  
**Education Center**

Federal ID :  
 Collected : 06/10/2016 1:50 AM Point No  
 Received : 06/11/2016 9:50 AM Location:  
 Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: CM

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u>   | <u>Container:</u>  |
|---------------------|----------------|------------------|-------------|--------------|--------------|--------------------|--------------------|
| Lead                | < 1.0          |                  | 1           | ug/L         | 15           | 06/28/2016 5:17 PM | Container-01 of 01 |

Qualifiers: E = Value above quantitation range, Value estimated.  
 B = Found in Blank  
 D.F. = Dilution Factor D = Results for Dilution  
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
 H = Received/analyzed outside of analytical holding time  
 J = Estimated value - below calibration range  
 M-, M+ = Matrix Spike recovery below / above control limit  
 N = Indicates presumptive evidence of compound  
 P = Duplicate RPD outside of control limit  
 r = Reporting limit below calibration range. Value estimated.  
 S = Recovery outside of control limits for this analyte  
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
 Result(s) reported meet(s) Regulatory Limit(s).  
 Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
 Date Reported : 6/29/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Oswego City School District**  
**120 East First Street**  
**Oswego, NY 13126**

**Lab No. : 1606C01-002**  
**Client Sample ID. : DF BETWEEN BATHROOMS 3RD FLOOR**

**Attn To : David Chrisafulli**

**Education Center**

Federal ID :

Collected : 06/10/2016 1:49 AM Point No

Received : 06/11/2016 9:50 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: CM

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u>   | <u>Container:</u>  |
|---------------------|----------------|------------------|-------------|--------------|--------------|--------------------|--------------------|
| Lead                | 10             |                  | 1           | ug/L         | 15           | 06/28/2016 5:20 PM | Container-01 of 01 |

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/29/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Oswego City School District**  
**120 East First Street**  
**Oswego, NY 13126**

**Lab No. : 1606C01-003**  
**Client Sample ID. : DF BETWEEN BATHROOMS 2ND FLOOR**

**Attn To : David Chrisafulli**

**Education Center**

Federal ID :

Collected : 06/10/2016 1:53 AM Point No

Received : 06/11/2016 9:50 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: CM

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u>   | <u>Container:</u>  |
|---------------------|----------------|------------------|-------------|--------------|--------------|--------------------|--------------------|
| Lead                | 2.2            |                  | 1           | ug/L         | 15           | 06/28/2016 5:22 PM | Container-01 of 01 |

Qualifiers: E = Value above quantitation range, Value estimated.  
 B = Found in Blank  
 D.F. = Dilution Factor D = Results for Dilution  
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
 H = Received/analyzed outside of analytical holding time  
 J = Estimated value - below calibration range  
 M-, M+ = Matrix Spike recovery below / above control limit  
 N = Indicates presumptive evidence of compound  
 P = Duplicate RPD outside of control limit  
 r = Reporting limit below calibration range. Value estimated.  
 S = Recovery outside of control limits for this analyte  
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
 Result(s) reported meet(s) Regulatory Limit(s).  
 Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
 Date Reported : 6/29/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**  
 Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Oswego City School District**  
**120 East First Street**  
**Oswego, NY 13126**

**Lab No. : 1606C01-004**  
**Client Sample ID. : BREAK ROOM SINK - 2ND FLOOR**

**Attn To : David Chrisafulli**

**Education Center**

Federal ID :  
 Collected : 06/10/2016 1:53 AM Point No  
 Received : 06/11/2016 9:50 AM Location:  
 Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: CM

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u>   | <u>Container:</u>  |
|---------------------|----------------|------------------|-------------|--------------|--------------|--------------------|--------------------|
| Lead                | 8.1            |                  | 1           | ug/L         | 15           | 06/28/2016 5:40 PM | Container-01 of 01 |

Qualifiers: E = Value above quantitation range, Value estimated.  
 B = Found in Blank  
 D.F. = Dilution Factor D = Results for Dilution  
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
 H = Received/analyzed outside of analytical holding time  
 J = Estimated value - below calibration range  
 M-, M+ = Matrix Spike recovery below / above control limit  
 N = Indicates presumptive evidence of compound  
 P = Duplicate RPD outside of control limit  
 r = Reporting limit below calibration range. Value estimated.  
 S = Recovery outside of control limits for this analyte  
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
 Result(s) reported meet(s) Regulatory Limit(s).  
 Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
 Date Reported : 6/29/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.  
 This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Oswego City School District**  
**120 East First Street**  
**Oswego, NY 13126**

**Lab No. : 1606C01-005**  
**Client Sample ID. : DF BETWEEN BATHROOMS MAIN**  
**FLOOR**  
**Education Center**

**Attn To :** David Chrisafulli

Federal ID :

Collected : 06/10/2016 1:57 AM Point No

Received : 06/11/2016 9:50 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: CM

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u>   | <u>Container:</u>  |
|---------------------|----------------|------------------|-------------|--------------|--------------|--------------------|--------------------|
| Lead                | 1.8            |                  | 1           | ug/L         | 15           | 06/28/2016 5:43 PM | Container-01 of 01 |

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/29/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Oswego City School District**  
**120 East First Street**  
**Oswego, NY 13126**

**Lab No. : 1606C01-006**  
**Client Sample ID. : SUPERS OFFICE - BREAK ROOM SINK -**  
**MAIN FLOOR**  
**Education Center**

**Attn To :** David Chrisafulli

Federal ID :

Collected : 06/10/2016 1:58 AM Point No

Received : 06/11/2016 9:50 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: CM

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u>   | <u>Container:</u>  |
|---------------------|----------------|------------------|-------------|--------------|--------------|--------------------|--------------------|
| Lead                | < 1.0          |                  | 1           | ug/L         | 15           | 06/28/2016 5:46 PM | Container-01 of 01 |

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/29/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Oswego City School District**  
**120 East First Street**  
**Oswego, NY 13126**

**Lab No. : 1606C01-007**  
**Client Sample ID. : SINK IN SCIENCE ROOM - BASEMENT**  
**FLOOR**  
**Education Center**

**Attn To :** David Chrisafulli

Federal ID :

Collected : 06/10/2016 2:00 AM Point No

Received : 06/11/2016 9:50 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: CM

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u>   | <u>Container:</u>  |
|---------------------|----------------|------------------|-------------|--------------|--------------|--------------------|--------------------|
| Lead                | * 50           | *                | 1           | ug/L         | 15           | 06/28/2016 5:49 PM | Container-01 of 01 |

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/29/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Oswego City School District**  
**120 East First Street**  
**Oswego, NY 13126**

**Lab No. : 1606C01-008**  
**Client Sample ID. : SINK IN BOARD ROOM BASEMENT**  
**FLOOR**  
**Education Center**

**Attn To :** David Chrisafulli

Federal ID :

Collected : 06/10/2016 2:03 AM Point No

Received : 06/11/2016 9:50 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: CM

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u>   | <u>Container:</u>  |
|---------------------|----------------|------------------|-------------|--------------|--------------|--------------------|--------------------|
| Lead                | 2.7            |                  | 1           | ug/L         | 15           | 06/28/2016 5:52 PM | Container-01 of 01 |

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/29/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.





**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested.  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Oswego City School District**  
**120 East First Street**  
**Oswego, NY 13126**

**Lab No. : 1606C01-009**  
**Client Sample ID. : ICE MACHINE - BREAK ROOM - 2ND FLOOR**  
**Education Center**

**Attn To :** David Chrisafulli

Federal ID :

Collected : 06/10/2016 1:54 AM Point No

Received : 06/11/2016 9:50 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: CM

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u>   | <u>Container:</u>  |
|---------------------|----------------|------------------|-------------|--------------|--------------|--------------------|--------------------|
| Lead                | < 1.0          |                  | 1           | ug/L         | 15           | 06/28/2016 5:55 PM | Container-01 of 01 |

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/29/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



PACE ANALYTICAL  
 575 Broad Hollow Road  
 Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
 Website: [www.pacelabs.com](http://www.pacelabs.com)

# QC SUMMARY REPORT

WO#: 1606C01  
 29-Jun-16

**Client:** Oswego City School District  
**Project:** Oswego City School District

**BatchID:** R100798

|            |          |                   |                      |                          |                |  |
|------------|----------|-------------------|----------------------|--------------------------|----------------|--|
| Sample ID  | CalBlank | SampType: MBLK    | TestCode: 200.8_DW_R | Units: ug/L              | Prep Date:     | RunNo: 100798  |
| Client ID: | PBW      | Batch ID: R100798 | TestNo: E200.8       | Analysis Date: 6/28/2016 | SeqNo: 2217085 |  |
| Analyte    |          | Result            | PQL                  | SPK value                | SPK Ref Val    | %REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual |
| Lead       |          | < 1.0             | 1.0                  |                          |                |  |

**Qualifiers:**

|  |   |  |
|--|---|--|
| * Value exceeds Maximum Contaminant Level            | D Dilution was required.                                    | E Value above quantitation range       |
| H Holding times for preparation or analysis exceeded | M Manual Integration used to determine area response        | ND Not Detected at the Reporting Limit |
| O RSD is greater than RSDlimit                       | P Second column confirmation exceeds                        | R RPD outside accepted recovery limits |
| S Spike Recovery outside accepted recovery limits    | W Sample container temperature is out of limit as specified |  |



PACE ANALYTICAL  
 575 Broad Hollow Road  
 Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
 Website: www.pacelabs.com

# Sample Receipt Checklist

Client Name **CITI** Date and Time Received: **6/11/2016 9:50:00 AM**

Work Order Number: **1606C01** RcptNo: **1** Received by **Edward Domaradzki**

Completed by: *George A. Cappadona* Reviewed by: *Elizabeth Harrison*

Completed Date: 6/12/2016 1:08:24 PM Reviewed Date: 6/17/2016 2:05:16 PM

Carrier name: FedEx

- Chain of custody present? Yes  No
- Chain of custody signed when relinquished and received? Yes  No
- Chain of custody agrees with sample labels? Yes  No
- Are matrices correctly identified on Chain of custody? Yes  No
- Is it clear what analyses were requested? Yes  No
- Custody seals intact on sample bottles? Yes  No  Not Present
- Samples in proper container/bottle? Yes  No
- Were correct preservatives used and noted? Yes  No  NA
- Preservative added to bottles:
- Sample Condition? Intact  Broken  Leaking
- Sufficient sample volume for indicated test? Yes  No
- Were container labels complete (ID, Pres, Date)? Yes  No
- All samples received within holding time? Yes  No
- Was an attempt made to cool the samples? Yes  No  NA
- All samples received at a temp. of > 0° C to 6.0° C? Yes  No  NA
- Response when temperature is outside of range:
- Sample Temp. taken and recorded upon receipt? Yes  No  To °
- Water - Were bubbles absent in VOC vials? Yes  No  No Vials
- Water - Was there Chlorine Present? Yes  No  NA
- Water - pH acceptable upon receipt? Yes  No  No Water
- Are Samples considered acceptable? Yes  No
- Custody Seals present? Yes  No
- Airbill or Sticker? Air Bil  Sticker  Not Present
- Airbill No: 7764-9503-9830

Case Number: SDG: SAS:

Any No response should be detailed in the comments section below, if applicable.

Client Contacted?  Yes  No  NA Person Contacted:  
 Contact Mode:  Phone:  Fax:  Email:  In Person:  
 Client Instructions:  
 Date Contacted: Contacted By:  
 Regarding:  
 Comments:  
 CorrectiveAction:

WorkOrder :  
1606C01

## Certifications

---

| STATE             | CERTIFICATION # |
|-------------------|-----------------|
| NEW YORK          | 10478           |
| NEW JERSEY        | NY158           |
| CONNECTICUT       | PH-0435         |
| MARYLAND          | 208             |
| MAS S ACHUS E TTS | M-NY026         |
| NE W HAMP S HIRE  | 2987            |
| RHODE IS LAND     | LAO00340        |
| P E NNS YLVANIA   | 68-00350        |