



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-001
Client Sample ID. : ROOM 117-FOUNTAIN

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 2:41 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	06/29/2016 6:26 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-002
Client Sample ID. : ROOM 115-FOUNTAIN

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 2:43 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.6		1	ug/L	15	06/29/2016 6:29 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-003
Client Sample ID. : ROOM 110-FOUNTAIN

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 2:45 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 21	*	1	ug/L	15	06/29/2016 6:32 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-004
Client Sample ID. : ROOM 113-FOUNTAIN

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 2:46 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 43	*	1	ug/L	15	06/29/2016 6:35 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-005
Client Sample ID. : DF ACROSS FROM ROOM 108

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 2:47 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	12		1	ug/L	15	06/29/2016 6:38 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-006
Client Sample ID. : ROOM 108-SINK

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 2:48 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 16	*	1	ug/L	15	06/29/2016 6:41 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-007
Client Sample ID. : ROOM 109-SINK

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 2:50 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	06/29/2016 6:44 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-008
Client Sample ID. : ROOM 106-SINK

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 2:52 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.5		1	ug/L	15	06/29/2016 6:47 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-009
Client Sample ID. : ROOM 104-SINK USED TO DISPENSE
MEDS
Charles E. Riley Elementary

Attn To : David Chrisafulli

Federal ID :

Collected : 06/10/2016 2:54 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.0		1	ug/L	15	06/29/2016 7:01 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-010
Client Sample ID. : ROOM 121-TEACHERS ROOM SINK

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 2:56 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.0		1	ug/L	15	06/29/2016 7:04 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
B = Found in Blank
D.F. = Dilution Factor D = Results for Dilution
c = Calibration acceptability criteria exceeded for this analyte. Value estimated
H = Received/analyzed outside of analytical holding time
J = Estimated value - below calibration range
M-, M+ = Matrix Spike recovery below / above control limit
N = Indicates presumptive evidence of compound
P = Duplicate RPD outside of control limit
r = Reporting limit below calibration range. Value estimated.
S = Recovery outside of control limits for this analyte
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method
Result(s) reported meet(s) Regulatory Limit(s).
Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-011
Client Sample ID. : DF ACROSS FROM 123B

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 2:57 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.4		1	ug/L	15	06/29/2016 7:07 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
B = Found in Blank
D.F. = Dilution Factor D = Results for Dilution
c = Calibration acceptability criteria exceeded for this analyte. Value estimated
H = Received/analyzed outside of analytical holding time
J = Estimated value - below calibration range
M-, M+ = Matrix Spike recovery below / above control limit
N = Indicates presumptive evidence of compound
P = Duplicate RPD outside of control limit
r = Reporting limit below calibration range. Value estimated.
S = Recovery outside of control limits for this analyte
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method
Result(s) reported meet(s) Regulatory Limit(s).
Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-012
Client Sample ID. : DF NEXT TO ROOM 134

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 2:59 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 7:10 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-013
Client Sample ID. : 3 BAY SINK-LEFT -ROOM 123D

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 3:02 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 26	*	1	ug/L	15	06/29/2016 7:13 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-014
Client Sample ID. : KETTLE ROOM 123D

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :
 Collected : 06/10/2016 3:04 AM Point No
 Received : 06/14/2016 10:15 AM Location:
 Collected By : CLIENT

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 29	*	1	ug/L	15	06/29/2016 7:16 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.
 This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-015
Client Sample ID. : ROOM 156 FAUCET ON SINK

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 3:06 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 150	*	1	ug/L	15	06/29/2016 7:19 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-016
Client Sample ID. : ROOM 158 FAUCET ON SINK

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 3:07 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	14		1	ug/L	15	06/29/2016 7:22 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-017
Client Sample ID. : DF ACROSS FROM 165 STAINLESS

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 3:08 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.1		1	ug/L	15	06/29/2016 7:36 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-018
Client Sample ID. : DF-ROOM 167

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 3:09 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	14		1	ug/L	15	06/29/2016 7:39 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-019
Client Sample ID. : DF-ROOM 169

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 3:10 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	12		1	ug/L	15	06/29/2016 7:42 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-020

Client Sample ID. : DF ACROSS FROM 208

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 3:12 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	8.8		1	ug/L	15	06/29/2016 7:45 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-021
Client Sample ID. : DF-ROOM 216

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 3:14 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 36	*	1	ug/L	15	06/29/2016 7:48 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-022
Client Sample ID. : DF-ROOM 184

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 3:16 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 16	*	1	ug/L	15	06/29/2016 7:51 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-023
Client Sample ID. : DF-ROOM 183

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 3:17 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 24	*	1	ug/L	15	06/29/2016 7:54 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-024
Client Sample ID. : DF-ROOM 181

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 3:19 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	11		1	ug/L	15	06/29/2016 7:57 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-025
Client Sample ID. : DF-ROOM 180

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 3:20 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 18	*	1	ug/L	15	06/29/2016 8:11 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-026
Client Sample ID. : DF OUTSIDE 176-GYM

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 3:22 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	06/29/2016 8:14 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F36-027
Client Sample ID. : 3 BAY SINK-RIGHT ROOM 123D

Attn To : David Chrisafulli

Charles E. Riley Elementary

Federal ID :

Collected : 06/10/2016 3:04 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : CLIENT

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 38	*	1	ug/L	15	06/29/2016 8:17 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 6/30/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



PACE ANALYTICAL
 575 Broad Hollow Road
 Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
 Website: www.pacelabs.com

QC SUMMARY REPORT

WO#: 1606F36
 30-Jun-16

Client: Oswego City School District
Project: Oswego City School District

BatchID: R100897

Sample ID	CalBlank	SampType: MBLK	TestCode: 200.8_DW_R	Units: ug/L	Prep Date:	RunNo: 100897
Client ID:	PBW	Batch ID: R100897	TestNo: E200.8	Analysis Date: 6/29/2016	SeqNo: 2219924	
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead		< 1.0	1.0			

Qualifiers:

* Value exceeds Maximum Contaminant Level	D Dilution was required.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	M Manual Integration used to determine area response	ND Not Detected at the Reporting Limit
O RSD is greater than RSDlimit	P Second column confirmation exceeds	R RPD outside accepted recovery limits
S Spike Recovery outside accepted recovery limits	W Sample container temperature is out of limit as specified	



PACE ANALYTICAL
 575 Broad Hollow Road
 Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
 Website: www.pacelabs.com

Sample Receipt Checklist

Client Name **CITI** Date and Time Received: **6/14/2016 10:15:00 AM**

Work Order Number: **1606F36** RcptNo: **1** Received by **George Cappadona**

Completed by: *George A. Cappadona* Reviewed by: *Elizabeth Harrison*
 Completed Date: 6/16/2016 11:00:29 AM Reviewed Date: 6/17/2016 12:49:34 PM

Carrier name: FedEx

- Chain of custody present? Yes No
- Chain of custody signed when relinquished and received? Yes No
- Chain of custody agrees with sample labels? Yes No
- Are matrices correctly identified on Chain of custody? Yes No
- Is it clear what analyses were requested? Yes No
- Custody seals intact on sample bottles? Yes No Not Present
- Samples in proper container/bottle? Yes No
- Were correct preservatives used and noted? Yes No NA
- Preservative added to bottles:
- Sample Condition? Intact Broken Leaking
- Sufficient sample volume for indicated test? Yes No
- Were container labels complete (ID, Pres, Date)? Yes No
- All samples received within holding time? Yes No
- Was an attempt made to cool the samples? Yes No NA
- All samples received at a temp. of > 0° C to 6.0° C? Yes No NA
- Response when temperature is outside of range:
- Sample Temp. taken and recorded upon receipt? Yes No To °
- Water - Were bubbles absent in VOC vials? Yes No No Vials
- Water - Was there Chlorine Present? Yes No NA
- Water - pH acceptable upon receipt? Yes No No Water
- Are Samples considered acceptable? Yes No
- Custody Seals present? Yes No
- Airbill or Sticker? Air Bil Sticker Not Present
- Airbill No: 7765-0906-8023

Case Number: SDG: SAS:

Any No response should be detailed in the comments section below, if applicable.

Client Contacted? Yes No NA Person Contacted:
 Contact Mode: Phone: Fax: Email: In Person:
 Client Instructions:
 Date Contacted: Contacted By:
 Regarding:
 Comments:
 CorrectiveAction:

WorkOrder :
1606F36

Certifications

STATE	CERTIFICATION #
NEW YORK	10478
NEW JERSEY	NY158
CONNECTICUT	PH-0435
MARYLAND	208
MAS S ACHUS E TTS	M-NY026
NE W HAMP S HIRE	2987
RHODE IS LAND	LAO00340
PE NNS YLVANIA	68-00350