



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-001
Client Sample ID. : ROOM 001-SINK

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:00 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.9		1	ug/L	15	06/29/2016 8:20 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-002
Client Sample ID. : ROOM 008-SINK

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:01 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 8:23 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-003
Client Sample ID. : DF ACROSS FROM GANG BATHROOMS

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:02 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 8:26 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-004
Client Sample ID. : DF-ROOM 017

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:04 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 8:29 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-005
Client Sample ID. : DF IN HALL NEXT TO 018

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:04 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 8:32 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-006
Client Sample ID. : DF-ROOM 018

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:05 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 8:47 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-007
Client Sample ID. : DF-ROOM 019

Attn To : David Chrisafulli

Middle School

Federal ID :
 Collected : 06/14/2016 4:06 AM Point No
 Received : 06/14/2016 10:15 AM Location:
 Collected By : Client

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Analyst:</u> AG <u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 8:49 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.
 This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-008
Client Sample ID. : DF-NEXT TO 038

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:07 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 8:52 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-009
Client Sample ID. : ROOM 040-SINK

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:08 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 8:55 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-010
Client Sample ID. : ROOM 133 SINK-STATION 1

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:12 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 8:58 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-011
Client Sample ID. : ROOM 133 SINK-STATION 2

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:13 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 9:01 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-012
Client Sample ID. : ROOM 133 SINK-STATION 3

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:14 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 9:04 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-013
Client Sample ID. : ROOM 133 SINK-STATION 4

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:15 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0	PM-	1	ug/L	15	06/29/2016 9:07 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-014
Client Sample ID. : DF-NEXT TO 135

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:16 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 9:22 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-015
Client Sample ID. : TEACHERS LOUNGE SINK

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:17 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 9:24 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-016
Client Sample ID. : DF-NEXT TO 157

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:18 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 9:27 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-017
Client Sample ID. : ROOM 159-SINK

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:18 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 9:30 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-018
Client Sample ID. : ICE MACHINE IN KITCHEN

Attn To : David Chrisafulli

Middle School

Federal ID :
 Collected : 06/14/2016 4:20 AM Point No
 Received : 06/14/2016 10:15 AM Location:
 Collected By : Client

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Analyst:</u> AG <u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 9:33 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.
 This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-019
Client Sample ID. : GROEN KETTLE-EAST SIDE

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:23 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.1		1	ug/L	15	06/29/2016 9:36 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
B = Found in Blank
D.F. = Dilution Factor D = Results for Dilution
c = Calibration acceptability criteria exceeded for this analyte. Value estimated
H = Received/analyzed outside of analytical holding time
J = Estimated value - below calibration range
M-, M+ = Matrix Spike recovery below / above control limit
N = Indicates presumptive evidence of compound
P = Duplicate RPD outside of control limit
r = Reporting limit below calibration range. Value estimated.
S = Recovery outside of control limits for this analyte
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method
Result(s) reported meet(s) Regulatory Limit(s).
Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-020
Client Sample ID. : GROEN KETTLE-WEST SIDE

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:23 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.9		1	ug/L	15	06/29/2016 9:39 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-021
Client Sample ID. : 3 BAY SINK-WEST SIDE

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:25 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.9	PM-	1	ug/L	15	06/29/2016 9:42 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-022
Client Sample ID. : 3 BAY SINK-EAST SIDE

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:25 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 9:57 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-023
Client Sample ID. : SINK-STAINLESS ISLAND-ACROSS
FROM 3 BAY
Middle School

Attn To : David Chrisafulli

Federal ID :

Collected : 06/14/2016 4:26 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.5		1	ug/L	15	06/29/2016 10:00 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-024
Client Sample ID. : GROEN STEAMER NEXT TO KETTLES

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:27 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 93	*	1	ug/L	15	06/29/2016 10:02 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-025
Client Sample ID. : VULCAN STEAMER-NEXT TO 013F
COOLER-EAST
Middle School

Attn To : David Chrisafulli

Federal ID :

Collected : 06/14/2016 4:29 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.0		1	ug/L	15	06/29/2016 10:05 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
B = Found in Blank
D.F. = Dilution Factor D = Results for Dilution
c = Calibration acceptability criteria exceeded for this analyte. Value estimated
H = Received/analyzed outside of analytical holding time
J = Estimated value - below calibration range
M-, M+ = Matrix Spike recovery below / above control limit
N = Indicates presumptive evidence of compound
P = Duplicate RPD outside of control limit
r = Reporting limit below calibration range. Value estimated.
S = Recovery outside of control limits for this analyte
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method
Result(s) reported meet(s) Regulatory Limit(s).
Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-026
Client Sample ID. : VULCAN STEAMER-NEXT TO 013F
COOLER-WEST
Middle School

Attn To : David Chrisafulli
Federal ID :
Collected : 06/14/2016 4:30 AM Point No
Received : 06/14/2016 10:15 AM Location:
Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.3		1	ug/L	15	06/29/2016 10:08 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
B = Found in Blank
D.F. = Dilution Factor D = Results for Dilution
c = Calibration acceptability criteria exceeded for this analyte. Value estimated
H = Received/analyzed outside of analytical holding time
J = Estimated value - below calibration range
M-, M+ = Matrix Spike recovery below / above control limit
N = Indicates presumptive evidence of compound
P = Duplicate RPD outside of control limit
r = Reporting limit below calibration range. Value estimated.
S = Recovery outside of control limits for this analyte
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method
Result(s) reported meet(s) Regulatory Limit(s).
Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-027
Client Sample ID. : 3 BAY SINK BY PIZZA OVEN-EAST SIDE
Middle School

Attn To : David Chrisafulli
Federal ID :
Collected : 06/14/2016 4:32 AM Point No
Received : 06/14/2016 10:15 AM Location:
Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/29/2016 10:11 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
B = Found in Blank
D.F. = Dilution Factor D = Results for Dilution
c = Calibration acceptability criteria exceeded for this analyte. Value estimated
H = Received/analyzed outside of analytical holding time
J = Estimated value - below calibration range
M-, M+ = Matrix Spike recovery below / above control limit
N = Indicates presumptive evidence of compound
P = Duplicate RPD outside of control limit
r = Reporting limit below calibration range. Value estimated.
S = Recovery outside of control limits for this analyte
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method
Result(s) reported meet(s) Regulatory Limit(s).
Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-028
Client Sample ID. : 3 BAY SINK BY PIZZA OVEN-WEST SIDE
Middle School

Attn To : David Chrisafulli
Federal ID :
Collected : 06/14/2016 4:32 AM Point No
Received : 06/14/2016 10:15 AM Location:
Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/30/2016 4:06 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
B = Found in Blank
D.F. = Dilution Factor D = Results for Dilution
c = Calibration acceptability criteria exceeded for this analyte. Value estimated
H = Received/analyzed outside of analytical holding time
J = Estimated value - below calibration range
M-, M+ = Matrix Spike recovery below / above control limit
N = Indicates presumptive evidence of compound
P = Duplicate RPD outside of control limit
r = Reporting limit below calibration range. Value estimated.
S = Recovery outside of control limits for this analyte
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method
Result(s) reported meet(s) Regulatory Limit(s).
Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-029
Client Sample ID. : DF-UPPER GYM

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:36 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/30/2016 4:21 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-030
Client Sample ID. : ROOM 113-BOYS LOCKER ROOM-DF

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:37 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/30/2016 4:24 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-031
Client Sample ID. : ROOM 108A GYM STORAGE ICE
MACHINE
Middle School

Attn To : David Chrisafulli

Federal ID :

Collected : 06/14/2016 4:40 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/30/2016 4:27 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
B = Found in Blank
D.F. = Dilution Factor D = Results for Dilution
c = Calibration acceptability criteria exceeded for this analyte. Value estimated
H = Received/analyzed outside of analytical holding time
J = Estimated value - below calibration range
M-, M+ = Matrix Spike recovery below / above control limit
N = Indicates presumptive evidence of compound
P = Duplicate RPD outside of control limit
r = Reporting limit below calibration range. Value estimated.
S = Recovery outside of control limits for this analyte
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method
Result(s) reported meet(s) Regulatory Limit(s).
Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-032
Client Sample ID. : DF-ROOM 106

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:42 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/30/2016 4:30 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-033
Client Sample ID. : DF-ACROSS FROM ROOM 105

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:43 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/30/2016 4:33 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-034
Client Sample ID. : ROOM 104-POOL DF-NEXT TO 104C

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:45 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.4		1	ug/L	15	06/30/2016 4:36 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-035
Client Sample ID. : 102M-SINK IN OFFICE

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:46 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.7		1	ug/L	15	06/30/2016 4:39 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:
 Type : Potable Water
 Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-036
Client Sample ID. : 102G-SINK IN NURSES OFFICE

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:47 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	07/01/2016 10:57 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) Regulatory Limit(s).
 Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
 Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-037
Client Sample ID. : 102F-SINK IN NURSES OFFICE

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:50 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 22	*	1	ug/L	15	06/30/2016 4:56 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-038
Client Sample ID. : DF-NEXT TO ROOM 110

Attn To : David Chrisafulli

Middle School

Federal ID :

Collected : 06/14/2016 4:51 AM Point No

Received : 06/14/2016 10:15 AM Location:

Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	06/30/2016 4:59 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
Origin:

LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Oswego City School District
120 East First Street
Oswego, NY 13126

Lab No. : 1606F42-039
Client Sample ID. : KITCHEN-SINGLE SINK-ACROSS FROM
COMBI OVENS
Middle School

Attn To : David Chrisafulli
Federal ID :
Collected : 06/14/2016 4:34 AM Point No
Received : 06/14/2016 10:15 AM Location:
Collected By : Client

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.6		1	ug/L	15	06/30/2016 5:02 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
B = Found in Blank
D.F. = Dilution Factor D = Results for Dilution
c = Calibration acceptability criteria exceeded for this analyte. Value estimated
H = Received/analyzed outside of analytical holding time
J = Estimated value - below calibration range
M-, M+ = Matrix Spike recovery below / above control limit
N = Indicates presumptive evidence of compound
P = Duplicate RPD outside of control limit
r = Reporting limit below calibration range. Value estimated.
S = Recovery outside of control limits for this analyte
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method
Result(s) reported meet(s) Regulatory Limit(s).
Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.
Date Reported : 7/5/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



PACE ANALYTICAL
 575 Broad Hollow Road
 Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
 Website: www.pacelabs.com

QC SUMMARY REPORT

WO#: **1606F42**
05-Jul-16

Client: Oswego City School District
Project: Oswego City School District

BatchID: R100897

Sample ID	CalBlank	SampType:	MBLK	TestCode:	200.8_DW_R	Units:	ug/L	Prep Date:		RunNo:	100897					
Client ID:	PBW	Batch ID:	R100897	TestNo:	E200.8			Analysis Date:	6/29/2016	SeqNo:	2219924					
Analyte		Result		PQL		SPK value		SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		< 1.0		1.0												

Qualifiers:

*	Value exceeds Maximum Contaminant Level	D	Dilution was required.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	M	Manual Integration used to determine area response	ND	Not Detected at the Reporting Limit
O	RSD is greater than RSDlimit	P	Second column confirmation exceeds	R	RPD outside accepted recovery limits
S	Spike Recovery outside accepted recovery limits	W	Sample container temperature is out of limit as specified		



PACE ANALYTICAL
 575 Broad Hollow Road
 Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
 Website: www.pacelabs.com

QC SUMMARY REPORT

WO#: **1606F42**
 05-Jul-16

Client: Oswego City School District
Project: Oswego City School District

BatchID: R100902

Sample ID	CalBlank	SampType: MBLK	TestCode: 200.8_DW_R	Units: ug/L	Prep Date:	RunNo: 100902
Client ID:	PBW	Batch ID: R100902	TestNo: E200.8	Analysis Date: 6/29/2016	SeqNo: 2220128	
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead		< 1.0	1.0			

Qualifiers:

* Value exceeds Maximum Contaminant Level	D Dilution was required.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	M Manual Integration used to determine area response	ND Not Detected at the Reporting Limit
O RSD is greater than RSDlimit	P Second column confirmation exceeds	R RPD outside accepted recovery limits
S Spike Recovery outside accepted recovery limits	W Sample container temperature is out of limit as specified	



PACE ANALYTICAL
 575 Broad Hollow Road
 Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
 Website: www.pacelabs.com

QC SUMMARY REPORT

WO#: **1606F42**
05-Jul-16

Client: Oswego City School District
Project: Oswego City School District

BatchID: R101104

Sample ID	CalBlank	SampType: MBLK	TestCode: 200.8_DW_R	Units: ug/L	Prep Date:	RunNo: 101104
Client ID:	PBW	Batch ID: R101104	TestNo: E200.8	Analysis Date: 7/1/2016	SeqNo: 2224839	
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead		< 1.0	1.0			

Qualifiers:

*	Value exceeds Maximum Contaminant Level	D	Dilution was required.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	M	Manual Integration used to determine area response	ND	Not Detected at the Reporting Limit
O	RSD is greater than RSDlimit	P	Second column confirmation exceeds	R	RPD outside accepted recovery limits
S	Spike Recovery outside accepted recovery limits	W	Sample container temperature is out of limit as specified		



PACE ANALYTICAL
 575 Broad Hollow Road
 Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
 Website: www.pacelabs.com

Sample Receipt Checklist

Client Name **CITI** Date and Time Received: **6/14/2016 10:15:00 AM**

Work Order Number: **1606F42** RcptNo: **1** Received by **George Cappadona**

Completed by: *George A. Cappadona* Reviewed by: *Elizabeth Harrison*

Completed Date: 6/16/2016 11:03:58 AM Reviewed Date: 6/17/2016 12:33:34 PM

Carrier name: FedEx

- Chain of custody present? Yes No
- Chain of custody signed when relinquished and received? Yes No
- Chain of custody agrees with sample labels? Yes No
- Are matrices correctly identified on Chain of custody? Yes No
- Is it clear what analyses were requested? Yes No
- Custody seals intact on sample bottles? Yes No Not Present
- Samples in proper container/bottle? Yes No
- Were correct preservatives used and noted? Yes No NA
- Preservative added to bottles:
- Sample Condition? Intact Broken Leaking
- Sufficient sample volume for indicated test? Yes No
- Were container labels complete (ID, Pres, Date)? Yes No
- All samples received within holding time? Yes No
- Was an attempt made to cool the samples? Yes No NA
- All samples received at a temp. of > 0° C to 6.0° C? Yes No NA
- Response when temperature is outside of range:
- Sample Temp. taken and recorded upon receipt? Yes No To °
- Water - Were bubbles absent in VOC vials? Yes No No Vials
- Water - Was there Chlorine Present? Yes No NA
- Water - pH acceptable upon receipt? Yes No No Water
- Are Samples considered acceptable? Yes No
- Custody Seals present? Yes No
- Airbill or Sticker? Air Bil Sticker Not Present
- Airbill No: 7765-0906-8023

Case Number: SDG: SAS:

Any No response should be detailed in the comments section below, if applicable.

Client Contacted? Yes No NA Person Contacted:
 Contact Mode: Phone: Fax: Email: In Person:
 Client Instructions:
 Date Contacted: Contacted By:
 Regarding:
 Comments:
 CorrectiveAction:

WorkOrder :
1606F42

Certifications

STATE	CERTIFICATION #
NEW YORK	10478
NEW JERSEY	NY158
CONNECTICUT	PH-0435
MARYLAND	208
MAS S ACHUS E TTS	M-NY026
NE W HAMP S HIRE	2987
RHODE IS LAND	LAO00340
P E NNS YLVANIA	68-00350