



OSWEGO
CITY SCHOOL DISTRICT

Education Center

120 East First Street, Oswego, New York 13126
www.oswego.org

Dr. Dean F. Goewey
Superintendent of Schools
(315) 341-2001
FAX: (315) 341-2910
dgoewey@oswego.org

August 2, 2016

Dear Parents:

I am writing to inform you that during the month of June the Oswego City School District conducted testing of water fountains and water sources used for cooking in schools and facilities throughout the district.

Out of over 210 outlets tested, only the following outlets were problematic.

Initial tests indicate that we had the following areas come back with lead levels above the Oswego County threshold of 20 parts per billion.

OHS	Two Steam Kettles and One Sink
OMS	One Steam Kettle and One Sink
ED CTR	One Sink
FLS	Three Sinks and Two Drinking Fountains
CER	Five Drinking Fountains, Four Sinks and One Kettle
KPS	One -Sink and One Kettle
MIN	One Sink
FPS	No Findings

These outlets have been removed from service and re-testing of each of these outlets is occurring.

We will keep you informed of the results of our water testing and any actions which may need to be taken.

Sincerely,

Dean F. Goewey
Superintendent of Schools

/kkc